


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	3/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	0.050	0.050	OFF	OFF	0.050	
2	OFF	OFF	0.050	OFF	OFF	0.050	0.050	
3	OFF	OFF	0.020	OFF	OFF	0.010	0.020	
4	OFF	OFF	0.090	0.020	0.030	OFF	0.090	
5	OFF	OFF	OFF	0.040	0.040	0.040	0.040	
6	0.040	0.040	0.040	0.050	0.030	0.030	0.050	
7	0.020	OFF	OFF	0.030	0.040	0.030	0.040	
8	OFF	0.030	OFF	0.030	0.020	0.020	0.030	
9	0.080	0.050	0.030	0.030	0.030	0.080	0.080	
10	0.030	OFF	OFF	0.030	0.020	0.030	0.030	
11	OFF	OFF	0.030	0.020	0.020	0.020	0.030	
12	0.020	OFF	0.010	0.030	0.020	0.080	0.080	
13	OFF	OFF	OFF	0.020	0.060	0.070	0.070	
14	0.030	OFF	OFF	0.030	0.030	0.030	0.030	
15	0.030	0.040	0.080	0.030	0.030	0.080	0.080	
16	OFF	OFF	OFF	0.090	0.020	0.020	0.090	
17	OFF	0.030	0.040	0.020	0.020	0.010	0.040	
18	0.010	OFF	0.010	0.020	0.010	0.020	0.020	
19	OFF	0.020	0.010	0.020	0.010	0.020	0.020	
20	0.010	OFF	0.010	0.010	0.020	0.020	0.020	
21	0.020	0.040	OFF	0.030	0.060	0.060	0.060	
22	OFF	OFF	OFF	0.070	0.050	0.030	0.070	
23	0.070	OFF	OFF	0.080	0.090	0.090	0.090	
24	OFF	OFF	0.050	0.030	0.020	0.020	0.050	
25	0.010	OFF	0.040	0.060	0.030	0.020	0.060	
26	0.020	OFF	0.030	0.020	0.040	0.080	0.080	
27	0.040	OFF	0.030	0.070	0.030	0.040	0.070	
28	0.020	0.050	0.050	0.020	0.050	0.090	0.090	
29	0.010	0.040	0.020	0.070	0.020	0.090	0.090	
30	0.060	0.020	0.040	0.020	0.040	0.090	0.090	
31	0.040	OFF	0.050	0.040	0.020	0.080	0.080	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			4/7/2025
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Mar-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.69	115	79.4	9.4	8.02	27.8	YES	1000
2	0.71	115	81.7	9.3	7.62	24.3	YES	1000
3	0.65	115	74.8	9.5	7.98	27.1	YES	1000
4	0.69	115	79.4	9.4	7.88	26.4	YES	1000
5	0.69	115	79.4	9.2	7.78	25.8	YES	1000
6	0.83	115	95.5	8.8	7.70	26.2	YES	1000
7	0.81	115	93.2	8.9	7.71	26.1	YES	1000
8	0.88	115	101.2	8.9	7.73	26.5	YES	1000
9	0.83	115	95.5	9.2	7.75	26.0	YES	1000
10	0.60	115	69.0	9.2	8.18	29.5	YES	1000
11	0.81	115	93.2	9.1	8.46	33.7	YES	1000
12	0.87	115	100.1	9.2	7.84	27.0	YES	1000
13	0.70	115	80.5	9.2	8.13	29.3	YES	1000
14	0.75	115	86.3	8.9	7.93	28.0	YES	1000
15	0.69	115	79.4	8.9	8.18	30.5	YES	1000
16	0.59	115	67.9	9.0	8.03	28.3	YES	1000
17	0.88	115	101.2	8.8	7.88	28.1	YES	1000
18	0.77	115	88.6	8.8	8.11	30.2	YES	1000
19	0.74	115	85.1	9.1	7.81	26.5	YES	1000
20	0.78	115	89.7	9.1	7.83	26.8	YES	1000
21	0.63	115	72.5	9.2	8.22	30.1	YES	1000
22	0.68	115	78.2	9.2	7.77	25.7	YES	1000
23	0.75	115	86.3	9.4	7.79	25.8	YES	1000
24	0.91	115	104.7	9.7	8.50	33.2	YES	1000
25	0.92	115	105.8	9.9	7.58	23.6	YES	1000
26	0.92	115	105.8	10.4	7.68	23.6	YES	1000
27	0.85	115	97.8	10.2	7.72	24.1	YES	1000
28	0.82	115	94.3	9.9	7.70	24.3	YES	1000
29	0.85	115	97.8	9.6	7.66	24.6	YES	1000
30	1.12	115	128.8	9.4	7.66	25.7	YES	1000
31	0.91	115	104.7	9.5	8.15	30.4	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012