

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	4/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.010	0.060	0.010	0.060	0.020	0.010	0.060	
2	0.020	0.020	0.080	0.050	0.040	0.020	0.080	
3	0.070	0.030	0.020	0.020	0.020	0.050	0.070	
4	0.020	0.050	0.020	0.080	0.070	0.020	0.080	
5	0.010	0.040	0.090	0.070	0.020	0.030	0.090	
6	0.050	OFF	0.020	0.070	0.080	0.020	0.080	
7	0.050	OFF	0.020	0.040	0.060	0.020	0.060	
8	0.020	0.040	0.030	0.020	0.020	0.030	0.040	
9	0.040	0.020	OFF	OFF	0.090	0.050	0.090	
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15	OFF	OFF	OFF	0.080	OFF	OFF	OFF	
16	OFF	OFF	OFF	0.030	0.070	OFF	0.070	
17	OFF	OFF	0.020	0.030	OFF	OFF	0.030	
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21	OFF	OFF	OFF	0.020	0.030	OFF	0.030	
22	OFF	OFF	OFF	0.030	0.030	OFF	0.030	
23	OFF	OFF	0.060	0.060	0.040	OFF	0.060	
24	OFF	OFF	OFF	0.040	OFF	OFF	0.040	
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28	OFF	OFF	0.030	0.030	0.050	OFF	0.050	
29	OFF	OFF	0.030	0.070	0.030	OFF	0.070	
30	OFF	OFF	0.040	0.030	0.060	OFF	0.060	
31								
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			5/7/2025
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:

City of Tillamook

ID#: 41

00893

Month/Year:

Apr-25

Disinfection *Giardia* Log Inactiv:

0.5

Date / Time

Minimum Cl₂ Residual at 1st User (**C**) ³

Contact Time (T)

Actual CT

Temp

pH

Required CT

CT Met? ³

Peak Hourly Demand Flow

[ppm or mg/L]

[minutes]

C X T

[° C]

formula

Yes / No

[GPM]

1

0.86

115

98.9

9.25

7.77

26.2

YES

1000

2

0.72

115

82.8

9.45

7.91

26.7

YES

1000

3

0.84

115

96.6

9.48

7.79

25.9

YES

1000

4

0.82

115

94.3

9.31

7.97

27.9

YES

1000

5

0.87

115

100.1

9.83

8.11

28.5

YES

1000

6

0.83

115

95.5

10.36

7.91

25.5

YES

1000

7

0.85

115

97.8

10.29

7.73

24.0

YES

1000

8

0.81

115

93.2

10.16

7.93

25.9

YES

1000

9

0.72

115

82.8

9.73

7.69

24.2

YES

1000

10

0.58

115

66.7

10.12

8.10

26.9

YES

1000

11

0.56

115

64.4

10.03

8.11

27.1

YES

1000

12

0.53

115

61.0

9.97

7.93

25.4

YES

1000

13

0.52

115

59.8

9.72

7.88

25.4

YES

1000

14

0.50

115

57.5

10.02

7.86

24.6

YES

1000

15

0.48

115

55.2

10.35

7.86

24.0

YES

1000

16

0.63

115

72.5

10.35

8.13

26.9

YES

1000

17

0.81

115

93.2

10.40

7.72

23.7

YES

1000

18

0.67

115

77.1

10.42

7.76

23.6

YES

1000

19

0.60

115

69.0

10.85

7.75

22.7

YES

1000

20

0.57

115

65.6

10.79

7.75

22.7

YES

1000

21

0.55

115

63.3

10.62

7.76

23.0

YES

1000

22

0.61

115

70.2

10.25

7.78

23.9

YES

1000

23

0.73

115

84.0

10.24

7.74

23.9

YES

1000

24

0.58

115

66.7

10.40

7.77

23.5

YES

1000

25

0.58

115

66.7

10.87

7.75

22.6

YES

1000

26

0.52

115

59.8

10.90

7.75

22.4

YES

1000

27

0.50

115

57.5

10.87

7.75

22.4

YES

1000

28

0.75

115

86.3

10.97

7.72

22.6

YES

1000

29

0.68

115

78.2

11.16

7.72

22.2

YES

1000

30

0.56

115

64.4

10.97

8.02

24.6

YES

1000

31

115

0.0

4.3

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2