

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	5/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	0.030	0.020	0.030	0.030	0.030	
2	OFF	OFF	0.030	0.070	0.040	0.090	0.090	
3	OFF	OFF	OFF	0.030	0.030	0.030	0.030	
4	OFF	OFF	0.080	0.030	0.030	0.040	0.080	
5	OFF	OFF	OFF	OFF	0.040	OFF	0.040	
6	OFF	OFF	0.030	0.030	0.050	OFF	0.050	
7	OFF	OFF	OFF	0.030	0.030	OFF	0.030	
8	OFF	OFF	OFF	0.040	0.050	0.030	0.050	
9	OFF	OFF	OFF	0.040	0.030	0.030	0.040	
10	OFF	OFF	0.040	0.030	0.030	0.040	0.040	
11	OFF	OFF	0.040	OFF	0.040	0.030	0.040	
12	OFF	OFF	0.080	0.040	0.060	0.040	0.080	
13	OFF	OFF	OFF	0.040	0.050	0.050	0.050	
14	0.040	0.040	0.050	0.070	0.040	OFF	0.070	
15	OFF	OFF	OFF	OFF	0.040	0.050	0.050	
16	OFF	OFF	0.080	0.050	0.050	0.060	0.080	
17	OFF	OFF	0.050	0.090	0.060	0.050	0.090	
18	OFF	OFF	OFF	0.050	0.050	0.050	0.050	
19	OFF	OFF	OFF	OFF	0.050	0.050	0.050	
20	OFF	OFF	OFF	0.060	0.060	0.080	0.080	
21	0.050	OFF	OFF	0.080	0.070	OFF	0.080	
22	OFF	OFF	OFF	0.020	0.040	0.020	0.040	
23	OFF	OFF	OFF	0.030	0.030	OFF	0.030	
24	OFF	OFF	OFF	0.020	0.020	0.020	0.020	
25	OFF	OFF	OFF	0.030	0.040	0.030	0.040	
26	OFF	OFF	OFF	OFF	0.030	0.030	0.030	
27	OFF	OFF	OFF	0.050	0.020	0.020	0.050	
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	OFF	0.030	0.030	0.040	0.040	
30	OFF	OFF	OFF	0.030	0.030	0.030	0.030	
31	OFF	OFF	OFF	0.040	0.040	0.030	0.030	
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			6/10/2025
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:

City of Tillamook

ID#: 41

00893

Month/Year:

May-25

Disinfection *Giardia* Log Inactiv:

0.5

Date / Time

Minimum Cl₂ Residual at 1st User (**C**) ³

Contact Time (T)

Actual CT

Temp

pH

Required CT

CT Met? ³

Peak Hourly Demand Flow

[ppm or mg/L]

[minutes]

C X T

[° C]

formula

Yes / No

[GPM]

1

0.91

115

104.7

11.63

8.07

25.0

YES

1000

2

0.92

115

105.8

11.24

8.10

25.9

YES

1000

3

1.03

115

118.5

11.25

8.00

25.3

YES

1000

4

0.96

115

110.4

11.38

8.01

25.0

YES

1000

5

0.96

115

110.4

11.91

7.95

23.6

YES

1000

6

0.94

115

108.1

11.79

7.93

23.6

YES

1000

7

0.89

115

102.4

11.50

7.98

24.4

YES

1000

8

0.94

115

108.1

11.54

8.02

24.8

YES

1000

9

0.94

115

108.1

11.53

8.03

24.9

YES

1000

10

0.99

115

113.9

11.53

8.00

24.8

YES

1000

11

0.95

115

109.3

11.40

8.04

25.2

YES

1000

12

0.95

115

109.3

11.38

8.06

25.4

YES

1000

13

1.02

115

117.3

11.30

8.01

25.3

YES

1000

14

0.95

115

109.3

11.24

8.22

27.2

YES

1000

15

0.95

115

109.3

11.24

8.22

27.2

YES

1000

16

0.94

115

108.1

11.26

8.05

25.5

YES

1000

17

1.00

115

115.0

11.14

7.97

25.2

YES

1000

18

1.02

115

117.3

11.01

8.04

26.1

YES

1000

19

0.95

115

109.3

11.06

8.07

26.1

YES

1000

20

1.06

115

121.9

11.27

8.02

25.6

YES

1000

21

1.03

115

118.5

11.24

8.04

25.7

YES

1000

22

0.95

115

109.3

11.42

8.23

27.0

YES

1000

23

0.99

115

113.9

11.71

7.93

23.9

YES

1000

24

0.93

115

107.0

11.76

7.97

24.0

YES

1000

25

0.91

115

104.7

11.82

8.13

25.2

YES

1000

26

0.97

115

111.6

12.14

8.02

23.9

YES

1000

27

0.88

115

101.2

12.15

7.93

22.9

YES

1000

28

0.93

115

107.0

12.29

7.95

23.0

YES

1000

29

0.95

115

109.3

12.48

7.95

22.7

YES

1000

30

0.97

115

111.6

12.45

7.97

23.0

YES

1000

31

0.96

115

110.4

12.27

8.02

23.7

YES

1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2