

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	6/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.040	0.040	0.030	0.030	0.070	0.030	0.070	
2	OFF	OFF	0.030	0.030	0.030	0.030	0.030	
3	0.030	0.040	0.040	0.040	0.080	0.030	0.080	
4	OFF	OFF	OFF	0.040	0.040	0.040	0.040	
5	0.040	OFF	0.040	0.040	0.040	0.040	0.040	
6	0.040	0.040	0.040	0.040	0.040	0.040	0.040	
7	0.040	0.040	0.050	0.040	0.070	0.040	0.070	
8	0.040	0.060	0.040	0.040	0.040	0.050	0.060	
9	0.040	0.040	OFF	0.040	0.040	0.040	0.040	
10	0.040	0.040	0.040	0.050	0.050	0.050	0.050	
11	0.070	0.040	0.040	0.040	0.040	0.040	0.070	
12	0.040	OFF	0.060	0.040	0.040	0.050	0.060	
13	0.040	0.040	0.040	OFF	0.040	0.040	0.040	
14	0.040	0.040	0.040	0.040	0.040	0.050	0.050	
15	0.050	0.040	0.050	0.040	0.050	0.060	0.060	
16	0.040	0.040	OFF	0.040	0.040	0.040	0.040	
17	0.080	0.040	0.040	0.040	0.050	0.040	0.080	
18	0.040	0.040	0.040	0.040	0.060	0.050	0.060	
19	0.050	0.060	0.040	0.040	0.050	0.040	0.060	
20	0.040	0.040	0.040	0.040	0.050	0.050	0.050	
21	0.050	0.050	0.050	0.050	0.060	0.080	0.080	
22	0.060	OFF	OFF	OFF	OFF	OFF	0.060	
23	OFF	OFF	0.020	0.070	0.050	0.040	0.070	
24	0.040	0.020	0.040	0.020	0.050	0.050	0.050	
25	0.020	0.040	0.040	0.040	0.050	0.060	0.060	
26	0.050	0.040	OFF	0.060	0.020	0.020	0.060	
27	0.050	0.040	0.060	0.030	0.040	0.050	0.060	
28	0.020	0.020	0.040	0.030	0.050	0.040	0.050	
29	0.020	0.070	0.020	0.070	0.040	0.050	0.070	
30	0.060	0.020	0.020	0.030	0.050	0.030	0.060	
31								
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			7/2/2025
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:

City of Tillamook

ID#: 41

00893

Month/Year:

Jun-25

Disinfection *Giardia* Log Inactiv:

0.5

Date / Time

Minimum Cl₂ Residual at 1st User (**C**) ³

Contact Time (T)

Actual CT

Temp

pH

Required CT

CT Met? ³

Peak Hourly Demand Flow

[ppm or mg/L]

[minutes]

C X T

[° C]

formula

Yes / No

[GPM]

1

0.99

115

113.9

12.2

7.95

23.3

YES

1000

2

0.99

115

113.9

12.4

7.98

23.2

YES

1000

3

0.95

115

109.3

12.3

8.40

27.0

YES

1000

4

0.96

115

110.4

12.5

7.93

22.6

YES

1000

5

1.01

115

116.2

12.8

7.93

22.3

YES

1000

6

0.99

115

113.9

13.0

7.93

21.9

YES

1000

7

0.99

115

113.9

13.4

7.90

21.1

YES

1000

8

1.02

115

117.3

13.4

7.91

21.3

YES

1000

9

1.02

115

117.3

13.3

7.90

21.3

YES

1000

10

1.01

115

116.2

13.2

7.91

21.5

YES

1000

11

0.99

115

113.9

13.0

8.08

23.2

YES

1000

12

1.00

115

115.0

12.9

7.91

21.9

YES

1000

13

1.01

115

116.2

12.5

7.95

22.9

YES

1000

14

1.01

115

116.2

12.6

7.97

22.9

YES

1000

15

1.07

115

123.1

12.8

7.90

22.2

YES

1000

16

1.08

115

124.2

13.0

7.95

22.3

YES

1000

17

1.06

115

121.9

13.0

7.90

21.8

YES

1000

18

1.06

115

121.9

12.7

7.91

22.4

YES

1000

19

1.05

115

120.8

12.6

7.86

22.1

YES

1000

20

0.98

115

112.7

12.3

8.00

23.5

YES

1000

21

1.24

115

142.6

12.2

8.04

24.7

YES

1000

22

0.94

115

108.1

12.5

7.90

22.3

YES

1000

23

1.01

115

116.2

12.5

7.98

23.1

YES

1000

24

0.99

115

113.9

12.4

8.01

23.4

YES

1000

25

1.05

115

120.8

12.3

7.97

23.4

YES

1000

26

1.36

115

156.4

12.5

7.70

21.7

YES

1000

27

0.99

115

113.9

13.0

7.78

20.7

YES

1000

28

0.97

115

111.6

13.3

7.81

20.5

YES

1000

29

0.99

115

113.9

13.4

7.90

21.1

YES

1000

30

0.86

115

98.9

12.8

8.14

23.6

YES

1000

31

115

0.0

4.4

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2

1