

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	7/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.040	0.020	0.080	0.030	0.050	0.020	0.080	
2	0.050	0.070	0.040	0.030	0.040	0.030	0.070	
3	0.020	0.040	0.030	0.060	0.040	0.020	0.060	
4	0.040	0.040	0.050	0.030	0.040	0.050	0.050	
5	0.040	0.040	0.030	0.030	0.040	0.050	0.050	
6	0.030	0.040	0.030	0.030	0.070	0.040	0.070	
7	0.030	0.050	0.030	0.030	0.040	0.050	0.050	
8	0.040	0.040	0.050	0.030	0.040	0.070	0.070	
9	0.050	0.040	0.050	0.030	0.050	0.050	0.050	
10	0.030	0.050	0.040	0.040	0.040	0.030	0.050	
11	0.040	0.060	0.030	0.060	0.060	0.040	0.060	
12	0.040	0.040	0.050	0.040	0.050	0.060	0.060	
13	0.060	0.040	0.050	0.050	0.060	0.040	0.060	
14	0.060	0.060	0.090	0.040	0.060	0.050	0.090	
15	0.060	0.050	0.040	0.060	0.040	0.040	0.060	
16	0.050	0.060	0.040	0.060	0.070	0.060	0.070	
17	0.090	0.050	0.060	0.060	0.080	0.050	0.090	
18	0.070	0.070	0.070	0.070	0.070	0.050	0.070	
19	0.090	0.060	0.080	0.070	0.080	0.090	0.090	
20	0.090	0.080	0.070	0.070	0.080	0.080	0.090	
21	0.070	0.070	0.070	0.070	0.080	0.070	0.080	
22	0.080	0.070	0.080	0.020	0.060	0.040	0.080	
23	0.020	0.020	0.030	0.020	0.030	0.020	0.030	
24	0.030	0.060	0.040	0.040	0.040	0.020	0.060	
25	0.040	0.020	0.030	0.040	0.030	0.020	0.040	
26	0.020	0.020	0.030	0.030	0.040	0.040	0.040	
27	0.040	0.030	0.030	0.030	0.030	0.040	0.040	
28	0.030	0.040	0.030	0.030	0.040	0.020	0.040	
29	0.050	0.030	0.040	0.020	0.030	0.020	0.050	
30	0.020	0.030	0.050	0.030	0.040	0.050	0.050	
31	0.030	0.030	0.030	0.030	0.060	0.020	0.060	
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			8/7/2025
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :
Disinfection *Giardia*
Log Inactiv:

A
0.5

System Name:

City of Tillamook

ID#: 41

00893

Month/Year:

Jul-25

Date / Time

Minimum Cl₂
Residual at 1st
User (**C**) ³

Contact Time
(**T**)

Actual CT

Temp

pH

Required CT

CT Met? ³

Peak Hourly
Demand Flow

[ppm or mg/L]

[minutes]

C X T

[° C]

formula

Yes / No

[GPM]

1

1.00

115

115.0

13.5

7.94

21.3

YES

1000

2

0.96

115

110.4

13.5

7.97

21.4

YES

1000

3

0.96

115

110.4

13.3

7.97

21.7

YES

1000

4

1.98

115

227.7

13.3

7.94

24.1

YES

1000

5

1.98

115

227.7

13.4

7.84

23.1

YES

1000

6

1.98

115

227.7

13.6

8.33

27.3

YES

1000

7

0.78

115

89.7

13.7

8.66

26.7

YES

1000

8

1.11

115

127.7

13.6

7.97

21.7

YES

1000

9

1.6

115

184.0

13.7

7.91

22.3

YES

1000

10

1.00

115

115.0

13.8

7.95

21.0

YES

1000

11

1.04

115

119.6

13.9

7.88

20.4

YES

1000

12

0.94

115

108.1

14.2

7.89

19.8

YES

1000

13

1.05

115

120.8

14.1

7.89

20.2

YES

1000

14

0.86

115

98.9

14.1

8.71

26.7

YES

1000

15

1.01

115

116.2

14.3

7.78

19.1

YES

1000

16

0.99

115

113.9

14.2

7.82

19.4

YES

1000

17

1.02

115

117.3

14.0

7.79

19.5

YES

1000

18

0.98

115

112.7

14.0

7.83

19.7

YES

1000

19

1.00

115

115.0

13.9

7.85

20.1

YES

1000

20

0.97

115

111.6

13.7

7.90

20.6

YES

1000

21

0.87

115

100.1

13.7

8.38

24.4

YES

1000

22

1.00

115

115.0

13.7

7.86

20.4

YES

1000

23

1.98

115

227.7

13.8

7.88

22.8

YES

1000

24

1.14

115

131.1

13.9

7.91

20.8

YES

1000

25

1.02

115

117.3

13.8

7.87

20.4

YES

1000

26

1.00

115

115.0

13.6

7.91

20.9

YES

1000

27

0.97

115

111.6

13.8

7.93

20.7

YES

1000

28

0.76

115

87.4

13.9

8.34

23.4

YES

1000

29

1.09

115

125.4

13.8

7.88

20.6

YES

1000

30

1.03

115

118.5

14.2

7.90

20.1

YES

1000

31

0.82

115

94.3

13.6

7.47

17.9

YES

1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2