

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	8/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.020	0.040	0.060	0.020	0.080	0.070	0.080	
2	0.020	0.020	OFF	0.040	0.020	0.020	0.040	
3	0.030	0.040	0.030	0.020	0.030	0.030	0.040	
4	0.020	0.020	0.030	0.030	0.050	0.050	0.050	
5	0.070	0.040	0.040	0.040	0.040	0.070	0.070	
6	0.060	0.030	0.040	0.050	0.040	0.070	0.070	
7	0.090	0.060	0.030	0.030	0.030	0.040	0.090	
8	0.040	0.040	0.040	0.040	0.040	0.040	0.040	
9	0.040	0.040	0.040	0.040	0.040	0.040	0.040	
10	0.040	0.040	0.060	0.040	0.040	0.040	0.060	
11	0.050	0.050	0.060	0.040	0.050	0.090	0.090	
12	0.050	0.040	0.050	0.060	0.090	0.050	0.090	
13	0.050	0.050	OFF	0.050	0.050	0.050	0.050	
14	0.060	0.050	0.050	0.050	0.060	0.060	0.060	
15	0.060	0.060	0.070	0.060	0.060	0.070	0.070	
16	OFF	OFF	0.090	0.090	0.060	0.060	0.090	
17	0.060	0.060	0.060	0.060	0.060	0.060	0.060	
18	0.060	0.060	0.060	0.060	0.070	0.080	0.080	
19	0.070	0.070	0.070	0.060	0.070	0.080	0.080	
20	OFF	0.080	0.090	OFF	0.080	OFF	0.090	
21	0.080	0.080	0.080	0.080	OFF	OFF	0.080	
22	0.030	0.030	0.060	0.030	0.050	0.040	0.050	
23	0.030	0.040	0.020	0.040	0.090	0.040	0.090	
24	0.040	0.050	0.050	0.040	0.040	0.050	0.050	
25	0.040	0.050	0.020	0.050	0.050	0.050	0.050	
26	0.050	0.040	0.040	0.030	0.040	0.040	0.050	
27	0.040	0.030	0.030	0.020	0.040	0.050	0.050	
28	0.040	0.030	OFF	OFF	OFF	OFF	0.040	
29	OFF	OFF	0.030	OFF	0.070	0.030	0.070	
30	OFF	OFF	OFF	0.030	OFF	0.040	0.040	
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			9/4/2025
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :
Disinfection *Giardia*
Log Inactiv:

A
0.5

System Name:

City of Tillamook

ID#: 41

00893

Month/Year:

Aug-25

Date / Time

Minimum Cl₂
Residual at 1st
User (**C**) ³

Contact Time
(**T**)

Actual CT

Temp

pH

Required CT

CT Met? ³

Peak Hourly
Demand Flow

[ppm or mg/L]

[minutes]

C X T

[° C]

formula

Yes / No

[GPM]

1

1.00

115

115.0

14.1

7.86

19.9

YES

1000

2

1.02

115

117.3

13.9

7.86

20.2

YES

1000

3

1.02

115

117.3

13.7

7.80

20.0

YES

1000

4

0.99

115

113.9

13.8

7.85

20.2

YES

1000

5

0.97

115

111.6

13.8

7.76

19.5

YES

1000

6

0.93

115

107.0

13.5

7.69

19.3

YES

1000

7

0.94

115

108.1

13.5

7.74

19.7

YES

1000

8

0.96

115

110.4

13.8

7.67

18.8

YES

1000

9

0.98

115

112.7

14.2

7.71

18.6

YES

1000

10

0.99

115

113.9

14.3

7.65

18.1

YES

1000

11

1.06

115

121.9

14.4

7.69

18.4

YES

1000

12

0.99

115

113.9

14.3

7.64

18.1

YES

1000

13

1.02

115

117.3

14.3

7.70

18.5

YES

1000

14

0.99

115

113.9

14.2

7.65

18.3

YES

1000

15

0.87

115

100.1

14.0

7.68

18.5

YES

1000

16

1.02

115

117.3

13.7

7.61

18.7

YES

1000

17

1.02

115

117.3

13.7

7.56

18.3

YES

1000

18

0.97

115

111.6

13.7

7.55

18.1

YES

1000

19

1.03

115

118.5

13.9

7.60

18.4

YES

1000

20

0.99

115

113.9

13.8

7.61

18.5

YES

1000

21

0.96

115

110.4

13.9

7.50

17.6

YES

1000

22

1.00

115

115.0

14.0

7.59

18.1

YES

1000

23

0.96

115

110.4

14.1

7.50

17.3

YES

1000

24

0.95

115

109.3

14.1

7.62

18.1

YES

1000

25

1.01

115

116.2

13.9

7.55

18.0

YES

1000

26

0.98

115

112.7

13.5

7.57

18.5

YES

1000

27

0.95

115

109.3

13.4

7.60

18.8

YES

1000

28

1.00

115

115.0

13.3

7.54

18.6

YES

1000

29

0.97

115

111.6

13.2

7.49

18.3

YES

1000

30

0.78

115

89.7

13.3

7.36

17.0

YES

1000

31

0.62

115

71.3

12.9

7.36

17.5

YES

OFF

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2