

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	9/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2	OFF	OFF	0.020	0.020	0.070	0.030	0.070	
3	0.070	0.020	0.030	0.030	0.020	0.030	0.070	
4	0.030	0.030	OFF	0.020	0.030	0.040	0.040	
5	0.030	OFF	0.030	0.030	0.040	0.020	0.040	
6	0.040	0.030	OFF	0.030	0.040	0.040	0.040	
7	0.050	OFF	0.040	0.070	0.070	0.050	0.070	
8	0.040	0.040	OFF	0.040	0.040	0.040	0.040	
9	0.070	OFF	0.040	0.040	0.040	0.030	0.070	
10	0.040	0.040	0.050	0.040	0.030	0.040	0.040	
11	0.070	0.040	0.040	0.040	0.050	0.030	0.070	
12	0.030	0.050	0.050	0.090	0.040	0.040	0.090	
13	OFF	0.040	0.050	0.050	0.060	0.040	0.060	
14	0.040	0.040	0.090	OFF	0.090	0.030	0.090	
15	0.050	OFF	0.050	0.050	0.060	0.090	0.090	
16	0.050	0.050	0.050	0.050	0.050	0.050	0.050	
17	0.080	0.050	0.050	0.070	0.090	0.050	0.090	
18	0.080	0.080	OFF	0.050	0.050	0.080	0.080	
19	0.070	OFF	0.050	0.060	0.070	0.060	0.070	
20	0.050	0.060	0.060	0.060	0.050	0.070	0.070	
21	0.070	0.060	0.060	OFF	0.070	0.080	0.080	
22	0.060	0.060	OFF	0.060	0.060	0.060	0.060	
23	0.080	0.060	0.060	0.070	0.060	0.060	0.080	
24	0.070	0.070	OFF	0.060	0.060	OFF	0.070	
25	OFF	OFF	OFF	OFF	0.060	0.090	0.090	
26	0.060	0.070	OFF	OFF	OFF	OFF	0.070	
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	OFF	OFF	0.090	OFF	0.090	
30	OFF	OFF	0.090	OFF	OFF	0.070	0.090	
31								
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			10/1/2025
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:

City of Tillamook

ID#: 41

00893

Month/Year:

Sep-25

Disinfection *Giardia* Log Inactiv:

0.5

Date / Time

Minimum Cl₂ Residual at 1st User (**C**) ³

Contact Time (T)

Actual CT

Temp

pH

Required CT

CT Met? ³

Peak Hourly Demand Flow

[ppm or mg/L]

[minutes]

C X T

[° C]

formula

Yes / No

[GPM]

1

0.97

115

111.6

13.5

7.48

17.9

YES

1000

2

1.00

115

115.0

13.5

7.56

18.5

YES

1000

3

0.97

115

111.6

13.3

7.52

18.4

YES

1000

4

0.94

115

108.1

13.3

7.60

18.9

YES

1000

5

1.00

115

115.0

13.3

7.52

18.5

YES

1000

6

0.97

115

111.6

13.4

7.56

18.6

YES

1000

7

1.01

115

116.2

13.4

7.81

20.5

YES

1000

8

1.01

115

116.2

13.3

7.59

19.0

YES

1000

9

1.98

115

227.7

13.2

7.79

23.0

YES

1000

10

1.98

115

227.7

13.1

7.96

24.6

YES

1000

11

1.98

115

227.7

13.1

7.80

23.2

YES

1000

12

1.98

115

227.7

13.1

7.93

24.3

YES

1000

13

1.98

115

227.7

13.1

7.94

24.4

YES

1000

14

1.87

115

215.1

12.9

7.47

20.6

YES

1000

15

1.04

115

119.6

13.1

7.32

17.5

YES

1000

16

1.03

115

118.5

13.1

7.46

18.4

YES

1000

17

1.01

115

116.2

13.0

7.44

18.3

YES

1000

18

1.00

115

115.0

12.7

7.60

19.8

YES

1000

19

1.02

115

117.3

12.6

7.44

18.9

YES

1000

20

0.98

115

112.7

12.7

7.57

19.6

YES

1000

21

0.97

115

111.6

12.5

7.48

19.2

YES

1000

22

1.00

115

115.0

12.7

7.54

19.4

YES

1000

23

1.06

115

121.9

12.6

7.50

19.4

YES

1000

24

1.02

115

117.3

12.4

7.56

20.1

YES

1000

25

1.00

115

115.0

12.2

7.46

19.6

YES

1000

26

0.54

115

62.1

12.4

7.25

17.1

YES

1000

27

0.50

115

57.5

12.5

7.23

16.6

YES

1000

28

0.98

115

112.7

12.5

7.43

18.8

YES

1000

29

0.93

115

107.0

12.4

7.34

18.4

YES

1000

30

0.70

115

80.5

12.2

7.12

16.9

YES

1000

31

115

0.0

4.4

YES

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2