

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	10/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.080	OFF	OFF	OFF	OFF	0.020	0.080	
2	OFF	OFF	OFF	0.020	0.040	OFF	0.040	
3	OFF	OFF	OFF	0.030	0.030	0.040	0.040	
4	OFF	OFF	0.020	0.030	0.020	0.070	0.070	
5	OFF	OFF	OFF	0.030	0.030	0.090	0.090	
6	OFF	OFF	0.040	0.060	0.060	0.020	0.060	
7	0.030	0.030	OFF	OFF	0.010	0.030	0.030	
8	OFF	OFF	OFF	OFF	0.020	0.020	0.020	
9	OFF	OFF	0.030	0.020	0.020	OFF	0.030	
10	OFF	OFF	OFF	0.020	0.020	0.070	0.070	
11	OFF	OFF	OFF	0.040	0.050	0.040	0.050	
12	OFF	OFF	OFF	0.030	0.060	0.040	0.060	
13	OFF	OFF	OFF	0.070	0.020	0.030	0.070	
14	OFF	OFF	0.030	0.020	0.030	0.040	0.040	
15	OFF	OFF	OFF	0.020	0.040	0.080	0.080	
16	0.060	0.030	0.050	0.020	0.060	0.020	0.060	
17	0.020	0.040	0.020	0.040	0.050	0.040	0.050	
18	0.040	OFF	0.040	0.030	0.080	0.070	0.080	
19	0.060	0.070	0.070	0.080	0.040	0.090	0.090	
20	OFF	0.020	0.050	0.030	0.020	0.020	0.050	
21	0.030	0.020	0.030	0.040	0.050	0.030	0.050	
22	0.020	0.020	0.040	0.040	OFF	OFF	0.040	
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28	OFF	OFF	OFF	0.020	0.020	0.080	0.080	
29	0.040	0.040	0.050	0.070	0.020	0.030	0.070	
30	0.030	0.040	0.030	0.020	0.040	0.020	0.040	
31	0.040	0.030	0.020	0.030	0.040	0.040	0.040	
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			11/10/2025
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:

City of Tillamook

ID#: 41

00893

Month/Year:

Oct-25

Disinfection *Giardia* Log Inactiv:

0.5

Date / Time

Minimum Cl₂ Residual at 1st User (**C**) ³

Contact Time (T)

Actual CT

Temp

pH

Required CT

CT Met? ³

Peak Hourly Demand Flow

[ppm or mg/L]

[minutes]

C X T

[° C]

formula

Yes / No

[GPM]

1

0.85

115

97.8

12.3

7.61

20.2

YES

1000

2

0.87

115

100.1

12.2

7.35

18.6

YES

1000

3

0.89

115

102.4

12.1

7.44

19.4

YES

1000

4

0.87

115

100.1

12.2

7.37

18.7

YES

1000

5

0.93

115

107.0

12.1

7.49

19.8

YES

1000

6

0.95

115

109.3

12.0

7.55

20.4

YES

1000

7

0.95

115

109.3

12.0

7.47

19.8

YES

1000

8

0.98

115

112.7

12.0

7.46

19.8

YES

1000

9

0.98

115

112.7

11.7

7.62

21.4

YES

1000

10

0.84

115

96.6

11.6

7.55

20.7

YES

1000

11

0.93

115

107.0

11.5

7.56

21.1

YES

1000

12

0.87

115

100.1

11.4

7.53

20.9

YES

1000

13

0.89

115

102.4

11.1

7.59

21.8

YES

1000

14

0.90

115

103.5

10.8

7.59

22.2

YES

1000

15

0.99

115

113.9

10.7

7.56

22.4

YES

1000

16

1.00

115

115.0

10.7

7.64

23.1

YES

1000

17

1.04

115

119.6

11.0

7.61

22.5

YES

1000

18

1.01

115

116.2

10.7

7.64

23.1

YES

1000

19

1.55

115

178.3

11.0

7.710

24.7

YES

1000

20

1.26

115

144.9

10.8

7.87

25.6

YES

1000

21

0.99

115

113.9

10.7

7.60

22.7

YES

1000

22

0.94

115

108.1

11.2

10.92

73.9

YES

1000

23

0.52

115

59.8

15.3

8.32

20.6

YES

OFF

24

0.51

115

58.7

12.8

8.89

29.9

YES

OFF

25

0.44

115

50.6

12.8

9.44

36.3

YES

OFF

26

0.39

115

44.9

12.4

10.98

64.9

YES

OFF

27

0.36

115

41.4

10.4

8.52

29.9

YES

OFF

28

1.11

115

127.7

11.0

8.03

26.3

YES

1000

29

1.21

115

139.2

11.0

8.10

27.3

YES

1000

30

1.41

115

162.2

10.3

8.00

28.2

YES

1000

31

1.22

115

140.3

10.0

8.03

29.1

YES

1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2