

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	11/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.040	0.060	0.060	OFF	OFF	OFF	0.060	
2	OFF	OFF	OFF	0.020	0.030	0.050	0.050	
3	OFF	OFF	0.020	0.040	0.020	0.040	0.040	
4	0.050	0.020	0.040	0.020	0.020	0.050	0.050	
5	0.020	0.090	0.030	0.060	0.040	0.050	0.060	
6	0.030	0.030	0.030	0.030	0.040	0.080	0.080	
7	0.020	OFF	OFF	0.070	0.080	0.090	0.090	
8	OFF	OFF	0.090	0.020	0.030	0.020	0.090	
9	0.030	0.090	0.020	0.030	0.040	0.090	0.090	
10	0.030	0.060	0.050	0.090	0.020	0.030	0.090	
11	0.030	0.020	0.030	0.040	0.020	0.020	0.040	
12	0.080	0.030	0.020	0.020	0.090	0.090	0.090	
13	0.030	0.030	0.080	0.020	0.040	0.090	0.090	
14	0.040	0.030	0.050	0.040	0.040	0.050	0.050	
15	0.070	0.020	0.080	0.030	0.040	0.050	0.080	
16	0.030	0.050	0.040	0.070	0.030	0.060	0.070	
17	0.030	0.050	0.040	OFF	0.030	0.030	0.050	
18	0.060	0.030	0.050	0.040	0.030	0.030	0.060	
19	0.030	0.040	0.030	0.030	0.030	0.030	0.040	
20	0.050	0.050	0.050	0.050	0.030	0.030	0.050	
21	0.030	OFF	0.030	0.050	0.040	0.040	0.050	
22	0.030	0.090	0.040	0.040	0.030	0.040	0.090	
23	0.040	0.030	OFF	0.040	0.040	0.050	0.050	
24	0.040	0.040	0.040	0.040	0.040	0.050	0.050	
25	0.040	0.040	0.040	0.040	0.040	0.060	0.060	
26	0.050	0.080	0.040	0.040	0.040	0.040	0.080	
27	0.040	OFF	0.040	0.050	0.040	0.040	0.050	
28	0.050	0.050	0.090	0.080	0.040	0.090	0.090	
29	OFF	OFF	0.050	0.040	0.010	0.030	0.050	
30	0.030	OFF	0.070	0.070	0.020	0.020	0.070	
31								
Conventional or Direct Filtration					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			12/08/2025
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:

City of Tillamook

ID#: 41

00893

Month/Year:

Nov-25

Disinfection *Giardia* Log Inactiv:

0.5

Date / Time

Minimum Cl₂ Residual at 1st User (**C**) ³

Contact Time (T)

Actual CT

Temp

pH

Required CT

CT Met? ³

Peak Hourly Demand Flow

[ppm or mg/L]

[minutes]

C X T

[° C]

formula

Yes / No

[GPM]

1

1.16

115

133.8

59.6

8.27

0.8

YES

1000

2

1.25

115

143.8

60.1

8.33

0.8

YES

1000

3

1.37

115

157.9

61.9

8.42

0.8

YES

1000

4

1.26

115

145.0

59.8

8.31

0.9

YES

1000

5

1.32

115

151.5

62.0

8.43

0.7

YES

1000

6

1.40

115

160.8

59.5

8.29

0.9

YES

1000

7

1.25

115

143.5

60.5

8.33

0.8

YES

1000

8

1.35

115

155.7

59.8

8.34

0.9

YES

1000

9

1.35

115

155.0

60.0

8.36

0.9

YES

1000

10

1.28

115

147.4

59.6

8.29

0.9

YES

1000

11

1.32

115

152.1

60.1

8.34

0.8

YES

1000

12

1.20

115

138.6

60.0

8.36

0.9

YES

1000

13

1.32

115

151.2

60.7

8.39

0.8

YES

1000

14

1.30

115

149.2

61.8

8.43

0.8

YES

1000

15

1.30

115

150.0

59.3

8.29

0.9

YES

1000

16

1.32

115

151.9

59.9

8.33

0.9

YES

1000

17

1.34

115

154.3

60.3

8.34

0.8

YES

1000

18

1.32

115

151.6

62.2

8.42

0.7

YES

1000

19

1.28

115

146.7

60.4

8.39

0.8

YES

1000

20

1.40

115

161.3

60.4

8.41

0.9

YES

1000

21

1.40

115

161.2

60.9

8.41

0.8

YES

1000

22

1.54

115

177.6

58.2

8.26

1.0

YES

1000

23

1.28

115

147.4

59.4

8.34

0.9

YES

1000

24

1.30

115

149.4

59.0

8.27

0.9

YES

1000

25

1.53

115

175.6

61.8

8.44

0.8

YES

1000

26

1.37

115

157.5

59.1

8.31

0.9

YES

1000

27

2.06

115

237.3

58.7

8.31

1.1

YES

1000

28

1.65

115

190.2

58.8

8.25

1.0

YES

1000

29

2.06

115

237.3

59.2

8.30

1.0

YES

1000

30

1.31

115

151.0

62.8

8.49

0.7

YES

1000

31

115

0.0

4.6

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012

PAGE 2 of 2