

OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	12/1/2025
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.070	0.020	0.020	0.020	0.020	0.030	0.070	
2	0.020	0.020	OFF	0.020	0.080	0.020	0.080	
3	0.020	0.020	0.020	0.020	0.050	0.030	0.050	
4	0.040	0.020	0.020	0.020	0.050	OFF	0.050	
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22	OFF	OFF	OFF	OFF	0.060	OFF	0.060	
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	0.080	OFF	OFF	OFF	0.080	
30	OFF	OFF	OFF	0.070	0.040	0.020	0.070	
31	0.020	0.020	OFF	0.020	0.020	0.070	0.070	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
				PRINTED NAME: Levi Beachy				
				SIGNATURE: 			1/6/2026	
				PHONE #: (503) 812-8804				
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Dec-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° F]		formula	Yes / No	[GPM]
1	1.31	115	150.7	62.7	8.49	0.7	YES	1000
2	2.06	115	237.3	60.4	8.40	1.0	YES	1000
3	1.53	115	176.2	60.2	8.37	0.9	YES	1000
4	2.06	115	237.3	59.7	8.01	0.8	YES	1000
5	0.61	115	69.6	61.8	8.48	0.7	YES	OFF
6	0.60	115	68.4	60.0	8.42	0.8	YES	OFF
7	0.56	115	64.2	62.5	8.51	0.6	YES	OFF
8	0.54	115	61.9	60.6	8.08	0.6	YES	OFF
9	0.52	115	59.8	61.7	8.41	0.7	YES	OFF
10	0.50	115	57.8	60.9	8.42	0.7	YES	OFF
11	0.49	115	56.7	63.4	8.54	0.6	YES	OFF
12	0.48	115	55.4	61.9	8.47	0.7	YES	OFF
13	0.47	115	53.6	62.1	8.44	0.6	YES	OFF
14	0.45	115	51.6	59.0	8.28	0.8	YES	OFF
15	0.44	115	50.4	61.2	8.39	0.7	YES	OFF
16	0.44	115	50.1	60.1	8.11	0.6	YES	OFF
17	0.43	115	49.2	60.1	8.31	0.7	YES	OFF
18	0.41	115	47.4	61.8	8.43	0.6	YES	OFF
19	0.40	115	46.2	61.8	8.41	0.6	YES	OFF
20	0.40	115	45.8	61.8	8.41	0.6	YES	OFF
21	0.40	115	45.4	61.5	8.40	0.6	YES	OFF
22	0.91	115	104.7	61.2	8.10	0.6	YES	1000
23	1.53	115	175.8	63.4	8.49	0.7	YES	OFF
24	0.46	115	52.4	61.6	8.42	0.7	YES	OFF
25	0.43	115	49.3	60.5	8.31	0.7	YES	OFF
26	0.42	115	48.3	60.5	8.30	0.7	YES	OFF
27	0.40	115	46.6	60.1	8.28	0.7	YES	OFF
28	0.39	115	45.4	60.6	8.31	0.7	YES	OFF
29	1.03	115	118.4	62.2	8.06	0.6	YES	1000
30	1.09	115	124.9	61.9	8.41	0.7	YES	1000
31	0.95	115	109.3	60.7	8.34	0.8	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012