

| OHA - Drinking Water Program -Turbidity Monitoring Report Form | | | | | | | County: | Tillamook |
|--|-------------------|------------|------------|------------------------------------|--|------------|---|-----------|
| Conventional or Direct Filtration | | | | | | | Month/Year: | 1/1/2026 |
| System Name: | City of Tillamook | | | ID#: 41 | 00893 | | WTP : TP - | Combined |
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day ¹ [NTU] | |
| 1 | 0.060 | 0.020 | 0.020 | 0.020 | 0.080 | 0.080 | 0.080 | |
| 2 | 0.020 | 0.020 | 0.020 | 0.090 | 0.030 | 0.030 | 0.090 | |
| 3 | 0.090 | 0.030 | 0.030 | 0.020 | 0.020 | 0.020 | 0.090 | |
| 4 | 0.020 | 0.030 | 0.070 | 0.090 | 0.090 | 0.050 | 0.090 | |
| 5 | 0.030 | 0.050 | 0.040 | 0.060 | 0.020 | 0.020 | 0.060 | |
| 6 | 0.020 | 0.030 | 0.030 | 0.030 | 0.030 | 0.060 | 0.060 | |
| 7 | 0.040 | 0.040 | 0.050 | OFF | OFF | 0.040 | 0.050 | |
| 8 | OFF | OFF | 0.030 | 0.020 | 0.020 | 0.020 | 0.030 | |
| 9 | 0.030 | 0.020 | 0.090 | OFF | 0.020 | 0.020 | 0.090 | |
| 10 | 0.090 | 0.050 | 0.090 | 0.070 | 0.020 | 0.060 | 0.090 | |
| 11 | 0.060 | 0.080 | 0.060 | 0.070 | 0.050 | 0.020 | 0.080 | |
| 12 | 0.080 | 0.020 | 0.020 | 0.040 | 0.030 | 0.020 | 0.080 | |
| 13 | 0.080 | 0.040 | 0.020 | 0.030 | 0.020 | 0.020 | 0.080 | |
| 14 | 0.080 | 0.030 | 0.070 | 0.070 | 0.060 | 0.050 | 0.080 | |
| 15 | 0.050 | OFF | 0.070 | 0.040 | 0.080 | 0.080 | 0.080 | |
| 16 | 0.050 | 0.050 | 0.080 | 0.050 | 0.050 | 0.050 | 0.080 | |
| 17 | 0.080 | 0.060 | 0.050 | 0.050 | 0.060 | 0.060 | 0.080 | |
| 18 | 0.070 | 0.060 | 0.060 | 0.060 | 0.070 | 0.060 | 0.070 | |
| 19 | 0.080 | 0.060 | OFF | 0.060 | 0.070 | OFF | 0.080 | |
| 20 | 0.090 | 0.040 | 0.020 | 0.070 | 0.020 | 0.060 | 0.090 | |
| 21 | 0.050 | 0.020 | 0.020 | 0.070 | 0.050 | 0.040 | 0.070 | |
| 22 | 0.020 | 0.020 | 0.020 | 0.020 | 0.020 | 0.020 | 0.020 | |
| 23 | 0.020 | 0.050 | 0.050 | 0.020 | 0.040 | 0.020 | 0.050 | |
| 24 | 0.050 | 0.070 | 0.080 | OFF | OFF | OFF | 0.080 | |
| 25 | OFF | OFF | OFF | OFF | OFF | OFF | OFF | |
| 26 | OFF | OFF | OFF | OFF | OFF | OFF | OFF | |
| 27 | OFF | OFF | OFF | 0.060 | 0.030 | 0.050 | 0.060 | |
| 28 | 0.090 | 0.090 | 0.020 | 0.060 | 0.050 | 0.080 | 0.080 | |
| 29 | 0.030 | 0.030 | 0.020 | 0.030 | 0.030 | 0.090 | 0.090 | |
| 30 | 0.030 | 0.020 | 0.040 | 0.060 | 0.080 | 0.030 | 0.080 | |
| 31 | 0.020 | 0.040 | 0.020 | 0.050 | 0.020 | 0.040 | 0.050 | |
| Conventional or Direct Filtration | | | | Monthly Summary (Answer Yes or No) | | | | |
| 95% of daily turbidity readings \leq 0.3 NTU? | | | | Yes | CT's met everyday? (see back) | | All Cl2 residual at entry point \geq 0.2 mg/l? | |
| All daily turbidity readings \leq 1 NTU? | | | | Yes | Yes | | Yes | |
| All turbidity readings < IFE ² triggers | | | | Yes | | | | |
| | | | | | PRINTED NAME: Levi Beachy | | | |
| | | | | | SIGNATURE:  | | 2/10/2026 | |
| | | | | | PHONE #: (503) 812-8804 | | | |
| ¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C)) | | | | | | | | |

| OHA - Drinking Water Program - Surface Water Quality Data Form | | | | | | | WTP - : | A |
|--|---|---------------------|--------------|-------|-------------|-------------|---|----------------------------|
| System Name: | City of Tillamook | | ID#: 41 | 00893 | Month/Year: | Jan-26 | Disinfection <i>Giardia</i> Log Inactiv: | 0.5 |
| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
| | [ppm or mg/L] | [minutes] | C X T | [° F] | | formula | Yes / No | [GPM] |
| 1 | 1.45 | 115 | 166.5 | 59.5 | 8.29 | 0.9 | YES | 1000 |
| 2 | 1.44 | 115 | 165.6 | 60.9 | 8.39 | 0.8 | YES | 1000 |
| 3 | 1.75 | 115 | 201.6 | 61.2 | 8.39 | 0.8 | YES | 1000 |
| 4 | 1.58 | 115 | 181.2 | 58.9 | 8.25 | 1.0 | YES | 1000 |
| 5 | 1.53 | 115 | 176.3 | 61.0 | 8.38 | 0.8 | YES | 1000 |
| 6 | 1.54 | 115 | 176.8 | 61.0 | 8.43 | 0.8 | YES | 1000 |
| 7 | 1.85 | 115 | 213.2 | 59.5 | 8.29 | 1.0 | YES | 1000 |
| 8 | 1.86 | 115 | 213.6 | 60.8 | 8.38 | 0.9 | YES | 1000 |
| 9 | 1.50 | 115 | 172.7 | 61.8 | 8.41 | 0.8 | YES | 1000 |
| 10 | 1.51 | 115 | 174.2 | 61.2 | 8.36 | 0.8 | YES | 1000 |
| 11 | 1.57 | 115 | 180.1 | 59.3 | 8.27 | 0.9 | YES | 1000 |
| 12 | 1.42 | 115 | 163.4 | 60.6 | 8.38 | 0.8 | YES | 1000 |
| 13 | 1.63 | 115 | 187.7 | 60.6 | 8.39 | 0.9 | YES | 1000 |
| 14 | 1.47 | 115 | 169.2 | 60.6 | 8.40 | 0.9 | YES | 1000 |
| 15 | 1.58 | 115 | 181.6 | 59.9 | 8.35 | 0.9 | YES | 1000 |
| 16 | 1.55 | 115 | 178.0 | 60.1 | 8.34 | 0.9 | YES | 1000 |
| 17 | 1.48 | 115 | 170.6 | 60.1 | 8.38 | 0.9 | YES | 1000 |
| 18 | 1.64 | 115 | 188.9 | 58.7 | 8.24 | 1.0 | YES | 1000 |
| 19 | 1.61 | 115 | 185.1 | 60.7 | 8.37 | 0.9 | YES | 1000 |
| 20 | 1.54 | 115 | 176.7 | 60.5 | 8.38 | 0.9 | YES | 1000 |
| 21 | 1.46 | 115 | 168.4 | 60.6 | 8.37 | 0.8 | YES | 1000 |
| 22 | 1.44 | 115 | 165.3 | 60.4 | 8.41 | 0.9 | YES | 1000 |
| 23 | 1.47 | 115 | 169.5 | 59.3 | 8.36 | 1.0 | YES | 1000 |
| 24 | 1.65 | 115 | 189.5 | 60.2 | 8.41 | 0.9 | YES | 1000 |
| 25 | 0.70 | 115 | 80.0 | 60.6 | 8.43 | 0.8 | YES | OFF |
| 26 | 0.70 | 115 | 80.4 | 59.7 | 8.41 | 0.8 | YES | OFF |
| 27 | 1.51 | 115 | 173.8 | 60.8 | 8.41 | 0.8 | YES | 1000 |
| 28 | 1.43 | 115 | 164.7 | 60.1 | 8.34 | 0.9 | YES | 1000 |
| 29 | 1.22 | 115 | 140.1 | 59.7 | 8.34 | 0.9 | YES | 1000 |
| 30 | 1.35 | 115 | 155.0 | 60.1 | 8.50 | 0.9 | YES | 1000 |
| 31 | 1.38 | 115 | 158.2 | 60.3 | 8.51 | 0.9 | YES | 1000 |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012