


| OHA - Drinking Water Program -Turbidity Monitoring Report Form   |                   |            |            |                                    |  |            | County:   | Tillamook |
|--|-------------------|------------|------------|------------------------------------|--|------------|---|-----------|
| Conventional or Direct Filtration  |                   |            |            |                                    |  |            | Month/Year:   | 2/1/2026  |
| System Name:   | City of Tillamook |            |            | ID#: 41                            | 00893  |            | WTP : TP -  | Combined  |
| Day  | 12 AM [NTU]       | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU]                         | 4 PM [NTU]   | 8 PM [NTU] | Highest Reading of the Day <sup>1</sup> [NTU]       |           |
| 1  | 0.020             | 0.020      | 0.020      | 0.040                              | 0.020  | 0.070      | 0.070   |           |
| 2  | 0.070             | 0.050      | 0.040      | 0.030                              | 0.030  | 0.030      | 0.070   |           |
| 3  | 0.050             | 0.030      | 0.040      | 0.030                              | 0.020  | 0.020      | 0.050   |           |
| 4  | 0.070             | 0.070      | 0.090      | 0.040                              | 0.060  | 0.070      | 0.090   |           |
| 5  | 0.040             | 0.010      | 0.060      | 0.020                              | 0.020  | 0.070      | 0.070   |           |
| 6  | 0.060             | 0.060      | 0.020      | 0.020                              | 0.020  | 0.060      | 0.060   |           |
| 7  | 0.020             | 0.020      | 0.020      | 0.020                              | 0.020  | 0.050      | 0.050   |           |
| 8  | 0.020             | 0.030      | 0.030      | 0.040                              | 0.070  | OFF        | 0.070   |           |
| 9  | OFF               | OFF        | OFF        | 0.040                              | 0.030  | 0.020      | 0.040   |           |
| 10   | 0.080             | 0.030      | 0.020      | 0.060                              | 0.080  | 0.020      | 0.080   |           |
| 11   | 0.090             | 0.090      | 0.020      | 0.020                              | 0.020  | 0.020      | 0.090   |           |
| 12   | 0.070             | 0.070      | 0.030      | 0.080                              | 0.070  | 0.020      | 0.080   |           |
| 13   | 0.050             | 0.040      | 0.020      | 0.020                              | 0.060  | 0.020      | 0.060   |           |
| 14   | 0.030             | 0.020      | 0.020      | 0.030                              | 0.080  | 0.020      | 0.080   |           |
| 15   | 0.040             | 0.040      | 0.030      | 0.040                              | 0.040  | 0.070      | 0.070   |           |
| 16   | 0.030             | 0.030      | 0.050      | 0.070                              | 0.030  | 0.070      | 0.070   |           |
| 17   | 0.030             | 0.040      | 0.050      | 0.030                              | 0.020  | 0.040      | 0.050   |           |
| 18   | 0.040             | 0.020      | 0.030      | 0.030                              | 0.030  | 0.030      | 0.040   |           |
| 19   | 0.030             | 0.030      | 0.070      | 0.030                              | 0.030  | 0.030      | 0.070   |           |
| 20   | 0.030             | 0.030      | 0.030      | 0.030                              | 0.030  | 0.030      | 0.030   |           |
| 21   | 0.030             | 0.030      | 0.040      | 0.080                              | 0.030  | 0.030      | 0.080   |           |
| 22   | 0.080             | 0.030      | 0.030      | 0.050                              | 0.050  | 0.040      | 0.080   |           |
| 23   | 0.040             | 0.080      | 0.040      | 0.040                              | 0.050  | 0.040      | 0.080   |           |
| 24   | 0.040             | 0.070      | 0.040      | 0.040                              | 0.050  | 0.040      | 0.070   |           |
| 25   | 0.040             | 0.040      | OFF        | 0.020                              | 0.030  | 0.030      | 0.040   |           |
| 26   | 0.020             | 0.030      | 0.030      | 0.050                              | 0.020  | 0.090      | 0.090   |           |
| 27   | 0.020             | 0.020      | 0.030      | 0.030                              | 0.030  | 0.030      | 0.030   |           |
| 28   | 0.030             | 0.050      | 0.050      | 0.040                              | 0.030  | 0.050      | 0.050   |           |
| 29   |                   |            |            |                                    |  |            |   |           |
| 30   |                   |            |            |                                    |  |            |   |           |
| 31   |                   |            |            |                                    |  |            |   |           |
| Conventional or Direct Filtration  |                   |            |            | Monthly Summary (Answer Yes or No) |  |            |   |           |
| 95% of daily turbidity readings $\leq$ 0.3 NTU?  |                   |            |            | Yes                                | CT's met everyday?<br>(see back)   |            | All Cl2 residual at entry point<br>$\geq$ 0.2 mg/l? |           |
| All daily turbidity readings $\leq$ 1 NTU?   |                   |            |            | Yes                                | Yes  |            | Yes   |           |
| All turbidity readings < IFE <sup>2</sup> triggers   |                   |            |            | Yes                                |  |            |   |           |
|  |                   |            |            |                                    | PRINTED NAME: Levi Beachy  |            |   |           |
|  |                   |            |            |                                    | SIGNATURE:  |            | 3/10/2026   |           |
|  |                   |            |            |                                    | PHONE #: ( 503 ) 812-8804  |            |   |           |
| <sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C)) |                   |            |            |                                    |  |            |   |           |

| OHA - Drinking Water Program - Surface Water Quality Data Form |   |                     |              |       |             |             | WTP - :                                     | A                          |
|--|---|---------------------|--------------|-------|-------------|-------------|---|----------------------------|
| System Name:   | City of Tillamook   |                     | ID#: 41      | 00893 | Month/Year: | Dec-25      | Disinfection <i>Giardia</i><br>Log Inactiv: | 0.5                        |
| Date / Time  | Minimum Cl <sub>2</sub><br>Residual at 1st<br>User ( C ) <sup>3</sup> | Contact Time<br>(T) | Actual CT    | Temp  | pH          | Required CT | CT Met? <sup>3</sup>                        | Peak Hourly<br>Demand Flow |
|  | [ppm or mg/L]   | [minutes]           | <b>C X T</b> | [° F] |             | formula     | Yes / No                                    | [GPM]                      |
| 1  | 1.46  | 115                 | 167.5        | 7.9   | 9.43        | 56.6        | YES   | 1000                       |
| 2  | 1.65  | 115                 | 189.2        | 7.9   | 9.65        | 63.0        | YES   | 1000                       |
| 3  | 1.50  | 115                 | 172.4        | 8.0   | 9.58        | 59.8        | YES   | 1000                       |
| 4  | 1.88  | 115                 | 216.1        | 8.2   | 9.44        | 58.6        | YES   | 1000                       |
| 5  | 1.45  | 115                 | 166.2        | 8.0   | 9.54        | 58.6        | YES   | 1000                       |
| 6  | 1.48  | 115                 | 170.1        | 7.6   | 9.63        | 62.6        | YES   | 1000                       |
| 7  | 1.38  | 115                 | 159.2        | 7.8   | 9.71        | 62.7        | YES   | 1000                       |
| 8  | 1.39  | 115                 | 159.8        | 8.5   | 9.65        | 58.5        | YES   | 1000                       |
| 9  | 1.39  | 115                 | 159.8        | 8.4   | 9.52        | 56.2        | YES   | 1000                       |
| 10   | 1.30  | 115                 | 149.7        | 7.6   | 9.53        | 59.0        | YES   | 1000                       |
| 11   | 1.38  | 115                 | 158.6        | 7.1   | 9.52        | 61.5        | YES   | 1000                       |
| 12   | 1.20  | 115                 | 137.6        | 6.8   | 9.53        | 61.7        | YES   | 1000                       |
| 13   | 1.21  | 115                 | 139.4        | 7.2   | 9.62        | 62.0        | YES   | 1000                       |
| 14   | 1.23  | 115                 | 141.2        | 7.2   | 9.51        | 59.8        | YES   | 1000                       |
| 15   | 1.32  | 115                 | 151.3        | 7.0   | 9.58        | 62.9        | YES   | 1000                       |
| 16   | 1.18  | 115                 | 135.4        | 7.2   | 9.57        | 60.7        | YES   | 1000                       |
| 17   | 1.24  | 115                 | 142.7        | 6.4   | 10.54       | 93.2        | YES   | 1000                       |
| 18   | 1.21  | 115                 | 138.9        | 5.6   | 9.44        | 64.9        | YES   | 1000                       |
| 19   | 1.13  | 115                 | 129.9        | 4.8   | 9.41        | 67.2        | YES   | 1000                       |
| 20   | 1.21  | 115                 | 138.6        | 4.6   | 9.45        | 70.0        | YES   | 1000                       |
| 21   | 1.12  | 115                 | 128.4        | 5.2   | 9.46        | 66.4        | YES   | 1000                       |
| 22   | 1.15  | 115                 | 132.3        | 5.9   | 9.45        | 63.4        | YES   | 1000                       |
| 23   | 1.15  | 115                 | 132.0        | 6.5   | 9.35        | 58.5        | YES   | 1000                       |
| 24   | 1.17  | 115                 | 134.6        | 6.2   | 9.29        | 58.6        | YES   | 1000                       |
| 25   | 1.11  | 115                 | 127.4        | 6.5   | 9.34        | 58.0        | YES   | 1000                       |
| 26   | 1.16  | 115                 | 133.9        | 6.1   | 9.37        | 60.8        | YES   | 1000                       |
| 27   | 1.15  | 115                 | 131.8        | 5.8   | 9.24        | 58.9        | YES   | 1000                       |
| 28   | 1.15  | 115                 | 131.7        | 5.7   | 9.17        | 57.9        | YES   | 1000                       |
| 29   |   | 115                 | 0.0          |       |             | 4.2         | YES   |                            |
| 30   |   | 115                 | 0.0          |       |             | 4.2         | YES   |                            |
| 31   |   | 115                 | 0.0          |       |             | 4.2         | YES   |                            |

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012