


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	3/1/2026
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.060	0.090	0.030	0.030	0.030	0.030	0.090	
2	0.030	0.030	0.060	0.040	0.060	0.090	0.090	
3	0.090	0.030	0.030	0.080	0.020	0.020	0.090	
4	0.010	0.020	OFF	0.020	0.030	0.050	0.050	
5	0.050	0.030	0.060	0.020	0.060	0.040	0.060	
6	0.030	0.050	0.020	0.030	0.020	0.070	0.070	
7	0.020	0.020	0.020	0.060	0.070	0.080	0.080	
8	0.040	0.050	0.040	0.030	0.030	0.040	0.050	
9	0.030	0.030	0.030	0.030	0.030	0.030	0.030	
10	0.040	0.050	0.030	0.040	0.030	OFF	0.050	
11	0.030	0.030	0.040	0.030	0.030	0.090	0.090	
12	0.060	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17	OFF	OFF	OFF	0.080	OFF	OFF	0.080	
18	0.060	0.080	0.020	0.080	0.020	0.040	0.080	
19	0.040	0.070	0.020	0.070	0.090	0.060	0.090	
20	0.020	OFF	0.020	0.020	0.020	0.020	0.020	
21	0.020	0.030	0.030	0.020	0.020	0.030	0.030	
22	0.030	0.020	0.040	0.060	0.030	0.070	0.070	
23	0.040	0.030	0.030	0.030	0.030	0.020	0.040	
24	0.060	0.030	0.040	0.030	0.030	0.070	0.070	
25	0.030	0.030	0.080	0.030	0.030	0.030	0.080	
26	0.050	0.030	0.040	0.040	0.090	0.020	0.090	
27	0.010	0.020	0.030	0.080	0.060	0.020	0.080	
28	0.060	0.070	0.030	0.050	0.020	0.030	0.070	
29	0.060	0.050	0.020	0.060	0.030	0.020	0.060	
30	0.090	0.070	0.080	0.020	0.080	0.070	0.080	
31	0.020	0.060	0.070	0.020	0.020	0.080	0.080	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 		4/1/2026	
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Mar-25	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° F]		formula	Yes / No	[GPM]
1	1.12	115	128.8	6.4	9.23	56.1	YES	1000
2	1.16	115	133.2	7.6	9.21	51.4	YES	1000
3	1.19	115	136.8	7.9	10.89	95.2	YES	1000
4	1.27	115	146.0	6.8	9.26	56.1	YES	1000
5	1.05	115	120.9	6.6	9.28	55.8	YES	1000
6	1.10	115	126.2	6.3	9.27	57.1	YES	1000
7	1.13	115	130.2	6.7	9.38	58.3	YES	1000
8	1.06	115	121.5	7.2	9.34	54.8	YES	1000
9	1.09	115	125.6	6.8	9.40	57.9	YES	1000
10	1.17	115	134.1	5.8	9.42	63.2	YES	1000
11	1.14	115	130.6	5.0	9.29	63.4	YES	1000
12		115	0.0			4.2	YES	
13		115	0.0			4.2	YES	
14		115	0.0			4.2	YES	
15		115	0.0			4.2	YES	
16		115	0.0			4.2	YES	
17	1.16	115	133.2	6.9	9.19	53.6	YES	1000
18	1.19	115	136.3	7.7	9.28	52.6	YES	1000
19	1.09	115	125.4	7.9	9.24	50.6	YES	1000
20	1.36	115	156.2	7.9	9.27	52.8	YES	1000
21	1.26	115	145.3	7.6	9.34	54.6	YES	1000
22	1.17	115	134.2	6.9	9.37	57.3	YES	1000
23	1.12	115	129.1	6.8	9.39	57.8	YES	1000
24	1.20	115	137.9	7.1	9.35	56.4	YES	1000
25	1.16	115	133.5	7.1	9.36	56.4	YES	1000
26	1.46	115	167.7	6.4	9.44	63.3	YES	1000
27	1.59	115	183.0	5.9	9.53	69.0	YES	1000
28	1.08	115	124.5	6.6	9.44	59.6	YES	1000
29	1.13	115	129.4	6.9	9.39	57.5	YES	1000
30	1.09	115	125.7	6.4	9.43	60.4	YES	1000
31	1.11	115	127.9	6.4	9.45	60.8	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012