


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	1/1/2021
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.032	OFF	OFF	0.038	0.033	0.033	0.038	
2	0.033	0.037	OFF	0.049	0.029	0.032	0.049	
3	OFF	OFF	OFF	0.031	0.038	0.035	0.038	
4	0.036	0.049	0.032	0.033	0.033	0.037	0.049	
5	0.037	0.049	0.043	0.034	0.034	0.034	0.049	
6	0.036	OFF	0.031	0.033	0.033	0.032	0.036	
7	0.034	0.035	0.035	0.049	0.049	0.037	0.049	
8	0.037	0.036	0.036	0.038	0.037	0.037	0.038	
9	0.033	0.038	0.049	0.049	0.033	OFF	0.049	
10	0.038	OFF	0.039	0.037	0.037	0.036	0.039	
11	0.032	0.039	0.039	0.036	0.036	0.038	0.039	
12	OFF	OFF	OFF	0.049	0.038	0.039	0.049	
13	OFF	OFF	OFF	0.049	OFF	OFF	0.049	
14	OFF	OFF	0.028	0.038	0.027	0.027	0.038	
15	0.049	OFF	0.030	0.026	0.028	0.033	0.049	
16	0.028	0.043	0.038	0.027	0.036	0.029	0.043	
17	0.030	OFF	0.031	0.031	0.031	0.034	0.034	
18	0.028	0.049	0.030	0.029	0.038	0.032	0.049	
19	0.030	0.030	0.049	0.036	OFF	0.032	0.049	
20	OFF	0.031	0.037	0.032	0.031	0.031	0.037	
21	0.030	OFF	0.031	0.028	0.028	0.031	0.031	
22	0.032	OFF	0.032	0.028	0.028	0.031	0.032	
23	0.031	OFF	0.033	0.033	0.031	0.031	0.033	
24	0.038	OFF	0.036	0.031	0.031	0.031	0.038	
25	OFF	0.032	0.032	0.032	0.033	0.033	0.033	
26	0.049	OFF	0.036	0.030	0.032	0.031	0.049	
27	OFF	0.037	0.031	0.030	0.033	0.033	0.037	
28	0.035	OFF	0.035	0.032	0.032	0.035	0.035	
29	0.037	0.033	0.030	0.029	0.029	0.049	0.049	
30	0.033	OFF	0.036	0.036	0.036	0.036	0.036	
31	0.036	OFF	0.029	0.036	0.035	0.035	0.036	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			2/1/2021
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Jan-20	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.88	115	101.2	9.2	8.77	37.8	YES	1000
2	0.88	115	101.2	9.4	7.81	26.3	YES	1000
3	0.87	115	100.1	9.4	7.76	25.8	YES	1000
4	0.85	115	97.8	9.7	7.77	25.4	YES	1000
5	0.85	115	97.8	9.3	8.22	30.6	YES	1000
6	0.87	115	100.1	9.4	8.11	29.3	YES	1000
7	0.88	115	101.2	9.3	7.61	24.7	YES	1000
8	0.88	115	101.2	9.4	7.75	25.8	YES	1000
9	0.88	115	101.2	8.8	7.68	26.2	YES	1000
10	0.89	115	102.4	9.2	8.39	33.0	YES	1000
11	0.89	115	102.4	9.4	7.98	28.0	YES	1000
12	0.88	115	101.2	9.8	8.09	28.4	YES	1000
13	0.87	115	100.1	9.7	7.72	25.0	YES	1000
14	0.85	115	97.8	9.5	8.96	39.6	YES	1000
15	0.85	115	97.8	9.9	7.50	22.7	YES	1000
16	0.86	115	98.9	9.2	7.69	25.5	YES	1000
17	0.88	115	101.2	9.3	7.66	25.1	YES	1000
18	0.89	115	102.4	8.8	7.80	27.4	YES	1000
19	0.89	115	102.4	8.6	8.07	30.6	YES	1000
20	0.51	115	58.7	8.3	7.87	27.8	YES	1000
21	0.89	115	102.4	8.8	7.85	27.9	YES	1000
22	0.89	115	102.4	8.9	7.89	52.1	YES	1000
23	0.89	115	102.4	8.3	7.87	29.0	YES	1000
24	0.89	115	102.4	8.5	8.08	30.9	YES	1000
25	0.89	115	102.4	8.1	7.83	29.0	YES	1000
26	0.87	115	100.1	8.2	8.32	34.3	YES	1000
27	0.89	115	102.4	8.1	7.99	30.7	YES	1000
28	0.89	115	102.4	8.3	8.00	30.4	YES	1000
29	0.88	115	101.2	8.1	7.94	30.1	YES	1000
30	0.87	115	100.1	8.4	8.04	30.6	YES	1000
31	0.87	115	100.1	8.7	7.94	28.9	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012