


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	3/1/2021
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.030	0.040	0.035	0.031	0.031	0.029	0.040	
2	0.028	OFF	0.038	0.032	0.032	0.035	0.038	
3	0.040	0.037	0.045	0.035	0.035	0.035	0.045	
4	0.035	OFF	0.040	0.029	0.029	0.030	0.040	
5	0.035	0.032	0.042	0.036	0.036	0.036	0.042	
6	0.037	0.038	0.038	0.038	0.037	0.037	0.038	
7	OFF	0.036	0.036	0.036	0.039	0.039	0.039	
8	0.036	OFF	0.043	0.038	0.036	0.036	0.043	
9	0.037	0.038	0.049	0.039	0.039	0.036	0.049	
10	0.037	0.037	OFF	OFF	OFF	OFF	0.037	
11	OFF	OFF	OFF	OFF	0.039	0.039	0.039	
12	0.049	OFF	0.040	0.038	0.038	0.039	0.049	
13	0.039	OFF	0.039	0.039	0.049	0.037	0.049	
14	0.038	OFF	0.040	0.040	0.040	0.040	0.040	
15	0.040	OFF	0.040	OFF	OFF	OFF	0.040	
16	OFF	OFF	OFF	OFF	0.048	0.041	0.048	
17	0.040	OFF	0.049	0.032	0.032	0.032	0.049	
18	0.036	OFF	0.037	0.031	0.031	0.031	0.037	
19	OFF	OFF	0.037	0.032	0.033	0.033	0.037	
20	0.034	OFF	0.030	0.038	0.030	0.030	0.038	
21	0.031	0.040	0.038	0.038	0.038	0.032	0.040	
22	OFF	0.037	0.037	0.030	0.030	0.030	0.037	
23	0.031	OFF	0.040	0.038	0.032	0.032	0.040	
24	0.049	0.037	0.037	0.031	0.031	0.020	0.049	
25	0.038	OFF	0.035	0.036	0.036	0.034	0.038	
26	0.038	0.038	0.036	0.040	0.040	0.037	0.040	
27	0.037	0.037	0.030	0.022	0.036	0.030	0.037	
28	0.030	0.035	0.035	0.035	0.035	0.036	0.036	
29	0.036	0.038	0.037	0.032	0.040	0.032	0.040	
30	0.032	OFF	0.033	0.033	0.038	0.030	0.038	
31	0.030	0.030	0.030	OFF	OFF	OFF	0.030	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		4/1/2021	
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Mar-20	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.93	115	107.0	8.8	7.84	59.0	YES	1000
2	0.94	115	108.1	8.9	7.89	28.2	YES	1000
3	0.91	115	104.7	8.7	7.89	28.5	YES	1000
4	0.89	115	102.4	8.8	8.38	33.8	YES	1000
5	0.87	115	100.1	9.2	8.24	31.1	YES	1000
6	0.85	115	97.8	8.9	7.81	27.2	YES	1000
7	0.83	115	95.5	8.9	7.95	28.5	YES	1000
8	0.82	115	94.3	8.4	7.91	29.0	YES	1000
9	0.82	115	94.3	8.6	8.30	33.0	YES	1000
10	0.82	115	94.3	8.7	7.92	28.5	YES	1000
11	0.79	115	90.9	8.8	7.95	28.5	YES	1000
12	0.78	115	89.7	8.5	7.91	28.7	YES	1000
13	0.78	115	89.7	8.7	7.89	28.1	YES	1000
14	0.79	115	90.9	9.1	7.92	27.7	YES	1000
15	0.78	115	89.7	8.6	7.95	28.9	YES	1000
16	0.76	115	87.4	8.7	7.95	28.6	YES	1000
17	0.76	115	87.4	8.3	8.33	33.8	YES	1000
18	0.78	115	89.7	8.7	7.94	28.6	YES	1000
19	0.78	115	89.7	9.0	7.95	28.1	YES	1000
20	0.77	115	88.6	8.9	7.89	27.7	YES	1000
21	0.75	115	86.3	8.7	7.87	27.8	YES	1000
22	0.74	115	85.1	8.9	8.02	54.0	YES	1000
23	0.74	115	85.1	8.6	8.36	33.4	YES	1000
24	0.74	115	85.1	8.9	8.29	31.9	YES	1000
25	0.74	115	85.1	8.9	8.17	30.5	YES	1000
26	0.73	115	84.0	8.8	7.82	27.1	YES	1000
27	0.72	115	82.8	8.9	7.83	26.9	YES	1000
28	0.72	115	82.8	9.1	7.91	27.4	YES	1000
29	0.71	115	81.7	8.7	7.82	27.2	YES	1000
30	0.69	115	79.4	8.7	7.89	27.8	YES	1000
31	0.68	115	78.2	8.7	7.99	28.8	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012