


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	6/1/2021
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.032	OFF	OFF	0.034	0.049	0.032	0.049	
2	0.032	0.032	0.036	0.040	0.036	0.032	0.040	
3	0.031	0.044	0.037	0.030	0.030	0.036	0.044	
4	0.037	OFF	0.036	0.036	0.036	0.036	0.037	
5	0.039	0.039	OFF	0.035	0.034	0.034	0.039	
6	0.036	OFF	0.038	0.038	0.038	0.031	0.038	
7	0.031	0.038	0.040	0.037	0.036	0.036	0.040	
8	0.039	0.039	0.040	0.040	0.038	0.037	0.040	
9	0.039	0.039	0.049	0.040	0.036	0.036	0.049	
10	0.035	OFF	0.038	0.040	0.036	0.038	0.040	
11	0.037	0.037	0.043	0.040	0.038	0.038	0.043	
12	0.039	OFF	0.040	0.040	0.040	0.040	0.040	
13	0.040	OFF	0.040	0.040	0.049	0.049	0.049	
14	0.049	0.047	OFF	OFF	0.049	0.045	0.049	
15	0.029	0.029	0.024	0.025	0.025	0.025	0.029	
16	0.025	0.025	0.025	0.023	0.023	0.022	0.025	
17	0.024	0.030	0.020	0.042	0.022	0.022	0.042	
18	0.023	0.029	0.023	0.023	0.023	0.023	0.029	
19	0.030	0.022	0.023	0.023	0.028	0.022	0.030	
20	0.022	0.022	0.022	0.022	0.023	0.023	0.023	
21	0.022	0.023	0.035	0.024	0.022	0.023	0.035	
22	0.025	0.033	0.030	0.022	0.022	0.022	0.033	
23	0.022	0.049	0.022	0.022	0.023	0.021	0.049	
24	0.020	0.024	0.022	0.025	0.022	0.021	0.025	
25	0.021	OFF	0.022	0.049	0.025	0.025	0.049	
26	0.022	OFF	0.031	0.031	0.023	0.022	0.031	
27	0.020	OFF	0.030	0.030	0.021	0.022	0.030	
28	0.022	0.028	0.028	0.024	0.024	0.021	0.028	
29	0.020	0.024	0.028	0.049	0.030	0.027	0.049	
30	0.023	0.023	0.023	0.023	0.026	0.023	0.026	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
				PRINTED NAME: Levi Beachy				
				SIGNATURE: 			7/10/2021	
				PHONE #: ( 503 ) 812-8804				
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Jun-21	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.51	115	58.7	11.7	7.79	42.1	YES	1000
2	0.52	115	59.8	12.1	7.83	21.3	YES	1000
3	0.54	115	62.1	11.9	7.66	20.4	YES	1000
4	0.55	115	63.3	11.7	7.69	20.9	YES	1000
5	0.56	115	64.4	11.8	7.67	20.6	YES	1000
6	0.56	115	64.4	11.3	7.69	21.5	YES	1000
7	0.56	115	64.4	11.0	7.71	22.0	YES	1000
8	0.54	115	62.1	11.0	7.71	22.0	YES	1000
9	0.54	115	62.1	10.8	7.70	22.2	YES	1000
10	0.56	115	64.4	11.0	7.72	22.1	YES	1000
11	0.57	115	65.6	11.2	7.76	22.2	YES	1000
12	0.57	115	65.6	11.0	7.78	22.6	YES	1000
13	0.57	115	65.6	11.4	7.76	21.9	YES	1000
14	0.55	115	63.3	11.3	8.48	28.4	YES	1000
15	0.49	115	56.4	11.5	7.85	22.2	YES	1000
16	0.48	115	55.2	11.2	7.67	21.3	YES	1000
17	0.51	115	58.7	11.5	7.64	20.7	YES	1000
18	0.59	115	67.9	11.5	7.68	21.2	YES	1000
19	0.68	115	78.2	11.5	7.67	21.3	YES	1000
20	0.73	115	84.0	11.8	7.78	21.8	YES	1000
21	0.76	115	87.4	12.0	7.81	21.9	YES	1000
22	0.78	115	89.7	12.3	7.68	48.3	YES	1000
23	0.78	115	89.7	12.2	7.68	20.7	YES	1000
24	0.79	115	90.9	11.9	7.68	21.1	YES	1000
25	0.79	115	90.9	12.2	7.90	22.3	YES	1000
26	0.78	115	89.7	12.6	7.68	20.0	YES	1000
27	0.78	115	89.7	12.9	7.60	19.1	YES	1000
28	0.77	115	88.6	13.5	7.56	18.0	YES	1000
29	0.75	115	86.3	13.2	7.67	19.1	YES	1000
30	0.76	115	87.4	13.1	7.64	19.1	YES	1000
31		115	0.0			4.4	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012