


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	7/1/2021
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.035	OFF	0.028	0.028	0.028	0.023	0.035	
2	0.022	0.022	0.022	0.023	0.022	0.022	0.022	
3	0.022	OFF	0.023	0.023	0.023	0.025	0.025	
4	0.025	OFF	0.024	0.024	0.023	0.022	0.025	
5	0.024	OFF	OFF	0.022	0.022	0.023	0.024	
6	0.023	0.026	0.021	0.023	0.023	0.022	0.026	
7	0.023	0.025	0.025	0.022	0.021	0.022	0.025	
8	0.022	0.022	0.023	0.023	0.022	0.021	0.023	
9	0.021	0.021	0.021	0.026	0.023	0.022	0.026	
10	0.022	OFF	0.022	0.021	0.021	0.021	0.022	
11	0.023	0.023	0.023	0.023	0.023	0.024	0.024	
12	0.028	OFF	0.029	0.024	0.022	0.022	0.029	
13	0.022	0.022	0.028	0.022	0.021	0.021	0.028	
14	0.021	OFF	0.023	0.023	0.023	0.023	0.023	
15	0.021	0.027	0.027	0.024	0.023	0.025	0.027	
16	0.022	0.023	0.023	0.022	0.022	0.023	0.023	
17	0.025	0.024	0.025	0.028	0.024	0.023	0.028	
18	0.027	OFF	0.033	0.030	0.035	0.030	0.035	
19	0.026	OFF	0.030	0.030	0.029	0.030	0.030	
20	0.031	0.029	0.030	0.033	0.030	0.030	0.033	
21	0.036	OFF	0.038	0.035	0.039	0.035	0.039	
22	0.035	0.037	0.040	0.039	0.040	0.040	0.040	
23	0.040	0.040	0.041	0.041	0.043	0.043	0.043	
24	0.042	0.042	0.047	0.047	0.048	0.049	0.049	
25	0.049	OFF	0.049	0.027	0.026	0.023	0.049	
26	0.024	0.033	0.029	0.025	0.025	0.025	0.033	
27	0.027	OFF	OFF	0.024	0.024	0.027	0.027	
28	0.026	0.028	0.028	0.037	0.021	0.022	0.037	
29	0.021	OFF	0.028	0.023	0.022	0.022	0.028	
30	OFF	OFF	OFF	0.020	0.020	OFF	0.020	
31	OFF	OFF	OFF	0.022	OFF	OFF	0.022	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 		8/5/2021	
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Jul-21	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.76	115	87.4	12.8	7.64	39.6	YES	1000
2	0.75	115	86.3	12.6	7.66	19.8	YES	1000
3	0.75	115	86.3	12.5	7.71	20.3	YES	1000
4	0.76	115	87.4	12.5	7.73	20.5	YES	1000
5	0.76	115	87.4	12.6	7.70	20.1	YES	1000
6	0.76	115	87.4	12.7	7.73	20.2	YES	1000
7	0.77	115	88.6	12.7	7.70	20.0	YES	1000
8	0.77	115	88.6	12.3	7.74	20.9	YES	1000
9	0.76	115	87.4	12.3	8.08	23.6	YES	1000
10	0.76	115	87.4	12.6	7.72	20.3	YES	1000
11	0.77	115	88.6	12.5	7.72	20.5	YES	1000
12	0.77	115	88.6	12.5	7.72	20.5	YES	1000
13	0.77	115	88.6	12.6	7.93	21.9	YES	1000
14	0.78	115	89.7	12.4	7.71	20.6	YES	1000
15	0.78	115	89.7	12.5	7.72	20.5	YES	1000
16	0.77	115	88.6	12.5	7.71	20.4	YES	1000
17	0.78	115	89.7	12.3	7.71	20.7	YES	1000
18	0.78	115	89.7	12.2	7.83	21.8	YES	1000
19	0.77	115	88.6	12.3	7.73	20.9	YES	1000
20	0.76	115	87.4	12.7	7.86	21.2	YES	1000
21	0.76	115	87.4	12.3	7.73	20.8	YES	1000
22	0.76	115	87.4	12.3	7.80	49.9	YES	1000
23	0.76	115	87.4	12.3	8.07	23.5	YES	1000
24	0.76	115	87.4	12.6	8.48	26.8	YES	1000
25	0.74	115	85.1	13.0	8.13	22.9	YES	1000
26	0.75	115	86.3	12.7	7.99	22.2	YES	1000
27	0.75	115	86.3	13.1	8.14	22.9	YES	1000
28	0.81	115	93.2	12.6	8.18	24.2	YES	800
29	0.89	115	102.4	12.8	8.59	28.0	YES	800
30	0.92	115	105.8	13.2	8.28	24.4	YES	800
31	0.91	115	104.7	13.3	8.32	24.6	YES	800

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012