


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	10/1/2021
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	OFF	OFF	0.038	0.042	OFF	0.042	
2	0.024	OFF	OFF	0.023	0.023	OFF	0.024	
3	OFF	OFF	OFF	0.028	OFF	0.022	0.028	
4	OFF	OFF	OFF	0.021	0.022	0.022	0.022	
5	OFF	OFF	0.022	0.022	OFF	0.039	0.039	
6	0.029	OFF	OFF	0.039	0.031	OFF	0.039	
7	OFF	OFF	0.033	0.028	0.026	0.025	0.033	
8	OFF	OFF	OFF	0.046	0.033	0.034	0.046	
9	0.022	OFF	OFF	0.042	0.042	0.040	0.042	
10	0.040	0.042	OFF	0.048	0.049	0.049	0.049	
11	OFF	OFF	0.029	0.025	0.029	0.021	0.029	
12	0.021	OFF	0.026	0.026	0.049	0.024	0.049	
13	0.049	0.021	0.028	0.024	0.027	0.023	0.049	
14	0.030	0.022	0.027	0.028	OFF	0.022	0.030	
15	OFF	OFF	OFF	0.043	0.022	0.024	0.043	
16	OFF	0.022	0.040	0.022	0.022	0.026	0.040	
17	0.033	0.021	0.021	0.027	OFF	0.021	0.033	
18	OFF	0.024	OFF	0.025	0.028	0.024	0.028	
19	0.045	0.031	0.043	0.039	0.027	0.049	0.049	
20	OFF	OFF	OFF	0.038	0.048	0.025	0.048	
21	OFF	0.035	0.022	0.022	0.030	0.027	0.030	
22	0.025	0.022	0.029	0.027	0.049	0.023	0.049	
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24	OFF	OFF	OFF	0.030	0.028	OFF	0.030	
25	OFF	OFF	OFF	0.032	OFF	0.030	0.032	
26	OFF	OFF	0.030	0.031	0.031	0.019	0.031	
27	OFF	OFF	0.036	OFF	0.040	0.049	0.049	
28	OFF	OFF	OFF	OFF	0.022	OFF	0.022	
29	OFF	OFF	OFF	OFF	0.024	0.040	0.040	
30	OFF	OFF	OFF	OFF	0.028	OFF	0.028	
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		11/1/2021	
					PHONE #: ( 503 ) 812-8804			
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Oct-21	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.69	115	79.4	11.6	8.23	49.4	YES	800
2	0.67	115	77.1	11.4	7.79	22.4	YES	800
3	0.65	115	74.8	11.3	7.87	23.1	YES	800
4	0.65	115	74.8	11.4	7.88	23.0	YES	800
5	0.67	115	77.1	11.5	7.96	23.6	YES	800
6	0.67	115	77.1	11.3	8.19	25.9	YES	800
7	0.67	115	77.1	11.3	8.29	26.9	YES	800
8	0.67	115	77.1	10.8	7.89	24.1	YES	800
9	0.69	115	79.4	10.8	8.27	27.7	YES	800
10	0.75	115	86.3	10.9	7.77	23.2	YES	800
11	0.73	115	84.0	10.8	8.56	30.9	YES	800
12	0.78	115	89.7	9.8	7.95	26.7	YES	1000
13	0.82	115	94.3	10.0	7.80	25.0	YES	1000
14	0.81	115	93.2	10.3	8.17	28.0	YES	1000
15	0.78	115	89.7	10.5	7.85	24.5	YES	1000
16	0.74	115	85.1	10.6	7.75	23.4	YES	1000
17	0.73	115	84.0	10.8	7.69	22.6	YES	1000
18	0.75	115	86.3	10.4	7.70	23.3	YES	1000
19	0.73	115	84.0	10.2	7.70	23.6	YES	1000
20	0.74	115	85.1	10.5	7.69	23.1	YES	1000
21	0.72	115	82.8	10.6	7.64	22.5	YES	1000
22	0.71	115	81.7	10.7	7.63	49.7	YES	1000
23	0.68	115	78.2	10.8	7.78	23.2	YES	1000
24	0.64	115	73.6	10.7	7.90	24.3	YES	1000
25	0.63	115	72.5	10.7	8.92	35.0	YES	1000
26	0.62	115	71.3	10.6	8.07	25.9	YES	1000
27	0.61	115	70.2	10.7	8.05	25.5	YES	1000
28	0.60	115	69.0	10.6	7.86	24.0	YES	1000
29	0.58	115	66.7	10.9	9.12	36.9	YES	1000
30	0.56	115	64.4	10.5	7.83	23.8	YES	1000
31	0.53	115	61.0	10.3	7.67	22.8	YES	1000

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012