


| OHA - Drinking Water Program -Turbidity Monitoring Report Form | | | | | | | County: | Tillamook |
|--|-------------------|------------|------------|------------------------------------|--|------------|---|-----------|
| Conventional or Direct Filtration | | | | | | | Month/Year: | 11/1/2021 |
| System Name: | City of Tillamook | | | ID#: 41 | 00893 | | WTP : TP - | Combined |
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day ¹ [NTU] | |
| 1 | OFF | OFF | 0.028 | 0.032 | 0.030 | OFF | 0.032 | |
| 2 | OFF | OFF | OFF | OFF | OFF | OFF | OFF | |
| 3 | OFF | OFF | OFF | 0.022 | OFF | 0.027 | 0.027 | |
| 4 | OFF | OFF | OFF | 0.026 | OFF | OFF | 0.026 | |
| 5 | OFF | OFF | OFF | 0.024 | 0.024 | 0.023 | 0.024 | |
| 6 | OFF | 0.021 | OFF | 0.030 | 0.030 | 0.025 | 0.030 | |
| 7 | 0.027 | 0.025 | 0.022 | 0.022 | 0.018 | 0.022 | 0.027 | |
| 8 | 0.024 | 0.025 | 0.030 | 0.049 | 0.030 | 0.021 | 0.049 | |
| 9 | OFF | 0.024 | 0.024 | 0.022 | 0.022 | 0.023 | 0.024 | |
| 10 | 0.023 | OFF | OFF? | 0.022 | 0.022 | 0.022 | 0.023 | |
| 11 | OFF | 0.020 | 0.020 | OFF | OFF | OFF | 0.020 | |
| 12 | OFF | OFF | OFF | OFF | OFF | OFF | OFF | |
| 13 | OFF | OFF | OFF | 0.021 | 0.040 | 0.021 | 0.040 | |
| 14 | OFF | OFF | OFF | 0.023 | 0.024 | OFF | 0.024 | |
| 15 | OFF | OFF | OFF | 0.021 | 0.023 | 0.023 | 0.023 | |
| 16 | 0.030 | 0.027 | 0.019 | 0.026 | 0.020 | 0.020 | 0.030 | |
| 17 | 0.032 | 0.022 | OFF | 0.021 | 0.026 | 0.025 | 0.032 | |
| 18 | 0.025 | 0.020 | 0.022 | 0.022 | 0.030 | 0.022 | 0.030 | |
| 19 | 0.021 | 0.021 | 0.021 | 0.020 | 0.021 | 0.021 | 0.021 | |
| 20 | 0.025 | 0.022 | 0.022 | 0.023 | 0.023 | 0.022 | 0.025 | |
| 21 | 0.022 | 0.022 | OFF | 0.021 | 0.022 | 0.022 | 0.022 | |
| 22 | 0.021 | 0.025 | 0.023 | 0.021 | 0.020 | 0.020 | 0.025 | |
| 23 | 0.022 | 0.022 | 0.020 | 0.022 | 0.022 | 0.022 | 0.022 | |
| 24 | 0.040 | 0.019 | 0.024 | 0.040 | 0.022 | 0.022 | 0.040 | |
| 25 | 0.021 | 0.037 | 0.023 | 0.022 | 0.024 | 0.020 | 0.037 | |
| 26 | 0.022 | OFF | 0.021 | 0.021 | 0.021 | 0.022 | 0.022 | |
| 27 | 0.022 | 0.022 | 0.022 | 0.020 | 0.021 | 0.020 | 0.022 | |
| 28 | 0.021 | 0.020 | 0.022 | OFF | 0.022 | 0.023 | 0.023 | |
| 29 | 0.024 | 0.024 | 0.024 | 0.021 | 0.021 | 0.021 | 0.024 | |
| 30 | 0.022 | 0.021 | 0.023 | 0.022 | 0.020 | 0.020 | 0.023 | |
| 31 | | | | | | | | |
| Conventional or Direct Filtration | | | | Monthly Summary (Answer Yes or No) | | | | |
| 95% of daily turbidity readings \leq 0.3 NTU? | | | | Yes | CT's met everyday? (see back) | | All Cl2 residual at entry point \geq 0.2 mg/l? | |
| All daily turbidity readings \leq 1 NTU? | | | | Yes | Yes | | Yes | |
| All turbidity readings < IFE ² triggers | | | | Yes | | | | |
| | | | | | PRINTED NAME: Levi Beachy | | | |
| | | | | | SIGNATURE:  | | | 12/1/2021 |
| | | | | | PHONE #: (503) 812-8804 | | | |
| ¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C)) | | | | | | | | |

| OHA - Drinking Water Program - Surface Water Quality Data Form | | | | | | | WTP - : | A |
|--|---|---------------------|-----------|-------|-------------|-------------|---|----------------------------|
| System Name: | City of Tillamook | | ID#: 41 | 00893 | Month/Year: | Nov-21 | Disinfection <i>Giardia</i> Log Inactiv: | 0.5 |
| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 0.51 | 115 | 58.7 | 10.4 | 7.75 | 55.5 | YES | 1000 |
| 2 | 0.53 | 115 | 61.0 | 10.3 | 7.70 | 22.9 | YES | 1000 |
| 3 | 0.55 | 115 | 63.3 | 10.3 | 7.68 | 22.8 | YES | 1000 |
| 4 | 0.58 | 115 | 66.7 | 10.7 | 7.60 | 21.7 | YES | 1000 |
| 5 | 0.60 | 115 | 69.0 | 10.6 | 8.70 | 32.4 | YES | 1000 |
| 6 | 0.67 | 115 | 77.1 | 10.1 | 7.62 | 22.9 | YES | 1000 |
| 7 | 0.73 | 115 | 84.0 | 9.7 | 7.61 | 23.6 | YES | 1000 |
| 8 | 0.77 | 115 | 88.6 | 9.5 | 7.57 | 23.7 | YES | 1000 |
| 9 | 0.80 | 115 | 92.0 | 9.8 | 7.64 | 23.9 | YES | 1000 |
| 10 | 0.81 | 115 | 93.2 | 9.6 | 7.57 | 23.7 | YES | 1000 |
| 11 | 0.84 | 115 | 96.6 | 10.1 | 7.56 | 22.9 | YES | 1000 |
| 12 | 0.82 | 115 | 94.3 | 10.4 | 7.56 | 22.4 | YES | 1000 |
| 13 | 0.79 | 115 | 90.9 | 10.4 | 7.56 | 22.3 | YES | 1000 |
| 14 | 0.78 | 115 | 89.7 | 10.5 | 7.43 | 21.2 | YES | 1000 |
| 15 | 0.77 | 115 | 88.6 | 10.7 | 7.41 | 20.7 | YES | 1000 |
| 16 | 0.78 | 115 | 89.7 | 10.1 | 7.70 | 23.9 | YES | 1000 |
| 17 | 0.82 | 115 | 94.3 | 9.5 | 7.58 | 23.9 | YES | 1000 |
| 18 | 0.84 | 115 | 96.6 | 9.6 | 7.59 | 23.9 | YES | 1000 |
| 19 | 0.83 | 115 | 95.5 | 10.0 | 7.68 | 24.0 | YES | 1000 |
| 20 | 0.79 | 115 | 90.9 | 9.8 | 7.60 | 23.6 | YES | 1000 |
| 21 | 0.78 | 115 | 89.7 | 9.1 | 7.67 | 25.3 | YES | 1000 |
| 22 | 0.77 | 115 | 88.6 | 8.9 | 7.67 | 50.7 | YES | 1000 |
| 23 | 0.77 | 115 | 88.6 | 9.4 | 8.04 | 28.3 | YES | 1000 |
| 24 | 0.74 | 115 | 85.1 | 9.0 | 7.62 | 24.9 | YES | 1000 |
| 25 | 0.73 | 115 | 84.0 | 9.2 | 7.67 | 25.0 | YES | 1000 |
| 26 | 0.73 | 115 | 84.0 | 9.7 | 7.61 | 23.6 | YES | 1000 |
| 27 | 0.72 | 115 | 82.8 | 9.9 | 7.97 | 26.5 | YES | 1000 |
| 28 | 0.72 | 115 | 82.8 | 10.3 | 8.00 | 26.1 | YES | 1000 |
| 29 | 0.74 | 115 | 85.1 | 10.2 | 7.50 | 22.0 | YES | 1000 |
| 30 | 0.76 | 115 | 87.4 | 10.2 | 7.47 | 21.8 | YES | 1000 |
| 31 | | 115 | 0.0 | | | 4.4 | YES | |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012