


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	12/1/2021
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.023	0.025	0.021	0.021	0.021	0.022	0.025	
2	0.023	0.022	0.024	0.023	0.023	0.023	0.024	
3	0.022	0.020	0.020	0.021	0.021	0.021	0.022	
4	0.021	0.024	0.024	0.021	0.022	0.022	0.024	
5	0.022	0.022	0.021	0.021	0.025	0.021	0.025	
6	0.021	OFF	0.025	0.022	0.021	0.027	0.027	
7	0.024	0.024	0.024	0.021	0.021	0.022	0.024	
8	0.022	OFF	0.023	0.042	0.028	0.021	0.042	
9	0.022	0.022	0.021	0.021	0.024	0.024	0.024	
10	0.022	0.023	0.024	0.021	0.049	0.026	0.049	
11	0.023	0.023	0.049	OFF	OFF	OFF	0.049	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	0.022	OFF	0.022	0.021	0.022	
14	0.020	0.020	0.020	0.022	0.021	0.021	0.022	
15	0.020	0.020	0.021	0.021	0.020	0.020	0.021	
16	0.020	OFF	0.020	0.022	0.020	0.020	0.022	
17	0.020	0.020	0.021	0.021	0.021	0.021	0.021	
18	0.021	0.020	0.022	0.022	0.037	0.022	0.037	
19	0.020	0.023	OFF	0.049	0.049	OFF?	0.049	
20	OFF	OFF	OFF	0.021	OFF	0.020	0.021	
21	OFF	0.035	0.021	0.049	0.023	0.020	0.049	
22	0.020	0.022	0.022	0.020	0.020	0.020	0.022	
23	0.023	0.026	0.022	0.022	0.020	0.020	0.026	
24	0.020	0.022	0.035	0.021	0.021	0.021	0.035	
25	0.021	0.023	0.023	0.020	0.020	0.020	0.023	
26	0.020	0.025	0.020	0.021	0.021	OFF	0.025	
27	OFF	OFF	OFF	0.022	OFF	0.021	0.022	
28	OFF	OFF	0.030	OFF	0.021	OFF	0.030	
29	OFF	OFF	0.023	0.049	OFF	OFF	0.049	
30	OFF	OFF	OFF	0.021	0.021	0.021	0.021	
31	0.022	OFF	0.024	0.022	0.022	OFF	0.024	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		1/3/2022	
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Dec-21	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.75	115	86.3	10.0	7.58	48.2	YES	1000
2	0.76	115	87.4	10.1	7.73	24.1	YES	1000
3	0.76	115	87.4	9.5	7.72	25.0	YES	1000
4	0.77	115	88.6	9.1	7.69	25.4	YES	1000
5	0.78	115	89.7	9.1	7.66	25.2	YES	1000
6	0.77	115	88.6	9.0	7.71	25.8	YES	1000
7	0.77	115	88.6	9.4	7.55	23.7	YES	1000
8	0.76	115	87.4	9.6	7.73	24.9	YES	1000
9	0.75	115	86.3	9.0	7.83	26.9	YES	1000
10	0.75	115	86.3	8.9	7.78	26.6	YES	1000
11	0.76	115	87.4	9.2	7.75	25.8	YES	1000
12	0.73	115	84.0	9.3	7.71	25.2	YES	1000
13	0.67	115	77.1	9.2	7.83	26.3	YES	1000
14	0.66	115	75.9	8.6	7.68	25.9	YES	1000
15	0.69	115	79.4	8.7	7.80	26.9	YES	1000
16	0.70	115	80.5	8.8	7.75	26.3	YES	1000
17	0.71	115	81.7	8.9	7.93	27.9	YES	1000
18	0.71	115	81.7	9.1	7.90	27.2	YES	1000
19	0.70	115	80.5	8.8	8.34	32.5	YES	1000
20	0.68	115	78.2	9.0	8.87	38.9	YES	1000
21	0.66	115	75.9	9.0	7.64	24.8	YES	1000
22	0.67	115	77.1	9.3	7.65	49.9	YES	1000
23	0.67	115	77.1	9.2	8.46	33.0	YES	1000
24	0.67	115	77.1	8.8	7.72	25.9	YES	1000
25	0.66	115	75.9	8.5	7.74	26.6	YES	1000
26	0.67	115	77.1	8.1	7.79	27.9	YES	1000
27	0.65	115	74.8	8.2	7.75	27.2	YES	1000
28	0.65	115	74.8	8.1	7.76	27.5	YES	1000
29	0.64	115	73.6	8.1	7.77	27.6	YES	1000
30	0.64	115	73.6	8.1	7.78	27.7	YES	1000
31	0.64	115	73.6	8.1	8.09	30.9	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012