


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	1/1/2022
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	0.021	0.021	0.022	0.022	
2	0.024	0.032	0.023	0.023	0.022	0.022	0.032	
3	0.037	0.028	OFF	0.023	0.023	0.024	0.037	
4	0.039	0.025	0.022	0.023	0.023	0.025	0.039	
5	0.020	0.023	0.023	0.022	0.022	0.028	0.028	
6	0.024	0.031	0.024	OFF	0.039	0.032	0.039	
7	OFF	OFF	OFF	OFF	0.038	0.034	0.038	
8	0.029	0.033	OFF	0.034	0.030	0.035	0.035	
9	0.030	0.030	OFF	0.031	0.027	0.036	0.036	
10	0.027	0.038	0.024	0.023	0.023	0.023	0.038	
11	0.028	0.024	0.024	0.024	0.031	0.030	0.031	
12	0.030	0.026	0.032	0.024	0.024	0.029	0.032	
13	0.031	0.031	0.035	0.038	0.037	0.026	0.038	
14	0.038	0.027	0.037	0.032	0.040	0.033	0.040	
15	0.039	0.036	0.031	0.036	0.027	0.033	0.039	
16	0.032	0.034	OFF	0.039	0.037	0.039	0.039	
17	0.039	0.041	0.038	0.026	0.028	0.049	0.049	
18	0.030	0.022	0.022	0.022	0.022	0.022	0.030	
19	0.026	0.021	0.021	0.021	0.023	0.023	0.026	
20	0.047	0.035	0.022	0.021	0.030	0.024	0.047	
21	0.021	OFF	0.021	0.023	0.020	0.024	0.024	
22	0.025	0.025	0.025	0.025	0.027	0.027	0.027	
23	0.029	0.029	0.029	0.048	0.049	0.027	0.049	
24	0.028	0.028	0.022	0.022	0.026	0.025	0.028	
25	0.028	0.028	0.021	0.021	0.021	0.021	0.028	
26	0.042	0.024	0.023	0.022	0.026	0.026	0.042	
27	0.021	0.027	0.023	0.027	0.027	0.026	0.027	
28	0.025	0.031	0.026	0.022	0.022	0.021	0.031	
29	0.022	0.020	0.022	0.023	0.023	0.023	0.023	
30	0.023	0.023	0.024	0.024	0.024	0.022	0.024	
31	0.023	0.040	0.032	0.027	0.030	0.030	0.040	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		2/1/2022	
PHONE #: (503) 812-8804								
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Jan-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.63	115	72.5	8.1	7.82	53.6	YES	1000
2	0.63	115	72.5	7.8	7.95	30.0	YES	1000
3	0.65	115	74.8	8.3	7.66	26.2	YES	1000
4	0.63	115	72.5	8.3	7.68	26.3	YES	1000
5	0.61	115	70.2	8.6	7.66	25.5	YES	1000
6	0.61	115	70.2	8.9	7.59	24.4	YES	1000
7	0.59	115	67.9	9.0	8.48	33.3	YES	1000
8	0.58	115	66.7	8.9	8.19	30.2	YES	1000
9	0.59	115	67.9	8.7	7.67	25.4	YES	1000
10	0.60	115	69.0	8.8	7.72	25.7	YES	1000
11	0.62	115	71.3	9.3	7.76	25.3	YES	1000
12	0.63	115	72.5	9.5	7.86	25.9	YES	1000
13	0.63	115	72.5	9.5	7.84	25.7	YES	1000
14	0.61	115	70.2	9.2	8.08	28.5	YES	1000
15	0.60	115	69.0	8.9	7.83	26.6	YES	1000
16	0.62	115	71.3	8.7	7.86	27.3	YES	1000
17	0.63	115	72.5	8.9	7.90	27.3	YES	1000
18	0.63	115	72.5	9.0	7.86	26.8	YES	1000
19	0.63	115	72.5	9.2	7.95	27.3	YES	1000
20	0.61	115	70.2	9.5	8.12	28.4	YES	1000
21	0.57	115	65.6	9.2	7.81	25.8	YES	1000
22	0.57	115	65.6	8.8	8.31	56.1	YES	1000
23	0.59	115	67.9	8.6	7.89	27.7	YES	1000
24	0.60	115	69.0	8.6	7.91	27.9	YES	1000
25	0.62	115	71.3	8.4	7.92	28.5	YES	1000
26	0.63	115	72.5	8.2	7.99	29.6	YES	1000
27	0.64	115	73.6	8.1	7.84	28.3	YES	1000
28	0.66	115	75.9	8.0	7.92	29.4	YES	1000
29	0.67	115	77.1	8.0	7.94	29.6	YES	1000
30	0.67	115	77.1	8.3	8.19	31.8	YES	1000
31	0.67	115	77.1	8.5	7.89	28.1	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012