


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	2/1/2022
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.026	0.026	0.032	0.025	0.022	0.023	0.032	
2	0.022	0.022	0.046	0.024	0.022	0.022	0.046	
3	0.023	OFF	0.027	0.033	0.026	0.026	0.033	
4	0.029	0.020	0.021	0.030	0.028	0.022	0.030	
5	0.023	0.032	0.025	0.025	0.025	0.025	0.032	
6	0.027	0.027	0.026	0.026	0.025	0.025	0.027	
7	0.022	0.022	0.028	0.028	0.023	0.023	0.028	
8	0.023	0.023	0.023	0.024	0.023	0.023	0.024	
9	0.024	0.024	0.030	0.029	0.023	0.023	0.030	
10	0.023	0.026	0.038	0.027	0.024	0.023	0.038	
11	0.030	0.022	0.022	0.028	0.028	0.028	0.030	
12	0.028	0.028	0.028	0.028	0.028	0.026	0.028	
13	0.024	0.024	0.024	0.023	0.023	0.033	0.033	
14	0.025	0.026	0.023	0.023	0.026	0.026	0.026	
15	0.026	0.026	0.026	0.026	0.048	0.026	0.048	
16	0.028	0.024	0.026	0.026	0.030	0.030	0.030	
17	0.028	0.022	0.022	0.022	0.022	0.022	0.028	
18	0.020	0.020	0.020	0.023	0.021	0.020	0.023	
19	0.022	0.022	0.022	0.024	0.024	0.020	0.024	
20	0.021	0.022	0.020	0.022	0.022	0.021	0.022	
21	0.024	0.022	0.023	0.022	0.021	0.021	0.024	
22	0.025	0.023	0.024	0.049	0.022	0.025	0.049	
23	OFF	OFF	OFF	OFF	0.022	OFF	0.022	
24	OFF	OFF	OFF	0.024	0.022	0.023	0.024	
25	0.024	0.024	0.023	0.021	0.021	0.040	0.040	
26	0.024	0.024	0.024	0.022	0.022	0.028	0.028	
27	0.023	OFF	0.022	0.022	0.022	0.022	0.023	
28	0.025	0.026	0.049	0.030	OFF	OFF	0.049	
29								
30								
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		3/9/2022	
					PHONE #: ( 503 ) 812-8804			
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Feb-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.65	115	74.8	8.3	8.20	61.3	YES	1000
2	0.62	115	71.3	8.4	7.91	28.3	YES	1000
3	0.62	115	71.3	8.6	7.85	27.4	YES	1000
4	0.63	115	72.5	8.5	7.87	27.8	YES	1000
5	0.63	115	72.5	8.7	8.07	29.5	YES	1000
6	0.63	115	72.5	8.4	8.00	29.3	YES	1000
7	0.64	115	73.6	8.5	7.86	27.7	YES	1000
8	0.65	115	74.8	8.4	7.90	28.3	YES	1000
9	0.66	115	75.9	8.5	8.20	31.4	YES	1000
10	0.67	115	77.1	8.8	7.85	27.2	YES	1000
11	0.67	115	77.1	8.6	7.90	28.0	YES	1000
12	0.67	115	77.1	8.6	7.89	27.9	YES	1000
13	0.68	115	78.2	8.6	7.91	28.2	YES	1000
14	0.67	115	77.1	9.0	8.05	28.8	YES	1000
15	0.66	115	75.9	8.8	7.85	27.1	YES	1000
16	0.65	115	74.8	8.8	7.88	27.4	YES	1000
17	0.65	115	74.8	8.8	8.10	29.7	YES	1000
18	0.64	115	73.6	8.8	7.90	27.6	YES	1000
19	0.63	115	72.5	8.8	7.91	27.6	YES	1000
20	0.63	115	72.5	8.8	7.92	27.7	YES	1000
21	0.60	115	69.0	8.5	8.33	32.7	YES	1000
22	0.60	115	69.0	8.1	8.14	55.3	YES	1000
23	0.58	115	66.7	8.1	7.91	28.8	YES	1000
24	0.56	115	64.4	7.8	7.91	29.3	YES	1000
25	0.64	115	73.6	7.6	7.94	30.3	YES	1000
26	0.72	115	82.8	7.6	7.93	30.5	YES	1000
27	0.76	115	87.4	8.4	7.94	29.1	YES	1000
28	0.75	115	86.3	9.0	8.10	29.6	YES	1000
29		115	0.0			4.2	YES	
30		115	0.0			4.2	YES	
31		115	0.0			4.2	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012