


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	4/1/2022
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.023	0.028	0.028	0.025	0.025	0.027	0.028	
2	0.026	0.026	OFF	0.028	0.028	0.028	0.028	
3	0.025	0.025	0.049	0.025	0.022	0.022	0.049	
4	0.022	OFF	OFF	OFF	0.021	OFF	0.022	
5	0.040	0.024	0.022	0.022	0.022	0.021	0.040	
6	0.021	0.037	0.026	OFF	0.021	0.023	0.037	
7	0.022	0.022	0.022	0.021	0.021	0.021	0.022	
8	0.021	0.023	0.023	0.020	0.022	0.049	0.049	
9	0.021	0.021	0.021	0.021	0.027	0.021	0.027	
10	0.022	OFF	0.023	0.023	0.023	0.023	0.023	
11	0.020	0.024	0.024	0.021	0.021	0.023	0.024	
12	0.022	0.022	0.022	0.020	0.020	0.020	0.022	
13	0.020	0.021	0.025	0.026	0.026	0.021	0.026	
14	0.020	0.020	0.020	0.020	0.021	0.021	0.021	
15	0.023	0.023	0.023	0.021	0.020	0.020	0.023	
16	0.021	0.024	0.022	0.022	0.022	0.022	0.024	
17	0.026	0.026	0.022	0.024	0.024	0.029	0.029	
18	0.023	0.025	0.025	0.021	0.021	0.021	0.025	
19	0.021	0.024	0.026	0.026	0.026	0.022	0.026	
20	0.027	0.022	0.022	0.024	0.024	0.025	0.027	
21	0.028	0.026	0.026	0.026	0.026	0.026	0.028	
22	0.022	0.022	0.027	0.023	0.023	0.022	0.027	
23	0.024	0.023	0.026	0.026	0.022	0.022	0.026	
24	0.025	0.029	0.022	0.022	0.020	0.021	0.029	
25	0.021	0.021	0.022	0.025	0.024	0.024	0.025	
26	0.026	0.026	0.026	0.024	0.024	0.032	0.032	
27	0.024	0.024	0.024	0.021	0.021	0.021	0.024	
28	0.021	0.022	0.021	0.026	0.026	0.026	0.026	
29	0.031	0.031	0.024	0.024	0.037	0.027	0.037	
30	0.028	0.026	0.028	0.028	0.028	0.028	0.028	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		5/9/2022	
PHONE #: ( 503 ) 812-8804								
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Apr-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.83	115	95.5	9.2	8.06	57.1	YES	1000
2	0.84	115	96.6	9.4	8.04	28.5	YES	1000
3	0.83	115	95.5	9.4	8.02	28.2	YES	1000
4	0.82	115	94.3	9.7	9.57	48.8	YES	1000
5	0.75	115	86.3	9.1	7.97	28.0	YES	1000
6	0.60	115	69.0	8.8	8.00	28.4	YES	1000
7	0.57	115	65.6	9.3	8.02	27.6	YES	1000
8	0.59	115	67.9	9.9	8.01	26.5	YES	1000
9	0.62	115	71.3	9.4	8.13	28.7	YES	1000
10	0.65	115	74.8	9.3	8.45	32.5	YES	1000
11	0.70	115	80.5	8.6	8.03	29.5	YES	1000
12	0.73	115	84.0	8.7	8.00	29.1	YES	1000
13	0.76	115	87.4	8.5	7.97	29.2	YES	1000
14	0.75	115	86.3	8.6	8.05	29.9	YES	1000
15	0.80	115	92.0	8.5	8.14	31.2	YES	1000
16	0.80	115	92.0	8.4	8.08	30.8	YES	1000
17	0.79	115	90.9	8.6	7.98	29.3	YES	1000
18	0.79	115	90.9	9.0	8.02	28.9	YES	1000
19	0.80	115	92.0	8.8	7.93	28.4	YES	1000
20	0.79	115	90.9	8.9	8.00	28.9	YES	1000
21	0.79	115	90.9	9.1	8.06	29.1	YES	1000
22	0.80	115	92.0	9.1	8.38	58.2	YES	1000
23	0.80	115	92.0	9.1	8.05	29.0	YES	1000
24	0.81	115	93.2	9.4	8.01	28.1	YES	1000
25	0.81	115	93.2	9.9	8.37	30.9	YES	1000
26	0.83	115	95.5	9.6	8.00	27.7	YES	1000
27	0.84	115	96.6	9.3	8.00	28.3	YES	1000
28	0.83	115	95.5	9.4	8.53	34.0	YES	1000
29	0.83	115	95.5	9.4	8.03	28.3	YES	1000
30	0.83	115	95.5	9.7	8.08	28.3	YES	1000
31		115	0.0			4.4	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012