


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	6/1/2022
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.032	0.031	0.031	0.028	0.030	0.030	0.032	
2	0.030	0.030	0.029	0.026	0.026	0.026	0.030	
3	0.038	0.032	0.032	0.032	0.033	0.033	0.038	
4	0.033	0.033	0.031	0.030	0.032	0.032	0.033	
5	0.032	0.032	0.033	0.034	0.034	0.034	0.034	
6	0.040	0.030	0.032	0.031	0.031	0.033	0.040	
7	0.034	0.020	0.033	0.033	0.033	0.035	0.035	
8	0.036	0.032	0.032	0.033	0.030	0.030	0.036	
9	0.031	0.031	0.031	0.035	0.035	0.035	0.035	
10	0.039	0.035	0.032	0.030	0.033	0.033	0.039	
11	0.038	0.038	0.036	0.036	0.036	0.037	0.038	
12	0.036	0.031	0.030	0.030	0.033	0.033	0.036	
13	0.037	0.038	0.037	0.031	0.032	0.033	0.038	
14	0.033	0.039	0.035	0.022	0.021	0.021	0.039	
15	0.023	0.020	0.020	0.020	0.020	0.022	0.023	
16	0.022	0.023	0.021	0.022	0.022	0.022	0.023	
17	0.021	0.022	0.022	0.022	0.022	0.022	0.022	
18	0.024	0.024	0.022	0.022	0.022	0.022	0.024	
19	0.021	0.020	0.020	0.020	0.022	0.022	0.022	
20	0.023	OFF	0.022	0.021	0.020	0.020	0.023	
21	0.021	0.021	0.020	0.024	0.020	0.021	0.024	
22	0.021	0.025	0.023	0.023	0.026	0.025	0.026	
23	0.028	0.027	0.028	0.031	0.025	0.025	0.031	
24	0.028	0.037	0.032	0.030	0.032	0.033	0.037	
25	0.033	0.033	0.038	0.038	0.036	0.036	0.038	
26	0.040	0.040	OFF	OFF	0.042	0.042	0.042	
27	OFF	OFF	OFF	OFF	OFF	0.020	0.020	
28	0.021	0.021	0.022	0.019	0.020	0.021	0.022	
29	0.042	0.020	0.020	0.026	0.020	OFF	0.042	
30	OFF	OFF	0.022	0.022	0.020	0.024	0.024	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			7/5/2022
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Jun-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.82	115	94.3	10.6	8.40	58.6	YES	1000
2	0.83	115	95.5	10.8	7.98	25.3	YES	1000
3	0.84	115	96.6	10.9	7.92	24.7	YES	1000
4	0.84	115	96.6	10.8	8.06	26.1	YES	1000
5	0.84	115	96.6	10.9	8.35	28.8	YES	1000
6	0.80	115	92.0	10.7	7.94	25.1	YES	1000
7	0.80	115	92.0	10.5	8.00	26.0	YES	1000
8	0.82	115	94.3	10.8	7.91	24.7	YES	1000
9	0.83	115	95.5	10.9	8.01	25.4	YES	1000
10	0.84	115	96.6	11.1	8.12	26.1	YES	1000
11	0.81	115	93.2	10.9	7.81	23.6	YES	1000
12	0.80	115	92.0	10.8	8.42	29.6	YES	1000
13	0.82	115	94.3	10.6	8.00	25.8	YES	1000
14	0.82	115	94.3	10.4	7.94	25.6	YES	1000
15	0.83	115	95.5	10.4	7.94	25.7	YES	1000
16	0.85	115	97.8	10.6	7.94	25.4	YES	1000
17	0.85	115	97.8	10.6	8.21	28.0	YES	1000
18	0.87	115	100.1	10.5	7.95	25.7	YES	1000
19	0.87	115	100.1	10.5	7.96	25.8	YES	1000
20	0.87	115	100.1	10.6	7.88	24.9	YES	1000
21	0.86	115	98.9	10.9	7.89	24.5	YES	1000
22	0.87	115	100.1	11.2	7.83	50.3	YES	1000
23	0.84	115	96.6	10.9	7.96	25.0	YES	1000
24	0.87	115	100.1	10.9	8.30	28.4	YES	1000
25	0.89	115	102.4	11.2	7.91	24.2	YES	1000
26	0.87	115	100.1	11.9	8.44	27.9	YES	1000
27	0.88	115	101.2	12.2	7.96	23.1	YES	1000
28	0.89	115	102.4	12.0	8.31	26.5	YES	1000
29	0.85	115	97.8	11.6	7.92	23.6	YES	1000
30	0.82	115	94.3	11.6	8.36	27.5	YES	1000
31		115	0.0			4.4	YES	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012