


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	8/1/2022
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.022	0.022	0.022	0.022	0.022	0.023	0.023	
2	OFF	0.021	0.023	0.023	0.023	0.022	0.023	
3	OFF	0.027	0.024	0.024	0.025	OFF	0.027	
4	0.031	0.033	0.033	0.026	0.035	0.035	0.035	
5	OFF	OFF	0.042	0.042	0.040	OFF	0.042	
6	0.044	0.044	0.046	0.027	0.029	0.029	0.046	
7	0.025	OFF	0.029	0.028	0.027	0.030	0.030	
8	0.026	OFF	0.033	0.028	0.029	0.029	0.033	
9	OFF	OFF	0.032	0.032	0.037	0.037	0.037	
10	OFF	0.033	0.033	0.032	0.032	0.034	0.034	
11	0.037	0.037	0.038	0.022	0.023	0.023	0.038	
12	0.023	0.023	0.023	0.022	0.022	0.020	0.023	
13	0.020	0.021	OFF	0.020	0.024	0.020	0.024	
14	OFF	0.020	0.020	0.020	0.020	0.020	0.020	
15	0.020	OFF	0.022	0.020	0.020	0.021	0.021	
16	0.020	OFF	0.022	0.022	0.022	0.022	0.022	
17	0.022	OFF	0.020	0.020	0.021	0.021	0.022	
18	0.020	0.021	0.021	0.021	0.021	0.020	0.021	
19	OFF	0.021	0.021	0.023	0.023	0.023	0.023	
20	0.023	OFF	0.021	0.021	0.021	0.021	0.023	
21	0.021	0.024	0.020	0.020	0.020	0.020	0.024	
22	0.020	0.020	0.020	0.020	0.020	0.020	0.020	
23	0.020	0.020	0.020	OFF	0.021	0.021	0.021	
24	0.020	OFF	OFF	0.022	0.020	0.022	0.022	
25	OFF	OFF	0.022	0.030	0.024	0.024	0.030	
26	OFF	OFF	OFF	0.025	0.025	0.032	0.032	
27	0.031	OFF	OFF	0.038	0.039	0.039	0.039	
28	OFF	OFF	OFF	OFF	0.040	0.042	0.042	
29	0.042	OFF	OFF	0.032	0.030	0.022	0.042	
30	0.022	OFF	OFF	0.022	0.022	0.022	0.022	
31	0.020	OFF	OFF	0.021	0.021	0.021	0.021	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
				PRINTED NAME: Levi Beachy				
				SIGNATURE: 			9/1/2022	
				PHONE #: (503) 812-8804				
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Aug-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.71	115	81.7	13.1	8.22	45.8	YES	1000
2	0.71	115	81.7	12.6	7.91	21.6	YES	1000
3	0.71	115	81.7	12.5	7.96	22.2	YES	1000
4	0.71	115	81.7	12.6	7.94	21.9	YES	1000
5	0.69	115	79.4	12.8	8.04	22.4	YES	1000
6	0.69	115	79.4	12.3	8.19	24.3	YES	1000
7	0.69	115	79.4	12.9	8.16	23.2	YES	1000
8	0.69	115	79.4	12.7	7.94	21.7	YES	1000
9	0.71	115	81.7	12.6	7.96	22.0	YES	1000
10	0.71	115	81.7	12.5	7.90	21.7	YES	1000
11	0.71	115	81.7	12.3	8.04	23.1	YES	1000
12	0.71	115	81.7	12.6	7.92	21.7	YES	1000
13	0.72	115	82.8	12.5	7.88	21.6	YES	1000
14	0.72	115	82.8	12.3	7.90	22.0	YES	1000
15	0.72	115	82.8	12.5	7.87	21.5	YES	1000
16	0.72	115	82.8	12.8	8.25	24.2	YES	1000
17	0.71	115	81.7	13.0	8.29	24.2	YES	800
18	0.74	115	85.1	13.0	7.90	21.1	YES	800
19	0.75	115	86.3	13.1	7.90	21.0	YES	800
20	0.75	115	86.3	12.9	8.29	24.5	YES	800
21	0.77	115	88.6	12.8	7.88	21.3	YES	800
22	0.78	115	89.7	12.8	7.88	50.1	YES	800
23	0.78	115	89.7	13.0	7.88	21.0	YES	800
24	0.75	115	86.3	13.3	8.42	25.0	YES	800
25	0.75	115	86.3	13.3	7.97	21.2	YES	800
26	0.74	115	85.1	13.3	7.98	21.3	YES	800
27	0.74	115	85.1	13.1	7.97	21.5	YES	800
28	0.72	115	82.8	13.1	8.03	21.9	YES	800
29	0.72	115	82.8	13.0	8.01	21.9	YES	800
30	0.73	115	84.0	13.0	7.92	21.2	YES	800
31	0.72	115	82.8	13.2	7.97	21.3	YES	800

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012