


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	9/1/2022
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	OFF	OFF	0.024	0.024	0.024	0.024	
2	0.024	OFF	OFF	0.022	0.022	OFF	0.024	
3	OFF	OFF	OFF	0.022	OFF	0.026	0.026	
4	0.025	OFF	OFF	0.038	0.032	0.032	0.038	
5	OFF	OFF	OFF	0.034	0.034	0.033	0.034	
6	0.032	OFF	OFF	0.037	0.037	0.030	0.037	
7	0.034	OFF	OFF	0.040	0.040	0.036	0.040	
8	0.038	0.038	OFF	0.021	0.020	0.021	0.038	
9	OFF	OFF	0.020	0.023	0.023	0.022	0.023	
10	OFF	OFF	0.025	0.021	OFF	OFF	0.025	
11	OFF	OFF	0.022	0.022	OFF	0.020	0.022	
12	OFF	OFF	0.022	0.023	0.023	0.021	0.023	
13	OFF	0.021	0.021	0.021	OFF	OFF	0.021	
14	0.022	OFF	0.024	0.021	0.020	OFF	0.024	
15	OFF	OFF	OFF	0.020	OFF	OFF	0.020	
16	OFF	OFF	0.020	0.020	OFF	OFF	0.020	
17	0.020	OFF	0.020	OFF	0.020	OFF	0.020	
18	OFF	OFF	0.020	0.020	0.021	0.020	0.021	
19	OFF	OFF	OFF	0.049	OFF	0.021	0.049	
20	OFF	OFF	0.020	OFF	0.022	0.022	0.022	
21	OFF	OFF	0.040	0.022	0.024	0.022	0.040	
22	OFF	OFF	0.020	OFF	OFF	0.020	0.020	
23	OFF	0.020	0.023	0.021	OFF	0.022	0.023	
24	OFF	0.020	0.020	0.026	OFF	0.024	0.026	
25	OFF	OFF	0.023	0.023	0.026	0.021	0.026	
26	OFF	OFF	0.024	OFF	OFF	OFF	0.024	
27	OFF	OFF	0.020	0.021	0.021	0.021	0.021	
28	OFF	OFF	0.022	OFF	OFF	OFF	0.022	
29	OFF	OFF	OFF	OFF	0.030	0.028	0.030	
30	OFF	OFF	OFF	0.030	0.031	0.020	0.031	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		10/4/2022	
PHONE #: ( 503 ) 812-8804								
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Sep-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.72	115	82.8	13.2	8.09	46.2	YES	800
2	0.73	115	84.0	13.1	8.07	22.3	YES	800
3	0.71	115	81.7	12.9	8.63	27.6	YES	800
4	0.71	115	81.7	12.8	8.10	22.9	YES	800
5	0.71	115	81.7	12.8	8.22	23.9	YES	800
6	0.71	115	81.7	12.7	8.19	23.8	YES	800
7	0.72	115	82.8	12.6	8.33	25.3	YES	800
8	0.72	115	82.8	12.0	8.44	27.2	YES	800
9	0.74	115	85.1	12.3	8.37	26.1	YES	800
10	0.73	115	84.0	12.5	8.35	25.7	YES	800
11	0.72	115	82.8	13.2	8.54	26.2	YES	800
12	0.72	115	82.8	12.7	8.33	25.1	YES	800
13	0.71	115	81.7	12.5	8.17	24.0	YES	800
14	0.70	115	80.5	12.6	8.24	24.4	YES	800
15	0.69	115	79.4	12.4	8.02	22.7	YES	800
16	0.69	115	79.4	12.6	8.06	22.8	YES	800
17	0.69	115	79.4	12.0	8.06	23.7	YES	800
18	0.69	115	79.4	12.1	8.16	24.4	YES	800
19	0.67	115	77.1	12.2	8.13	23.9	YES	800
20	0.68	115	78.2	12.4	8.04	22.9	YES	800
21	0.69	115	79.4	12.4	7.99	22.5	YES	800
22	0.69	115	79.4	12.2	7.97	50.8	YES	800
23	0.74	115	85.1	12.2	7.97	22.8	YES	800
24	0.76	115	87.4	11.9	7.96	23.2	YES	800
25	0.74	115	85.1	12.4	8.00	22.7	YES	800
26	0.74	115	85.1	12.4	7.96	22.4	YES	800
27	0.74	115	85.1	12.3	7.98	22.7	YES	800
28	0.73	115	84.0	12.1	8.07	23.7	YES	800
29	0.73	115	84.0	12.1	7.98	23.0	YES	800
30	0.73	115	84.0	12.1	7.98	23.0	YES	800
31		115	0.0			4.4	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012