


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	10/1/2022
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	OFF	OFF	0.038	0.038	0.031	0.038	
2	OFF	OFF	OFF	0.039	0.039	OFF	0.039	
3	OFF	OFF	OFF	0.038	OFF	0.040	0.040	
4	OFF	OFF	0.041	0.030	OFF	0.020	0.041	
5	OFF	OFF	OFF	OFF	0.022	0.022	0.022	
6	OFF	OFF	0.021	OFF	OFF	OFF	0.021	
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15	OFF	OFF	0.028	OFF	OFF	OFF	0.028	
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27	OFF	OFF	OFF	0.027	OFF	OFF	0.027	
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
					PRINTED NAME: Ljvi Beachy			
					SIGNATURE: 		11/2/2022	
					PHONE #: ( 503 ) 812-8804			
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Oct-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.69	115	79.4	12.1	7.98	45.2	YES	800
2	0.66	115	75.9	12.2	7.96	22.5	YES	800
3	0.65	115	74.8	12.2	8.00	22.8	YES	800
4	0.61	115	70.2	12.1	7.95	22.4	YES	800
5	0.62	115	71.3	11.8	7.88	22.3	YES	800
6	0.61	115	70.2	12.1	7.92	22.2	YES	800
7	0.58	115	66.7	12.0	7.90	22.1	YES	OFF
8	0.57	115	65.6	12.0	7.91	22.2	YES	800
9	0.56	115	64.4	12.0	7.87	21.8	YES	800
10	0.55	115	63.3	12.0	8.00	22.8	YES	800
11	0.54	115	62.1	11.7	8.18	24.8	YES	800
12	0.54	115	62.1	11.7	7.93	22.7	YES	800
13	0.53	115	61.0	11.7	7.88	22.3	YES	800
14	0.25	115	28.8	11.7	7.89	21.6	YES	OFF
15	0.47	115	54.1	11.7	7.74	21.1	YES	800
16	0.47	115	54.1	11.7	7.81	21.6	YES	OFF
17	0.47	115	54.1	11.8	7.80	21.4	YES	800
18	0.47	115	54.1	11.7	7.75	21.1	YES	OFF
19	0.46	115	52.9	11.7	7.76	21.2	YES	OFF
20	0.45	115	51.8	11.7	7.79	21.4	YES	800
21	0.45	115	51.8	11.6	7.75	21.2	YES	800
22	0.45	115	51.8	11.6	7.86	49.0	YES	800
23	0.45	115	51.8	11.4	7.79	21.8	YES	800
24	0.44	115	50.6	11.3	7.84	22.3	YES	800
25	0.44	115	50.6	11.2	7.78	22.0	YES	800
26	0.44	115	50.6	11.1	7.83	22.5	YES	OFF
27	0.43	115	49.5	11.1	7.87	22.8	YES	800
28	0.44	115	50.6	10.9	7.91	23.5	YES	OFF
29	0.43	115	49.5	11.0	7.89	23.1	YES	OFF
30	0.42	115	48.3	11.0	7.86	22.9	YES	800
31	0.42	115	48.3	11.0	7.77	22.2	YES	OFF

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012