


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	11/1/2022
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	OFF	OFF	OFF	0.022	OFF	0.022	
2	OFF	OFF	OFF	OFF	0.024	OFF	0.024	
3	OFF	OFF	OFF	0.028	0.038	0.030	0.038	
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9	OFF	OFF	OFF	0.040	0.022	0.022	0.040	
10	OFF	OFF	OFF	0.022	0.022	0.022	0.022	
11	OFF	OFF	0.022	0.020	0.020	0.025	0.025	
12	OFF	OFF	0.022	0.022	0.022	0.024	0.024	
13	OFF	OFF	0.026	0.026	0.026	0.026	0.026	
14	0.023	0.027	0.026	0.021	OFF	0.020	0.027	
15	0.024	0.020	0.020	0.027	0.020	0.020	0.027	
16	0.023	0.020	0.020	0.022	0.030	0.028	0.030	
17	0.020	0.020	0.020	0.022	0.020	0.020	0.022	
18	0.020	OFF	0.025	0.022	0.042	0.020	0.042	
19	0.034	0.021	0.021	0.020	0.020	0.022	0.034	
20	0.024	0.023	0.022	0.032	0.029	0.035	0.035	
21	0.028	0.020	0.020	0.021	0.021	0.021	0.028	
22	0.021	0.021	0.030	0.026	0.023	OFF	0.030	
23	OFF	OFF	0.022	0.021	0.022	0.022	0.022	
24	0.022	OFF	0.027	0.027	0.025	0.023	0.027	
25	0.049	OFF	0.026	0.022	0.022	0.046	0.049	
26	OFF	OFF	0.038	0.021	0.021	0.023	0.038	
27	0.022	0.022	0.021	OFF	OFF	OFF	0.022	
28	OFF	OFF	OFF	0.024	0.022	OFF	0.024	
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
					PRINTED NAME: Levi Beachy			
					SIGNATURE: 		12/6/2022	
					PHONE #: ( 503 ) 812-8804			
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Nov-22	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.53	115	61.0	11.0	7.80	46.6	YES	800
2	0.42	115	48.3	10.7	7.84	23.2	YES	800
3	0.41	115	47.2	10.4	7.86	23.8	YES	800
4	0.40	115	46.0	10.1	7.95	25.0	YES	OFF
5	0.39	115	44.9	10.5	7.90	23.9	YES	OFF
6	0.38	115	43.7	10.4	7.90	24.0	YES	OFF
7	0.38	115	43.7	10.3	7.89	24.1	YES	OFF
8	0.46	115	52.9	10.1	7.88	24.6	YES	OFF
9	0.40	115	46.0	10.0	7.84	24.2	YES	800
10	0.61	115	70.2	9.6	7.91	26.1	YES	800
11	0.40	115	46.0	9.4	7.94	26.1	YES	800
12	0.43	115	49.5	9.3	7.95	26.5	YES	800
13	0.47	115	54.1	9.2	8.03	27.6	YES	800
14	0.51	115	58.7	8.7	8.07	29.1	YES	800
15	0.58	115	66.7	8.8	8.03	28.7	YES	800
16	0.66	115	75.9	8.6	8.05	29.6	YES	800
17	0.71	115	81.7	8.5	8.11	30.6	YES	800
18	0.76	115	87.4	8.4	8.17	31.7	YES	800
19	0.81	115	93.2	8.1	8.08	31.4	YES	800
20	0.85	115	97.8	7.9	8.10	32.3	YES	800
21	0.86	115	98.9	8.3	8.08	31.2	YES	800
22	0.87	115	100.1	8.8	8.34	58.4	YES	800
23	0.86	115	98.9	8.9	8.25	31.9	YES	800
24	0.87	115	100.1	8.7	8.07	30.3	YES	800
25	0.87	115	100.1	8.7	8.07	30.3	YES	800
26	0.85	115	97.8	8.8	8.37	33.5	YES	800
27	0.85	115	97.8	8.9	8.24	31.7	YES	800
28	0.83	115	95.5	9.0	8.36	32.8	YES	800
29	0.81	115	93.2	8.8	8.08	30.0	YES	OFF
30	0.80	115	92.0	8.8	8.12	30.4	YES	OFF
31		115	0.0			4.4	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012