


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	1/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17	OFF	OFF	OFF	0.028	0.025	0.022	0.028	
18	OFF	0.024	0.022	0.022	0.038	0.030	0.038	
19	OFF	OFF	OFF	0.032	OFF	0.035	0.035	
20	OFF	0.038	0.038	0.037	0.032	0.032	0.038	
21	OFF	0.042	0.040	0.040	0.070	0.038	0.042	
22	0.040	0.040	0.042	0.040	0.033	0.040	0.042	
23	0.040	0.041	0.041	0.022	0.023	0.028	0.041	
24	0.028	0.020	0.027	0.022	0.022	0.022	0.028	
25	0.021	0.026	0.023	0.021	0.021	0.023	0.026	
26	0.022	OFF	0.020	0.021	0.022	0.030	0.030	
27	OFF	0.027	0.026	0.021	0.024	0.024	0.027	
28	0.049	0.040	0.049	0.049	0.022	0.021	0.049	
29	0.021	0.022	0.034	0.023	0.023	0.023	0.034	
30	0.021	OFF	0.033	0.027	0.031	0.021	0.033	
31	0.021	0.021	OFF	0.020	0.021	0.021	0.021	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
PRINTED NAME: Lpvi Beachy					SIGNATURE: 		2/8/2023	
					PHONE #: ( 503 ) 812-8804			
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Jan-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.74	115	85.1	8.7	8.16	61.9	YES	OFF
2	0.74	115	85.1	8.5	8.05	30.0	YES	OFF
3	0.74	115	85.1	8.6	8.09	30.3	YES	OFF
4	0.73	115	84.0	8.7	8.14	30.6	YES	OFF
5	0.72	115	82.8	8.7	8.19	31.1	YES	OFF
6	0.73	115	84.0	8.9	8.18	30.6	YES	OFF
7	0.72	115	82.8	8.9	8.18	30.6	YES	OFF
8	0.71	115	81.7	8.9	8.16	30.3	YES	OFF
9	0.71	115	81.7	8.9	8.13	30.0	YES	OFF
10	0.69	115	79.4	8.9	8.11	29.7	YES	OFF
11	0.69	115	79.4	9.0	9.26	44.9	YES	OFF
12	0.68	115	78.2	9.0	9.28	45.2	YES	OFF
13	0.67	115	77.1	9.2	9.17	42.8	YES	OFF
14	0.66	115	75.9	9.2	9.20	43.2	YES	OFF
15	0.65	115	74.8	9.2	9.14	42.2	YES	OFF
16	0.63	115	72.5	9.1	9.15	42.5	YES	OFF
17	0.63	115	72.5	9.2	9.30	44.7	YES	1000
18	0.61	115	70.2	9.2	7.95	27.2	YES	1000
19	0.60	115	69.0	9.0	8.45	33.0	YES	1000
20	0.56	115	64.4	8.6	7.97	28.4	YES	1000
21	0.55	115	63.3	8.2	8.37	33.7	YES	1000
22	0.60	115	69.0	8.6	8.35	57.6	YES	1000
23	0.63	115	72.5	8.5	8.35	33.1	YES	1000
24	0.65	115	74.8	8.3	8.04	30.0	YES	1000
25	0.70	115	80.5	8.2	8.04	30.4	YES	1000
26	0.72	115	82.8	8.4	8.00	29.6	YES	1000
27	0.74	115	85.1	8.7	7.98	28.9	YES	1000
28	0.74	115	85.1	8.8	8.72	37.6	YES	1000
29	0.74	115	85.1	8.2	8.06	30.8	YES	1000
30	0.74	115	85.1	7.5	8.71	40.9	YES	1000
31	0.75	115	86.3	7.4	8.11	33.1	YES	1000

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012