


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	3/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	0.026	0.049	0.028	0.033	OFF	0.031	0.049	
2	0.032	0.035	0.038	0.033	0.036	0.038	0.038	
3	0.038	OFF	0.049	0.036	0.032	0.032	0.049	
4	0.037	0.037	0.049	0.037	0.036	0.036	0.049	
5	0.032	OFF	0.040	0.039	0.033	0.038	0.040	
6	0.038	0.038	0.042	0.038	0.038	0.031	0.042	
7	0.031	OFF	0.040	0.038	0.038	0.038	0.040	
8	OFF	0.037	0.049	0.049	0.033	0.033	0.049	
9	0.032	OFF	0.039	0.034	0.038	0.038	0.039	
10	0.034	0.034	0.038	0.038	0.036	0.035	0.038	
11	0.037	0.037	0.038	0.037	0.038	0.038	0.038	
12	0.039	0.039	0.036	0.036	0.032	0.032	0.039	
13	0.033	0.039	0.039	0.037	0.037	0.049	0.049	
14	OFF	OFF	OFF	0.039	0.035	0.038	0.039	
15	0.038	OFF	0.039	0.041	0.037	0.038	0.041	
16	0.038	OFF	0.038	0.049	OFF	0.037	0.049	
17	0.032	0.032	0.048	0.039	0.038	0.038	0.048	
18	0.037	OFF	0.040	0.036	0.036	0.038	0.040	
19	0.038	OFF	0.033	0.038	0.037	0.039	0.039	
20	0.037	OFF	0.043	0.038	0.049	0.036	0.049	
21	0.033	0.038	0.034	0.040	0.038	0.038	0.040	
22	0.037	OFF	0.049	0.037	OFF	0.038	0.049	
23	0.039	OFF	0.038	0.049	0.032	0.038	0.049	
24	0.038	OFF	0.041	0.049	0.038	0.036	0.049	
25	0.037	0.037	0.039	0.038	0.038	0.036	0.039	
26	0.036	OFF	0.049	0.037	0.037	0.038	0.049	
27	0.038	OFF	0.038	0.038	0.038	0.038	0.038	
28	0.036	0.040	0.037	0.037	0.049	0.038	0.049	
29	0.038	0.038	0.038	0.039	0.039	0.038	0.039	
30	0.038	OFF	0.039	0.036	0.035	0.037	0.039	
31	0.038	0.039	0.039	0.037	0.037	0.038	0.039	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
				PRINTED NAME: Levi Beachy				
				SIGNATURE: 			4/10/2023	
				PHONE #: ( 503 ) 812-8804				
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Mar-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.70	115	80.5	7.6	8.36	68.5	YES	1000
2	0.70	115	80.5	8.1	8.33	34.0	YES	1000
3	0.69	115	79.4	8.1	8.29	33.5	YES	1000
4	0.69	115	79.4	8.1	8.65	38.2	YES	1000
5	0.68	115	78.2	8.1	8.25	32.9	YES	1000
6	0.68	115	78.2	8.3	8.54	36.1	YES	1000
7	0.69	115	79.4	8.3	8.32	33.4	YES	1000
8	0.70	115	80.5	8.1	8.30	33.6	YES	1000
9	0.71	115	81.7	8.4	8.34	33.5	YES	1000
10	0.71	115	81.7	8.3	8.30	33.2	YES	1000
11	0.71	115	81.7	8.4	8.33	33.4	YES	1000
12	0.72	115	82.8	8.3	8.33	33.6	YES	1000
13	0.72	115	82.8	8.9	8.21	30.9	YES	1000
14	0.70	115	80.5	8.7	9.25	45.8	YES	1000
15	0.70	115	80.5	8.7	8.32	32.5	YES	1000
16	0.71	115	81.7	8.5	8.24	32.1	YES	1000
17	0.72	115	82.8	8.7	8.79	38.7	YES	1000
18	0.72	115	82.8	8.9	8.33	32.3	YES	1000
19	0.72	115	82.8	9.1	8.25	30.9	YES	1000
20	0.71	115	81.7	9.2	8.29	31.1	YES	1000
21	0.71	115	81.7	8.9	8.33	32.2	YES	1000
22	0.71	115	81.7	9.0	8.30	57.6	YES	1000
23	0.71	115	81.7	9.1	8.34	31.9	YES	1000
24	0.71	115	81.7	8.6	8.64	36.8	YES	1000
25	0.71	115	81.7	8.1	8.53	36.6	YES	1000
26	0.71	115	81.7	8.3	8.38	34.2	YES	1000
27	0.71	115	81.7	8.3	8.37	34.1	YES	1000
28	0.71	115	81.7	8.6	8.36	33.3	YES	1000
29	0.72	115	82.8	8.4	8.37	33.9	YES	1000
30	0.73	115	84.0	8.8	8.76	38.1	YES	1000
31	0.73	115	84.0	8.9	8.36	32.7	YES	1000

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012