


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	4/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	0.037	0.040	0.038	0.039	0.036	0.040	
2	0.031	OFF	0.040	0.037	0.037	0.038	0.040	
3	0.038	OFF	0.040	0.038	0.038	0.036	0.040	
4	0.036	0.042	0.049	0.039	0.036	0.037	0.049	
5	0.032	OFF	0.039	0.038	OFF	0.038	0.039	
6	0.038	OFF	0.039	0.037	0.037	0.038	0.039	
7	0.038	OFF	0.038	0.040	0.049	0.040	0.049	
8	0.039	0.049	0.049	0.038	0.033	0.038	0.049	
9	0.038	0.040	0.043	0.040	OFF	0.036	0.040	
10	0.039	OFF	0.049	0.039	0.039	0.039	0.049	
11	OFF	OFF	OFF	0.049	OFF	0.033	0.049	
12	OFF	OFF	0.049	0.037	0.037	0.038	0.049	
13	0.037	0.037	0.039	0.037	0.037	0.037	0.039	
14	0.038	OFF	0.040	0.038	0.038	0.038	0.040	
15	0.038	OFF	0.043	0.038	0.038	0.038	0.043	
16	0.038	OFF	0.038	0.039	0.037	0.037	0.039	
17	0.037	0.037	0.049	0.039	0.033	OFF	0.049	
18	OFF	OFF	0.049	0.039	0.043	0.036	0.049	
19	0.038	OFF	0.041	0.037	0.032	0.033	0.041	
20	0.039	OFF	0.039	0.033	0.035	0.035	0.039	
21	0.037	OFF	0.039	0.037	0.036	0.036	0.039	
22	0.036	OFF	0.042	0.038	OFF	0.037	0.042	
23	0.038	OFF	0.040	0.039	OFF	0.038	0.040	
24	0.036	OFF	0.039	0.038	0.037	0.038	0.039	
25	0.038	OFF	0.040	0.040	0.038	0.038	0.040	
26	OFF	0.032	0.049	0.038	0.032	0.031	0.049	
27	0.033	OFF	0.049	0.037	0.036	0.038	0.049	
28	0.038	0.041	0.040	0.039	0.035	0.031	0.041	
29	0.038	OFF	0.039	0.039	0.037	0.037	0.039	
30	0.041	OFF	0.040	0.038	0.038	0.036	0.041	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		5/1/2023	
PHONE #: ( 503 ) 812-8804								
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Apr-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.73	115	84.0	8.8	8.89	71.8	YES	1000
2	0.71	115	81.7	8.6	8.32	32.8	YES	1000
3	0.71	115	81.7	8.3	8.60	37.1	YES	1000
4	0.71	115	81.7	8.5	8.21	31.7	YES	1000
5	0.71	115	81.7	8.5	8.22	31.8	YES	1000
6	0.71	115	81.7	9.0	8.71	36.8	YES	1000
7	0.71	115	81.7	9.1	8.20	30.3	YES	1000
8	0.71	115	81.7	9.0	8.16	30.1	YES	1000
9	0.71	115	81.7	9.2	8.19	30.0	YES	1000
10	0.71	115	81.7	9.2	8.94	39.5	YES	1000
11	0.70	115	80.5	9.2	8.09	28.9	YES	1000
12	0.69	115	79.4	8.9	7.97	28.2	YES	1000
13	0.70	115	80.5	8.9	8.08	29.4	YES	1000
14	0.71	115	81.7	9.0	8.14	29.9	YES	1000
15	0.72	115	82.8	9.4	8.22	30.0	YES	1000
16	0.73	115	84.0	9.4	8.15	29.3	YES	1000
17	0.73	115	84.0	9.2	8.39	32.4	YES	1000
18	0.72	115	82.8	9.2	8.34	31.7	YES	1000
19	0.73	115	84.0	8.9	8.21	30.9	YES	1000
20	0.73	115	84.0	8.8	8.26	31.7	YES	1000
21	0.75	115	86.3	9.1	8.17	30.1	YES	1000
22	0.74	115	85.1	9.4	8.35	58.3	YES	1000
23	0.74	115	85.1	9.7	8.20	29.2	YES	1000
24	0.74	115	85.1	9.5	8.33	31.1	YES	1000
25	0.74	115	85.1	9.1	8.92	39.6	YES	1000
26	0.74	115	85.1	9.5	8.17	29.3	YES	1000
27	0.74	115	85.1	9.8	8.18	28.8	YES	1000
28	0.74	115	85.1	10.1	8.14	27.8	YES	1000
29	0.74	115	85.1	10.4	8.73	33.8	YES	1000
30	0.74	115	85.1	10.4	8.21	28.0	YES	1000
31		115	0.0			4.4	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012