


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	5/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.030	OFF	OFF	OFF	0.038	0.030	0.038	
2	0.032	0.038	0.064	0.040	OFF	0.035	0.064	
3	0.037	OFF	0.040	OFF	0.050	0.040	0.050	
4	0.038	0.038	0.042	0.042	0.042	0.042	0.042	
5	0.042	0.044	0.052	0.047	0.060	0.037	0.060	
6	0.032	0.039	0.036	0.069	0.036	0.036	0.069	
7	0.035	0.035	0.032	0.038	0.039	OFF	0.039	
8	OFF	OFF	0.032	OFF	OFF	OFF	0.032	
9	OFF	0.069	OFF	0.035	OFF	OFF	0.069	
10	OFF	0.030	0.037	0.069	0.036	0.036	0.069	
11	0.069	0.036	0.036	0.036	0.036	0.036	0.069	
12	0.036	0.038	0.038	0.038	0.036	0.036	0.038	
13	0.035	0.040	0.038	0.032	0.034	0.038	0.040	
14	0.039	0.037	0.037	0.033	0.033	0.033	0.039	
15	0.033	0.042	0.038	OFF	0.037	0.037	0.042	
16	0.037	0.032	0.032	0.032	0.035	0.035	0.035	
17	0.038	0.038	0.020	0.038	0.039	0.035	0.039	
18	0.033	0.035	0.035	0.035	0.035	0.033	0.035	
19	0.037	0.038	0.038	0.033	0.033	0.035	0.038	
20	0.036	OFF	0.037	0.037	0.035	0.035	0.037	
21	0.040	0.035	0.038	0.038	0.036	0.036	0.040	
22	0.038	0.038	0.038	0.036	0.035	0.035	0.038	
23	0.038	0.069	0.032	0.037	0.037	0.390	0.069	
24	0.039	OFF	0.037	OFF	OFF	OFF	0.039	
25	OFF	OFF	OFF	OFF	0.032	0.032	0.032	
26	0.039	0.039	0.040	0.036	0.036	0.036	0.040	
27	0.036	0.040	0.037	0.035	0.035	0.036	0.040	
28	0.036	0.041	0.039	0.035	0.035	0.035	0.041	
29	0.035	0.035	0.035	0.035	0.036	0.034	0.036	
30	0.036	0.048	0.037	OFF	0.035	0.035	0.048	
31	0.036	0.037	0.037	0.037	0.036	0.036	0.037	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		6/1/2023	
PHONE #: (503) 812-8804								
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	May-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.73	115	84.0	10.3	8.27	61.9	YES	1000
2	0.73	115	84.0	10.2	8.18	28.0	YES	1000
3	0.73	115	84.0	10.2	8.24	28.6	YES	1000
4	0.73	115	84.0	10.2	8.31	29.4	YES	1000
5	0.73	115	84.0	10.1	8.63	33.2	YES	1000
6	0.73	115	84.0	10.1	8.20	28.4	YES	1000
7	0.73	115	84.0	10.2	8.74	34.3	YES	1000
8	0.72	115	82.8	10.5	8.45	30.2	YES	1000
9	0.72	115	82.8	10.3	8.27	28.7	YES	1000
10	0.71	115	81.7	10.2	8.35	29.7	YES	1000
11	0.72	115	82.8	10.7	8.25	27.7	YES	1000
12	0.71	115	81.7	10.7	8.41	29.4	YES	1000
13	0.68	115	78.2	11.0	8.18	26.4	YES	1000
14	0.67	115	77.1	11.6	8.17	25.2	YES	1000
15	0.65	115	74.8	12.1	8.20	24.6	YES	1000
16	0.63	115	72.5	11.8	8.23	25.3	YES	1000
17	0.63	115	72.5	11.8	8.25	25.5	YES	1000
18	0.63	115	72.5	12.0	8.28	25.4	YES	1000
19	0.62	115	71.3	11.6	8.74	30.8	YES	1000
20	0.62	115	71.3	11.8	8.30	25.9	YES	1000
21	0.62	115	71.3	11.7	8.23	25.5	YES	1000
22	0.62	115	71.3	11.4	8.36	55.2	YES	1000
23	0.63	115	72.5	11.2	8.32	27.2	YES	1000
24	0.64	115	73.6	11.0	8.48	29.3	YES	1000
25	0.62	115	71.3	11.0	8.41	28.5	YES	1000
26	0.62	115	71.3	11.5	7.82	22.3	YES	1000
27	0.64	115	73.6	11.5	8.39	27.4	YES	1000
28	0.65	115	74.8	10.9	8.40	28.7	YES	1000
29	0.65	115	74.8	11.2	8.42	28.3	YES	1000
30	0.65	115	74.8	11.3	8.41	28.0	YES	1000
31	0.65	115	74.8	11.0	8.43	28.8	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012