


| OHA - Drinking Water Program -Turbidity Monitoring Report Form | | | | | | | County: | Tillamook |
|--|-------------------|------------|------------|------------------------------------|--|------------|--|-----------|
| Conventional or Direct Filtration | | | | | | | Month/Year: | 6/1/2023 |
| System Name: | City of Tillamook | | | ID#: 41 | 00893 | | WTP : TP - | Combined |
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day ¹ [NTU] | |
| 1 | 0.032 | 0.032 | 0.035 | 0.038 | 0.034 | 0.035 | 0.038 | |
| 2 | 0.035 | 0.036 | 0.036 | 0.034 | 0.034 | 0.034 | 0.036 | |
| 3 | 0.037 | 0.037 | 0.037 | 0.037 | 0.037 | 0.035 | 0.037 | |
| 4 | 0.034 | 0.034 | 0.036 | 0.032 | 0.032 | 0.032 | 0.036 | |
| 5 | 0.036 | 0.037 | 0.037 | 0.035 | 0.039 | 0.033 | 0.039 | |
| 6 | 0.038 | 0.035 | 0.033 | 0.036 | 0.032 | 0.032 | 0.038 | |
| 7 | 0.037 | 0.037 | 0.031 | 0.034 | 0.034 | 0.034 | 0.037 | |
| 8 | 0.036 | OFF | 0.038 | 0.036 | 0.036 | 0.037 | 0.038 | |
| 9 | 0.040 | 0.034 | 0.034 | 0.037 | 0.037 | 0.037 | 0.040 | |
| 10 | 0.036 | 0.038 | 0.038 | 0.037 | 0.037 | 0.037 | 0.038 | |
| 11 | 0.038 | 0.038 | 0.036 | 0.037 | 0.037 | 0.037 | 0.038 | |
| 12 | 0.034 | 0.040 | 0.039 | 0.036 | 0.037 | 0.037 | 0.040 | |
| 13 | 0.040 | 0.036 | 0.039 | 0.032 | 0.032 | 0.320 | 0.040 | |
| 14 | 0.035 | 0.036 | 0.036 | 0.036 | 0.036 | 0.036 | 0.036 | |
| 15 | 0.036 | 0.036 | 0.035 | 0.038 | 0.039 | 0.032 | 0.039 | |
| 16 | 0.033 | 0.037 | 0.037 | 0.036 | 0.036 | 0.039 | 0.039 | |
| 17 | 0.039 | 0.039 | 0.039 | 0.032 | 0.032 | 0.037 | 0.039 | |
| 18 | 0.038 | 0.038 | 0.038 | 0.038 | 0.038 | 0.037 | 0.038 | |
| 19 | 0.037 | 0.037 | 0.037 | 0.040 | 0.036 | 0.035 | 0.040 | |
| 20 | 0.039 | OFF | 0.039 | 0.033 | 0.038 | 0.038 | 0.039 | |
| 21 | 0.040 | 0.036 | 0.037 | 0.037 | 0.037 | 0.037 | 0.040 | |
| 22 | 0.037 | 0.037 | 0.038 | 0.037 | 0.037 | 0.038 | 0.038 | |
| 23 | 0.039 | 0.037 | 0.037 | 0.037 | 0.037 | 0.040 | 0.040 | |
| 24 | 0.037 | 0.037 | 0.037 | 0.038 | 0.038 | 0.035 | 0.038 | |
| 25 | 0.034 | 0.048 | OFF | 0.037 | OFF | OFF | 0.048 | |
| 26 | 0.038 | 0.036 | 0.038 | 0.039 | 0.038 | 0.038 | 0.039 | |
| 27 | 0.038 | 0.036 | 0.034 | 0.035 | 0.034 | 0.038 | 0.038 | |
| 28 | 0.039 | 0.039 | 0.038 | 0.035 | 0.035 | 0.038 | 0.039 | |
| 29 | 0.037 | 0.036 | OFF | 0.036 | 0.037 | OFF | 0.037 | |
| 30 | 0.036 | OFF | 0.038 | 0.035 | 0.036 | OFF | 0.038 | |
| 31 | | | | | | | | |
| Conventional or Direct Filtration | | | | Monthly Summary (Answer Yes or No) | | | | |
| 95% of daily turbidity readings ≤ 0.3 NTU? | | | | Yes | CT's met everyday? (see back) | | All Cl2 residual at entry point ≥ 0.2 mg/l? | |
| All daily turbidity readings ≤ 1 NTU? | | | | Yes | Yes | | Yes | |
| All turbidity readings < IFE ² triggers | | | | Yes | | | | |
| PRINTED NAME: Leyi Beachy | | | | | SIGNATURE:  | | 7/5/2023 | |
| PHONE #: (503) 812-8804 | | | | | | | | |
| ¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C)) | | | | | | | | |

| OHA - Drinking Water Program - Surface Water Quality Data Form | | | | | | | WTP - : | A |
|--|---|---------------------|--------------|-------|-------------|-------------|---|----------------------------|
| System Name: | City of Tillamook | | ID#: 41 | 00893 | Month/Year: | Jun-23 | Disinfection <i>Giardia</i> Log Inactiv: | 0.5 |
| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 0.65 | 115 | 74.8 | 11.0 | 8.47 | 57.4 | YES | 1000 |
| 2 | 0.65 | 115 | 74.8 | 10.9 | 8.41 | 28.8 | YES | 1000 |
| 3 | 0.66 | 115 | 75.9 | 11.0 | 8.43 | 28.8 | YES | 1000 |
| 4 | 0.66 | 115 | 75.9 | 11.2 | 8.41 | 28.2 | YES | 1000 |
| 5 | 0.66 | 115 | 75.9 | 11.1 | 8.39 | 28.2 | YES | 1000 |
| 6 | 0.67 | 115 | 77.1 | 11.2 | 8.40 | 28.2 | YES | 1000 |
| 7 | 0.67 | 115 | 77.1 | 11.5 | 8.35 | 27.1 | YES | 1000 |
| 8 | 0.67 | 115 | 77.1 | 11.8 | 8.31 | 26.2 | YES | 1000 |
| 9 | 0.67 | 115 | 77.1 | 11.6 | 8.39 | 27.3 | YES | 1000 |
| 10 | 0.67 | 115 | 77.1 | 11.3 | 8.56 | 29.6 | YES | 1000 |
| 11 | 0.65 | 115 | 74.8 | 11.8 | 8.65 | 29.5 | YES | 1000 |
| 12 | 0.65 | 115 | 74.8 | 11.9 | 8.34 | 26.2 | YES | 1000 |
| 13 | 0.65 | 115 | 74.8 | 12.1 | 8.39 | 26.3 | YES | 1000 |
| 14 | 0.64 | 115 | 73.6 | 11.6 | 8.39 | 27.2 | YES | 1000 |
| 15 | 0.64 | 115 | 73.6 | 11.5 | 8.41 | 27.6 | YES | 1000 |
| 16 | 0.65 | 115 | 74.8 | 11.6 | 8.32 | 26.6 | YES | 1000 |
| 17 | 0.64 | 115 | 73.6 | 11.9 | 8.35 | 26.3 | YES | 1000 |
| 18 | 0.64 | 115 | 73.6 | 11.6 | 8.36 | 26.9 | YES | 1000 |
| 19 | 0.64 | 115 | 73.6 | 11.1 | 8.80 | 32.6 | YES | 1000 |
| 20 | 0.62 | 115 | 71.3 | 11.2 | 8.38 | 27.8 | YES | 1000 |
| 21 | 0.63 | 115 | 72.5 | 11.0 | 8.34 | 27.8 | YES | 1000 |
| 22 | 0.63 | 115 | 72.5 | 11.5 | 8.39 | 56.0 | YES | 1000 |
| 23 | 0.63 | 115 | 72.5 | 11.9 | 8.36 | 26.4 | YES | 1000 |
| 24 | 0.63 | 115 | 72.5 | 11.5 | 8.38 | 27.3 | YES | 1000 |
| 25 | 0.64 | 115 | 73.6 | 11.8 | 8.41 | 27.0 | YES | 1000 |
| 26 | 0.63 | 115 | 72.5 | 12.0 | 8.56 | 28.1 | YES | 1000 |
| 27 | 0.63 | 115 | 72.5 | 12.1 | 8.39 | 26.3 | YES | 1000 |
| 28 | 0.62 | 115 | 71.3 | 12.2 | 7.93 | 22.1 | YES | 1000 |
| 29 | 0.63 | 115 | 72.5 | 12.4 | 7.89 | 21.6 | YES | 1000 |
| 30 | 0.60 | 115 | 69.0 | 12.9 | 8.05 | 22.1 | YES | 1000 |
| 31 | | 115 | 0.0 | | | 4.3 | YES | |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012