


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	8/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	OFF	0.037	0.038	0.033	0.038	
2	OFF	OFF	0.035	0.036	OFF	0.037	0.037	
3	OFF	OFF	0.036	0.036	0.037	OFF	0.037	
4	0.031	OFF	0.038	0.037	0.035	OFF	0.038	
5	0.049	OFF	OFF	0.036	OFF	0.039	0.049	
6	OFF	OFF	0.040	0.038	OFF	0.041	0.041	
7	OFF	0.063	OFF	0.069	0.069	OFF	0.069	
8	0.041	0.041	OFF	0.050	0.036	0.039	0.050	
9	0.038	0.038	OFF	OFF	0.038	OFF	0.038	
10	OFF	OFF	OFF	OFF	0.039	OFF	0.039	
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14	OFF	OFF	OFF	0.037	0.037	OFF	0.037	
15	OFF	OFF	0.037	OFF	OFF	OFF	0.037	
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17	OFF	OFF	0.039	0.039	0.041	OFF	0.041	
18	OFF	OFF	OFF	OFF	0.043	OFF	0.043	
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21	OFF	OFF	0.033	0.033	0.033	OFF	OFF	
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23	OFF	OFF	OFF	0.033	OFF	OFF	0.033	
24	OFF	OFF	0.033	OFF	0.033	OFF	0.033	
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
28	OFF	OFF	OFF	OFF	0.015	OFF	0.015	
29	OFF	OFF	OFF	0.033	0.033	OFF	0.033	
30	OFF	OFF	OFF	0.060	OFF	OFF	0.060	
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
5					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			9/6/2023
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Aug-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.41	115	47.2	13.3	8.26	43.4	YES	1000
2	0.42	115	48.3	13.3	8.12	21.6	YES	1000
3	0.44	115	50.6	13.3	8.05	21.1	YES	1000
4	0.45	115	51.8	13.3	8.07	21.3	YES	1000
5	0.46	115	52.9	13.6	8.05	20.7	YES	1000
6	0.46	115	52.9	13.6	8.01	20.4	YES	1000
7	0.47	115	54.1	13.7	8.34	22.9	YES	1000
8	0.49	115	56.4	13.5	8.03	20.8	YES	1000
9	0.49	115	56.4	13.5	7.91	19.9	YES	1000
10	0.42	115	48.3	13.3	8.16	21.9	YES	1000
11	0.45	115	51.8	13.3	8.06	21.2	YES	OFF
12	0.42	115	48.3	13.4	8.06	21.0	YES	OFF
13	0.39	115	44.9	13.4	8.06	20.9	YES	OFF
14	0.40	115	46.0	13.6	8.06	20.7	YES	1000
15	0.39	115	44.9	14.1	8.19	20.9	YES	1000
16	0.38	115	43.7	14.0	8.23	21.4	YES	OFF
17	0.37	115	42.6	14.0	8.23	21.4	YES	1000
18	0.38	115	43.7	13.8	7.87	19.0	YES	1000
19	0.36	115	41.4	13.6	7.91	19.5	YES	OFF
20	0.35	115	40.3	13.5	7.89	19.4	YES	OFF
21	0.34	115	39.1	13.4	7.88	19.5	YES	OFF
22	0.36	115	41.4	13.2	7.93	20.1	YES	OFF
23	0.34	115	39.1	13.3	7.92	19.9	YES	1000
24	0.34	115	39.1	13.2	7.89	19.8	YES	1000
25	0.36	115	41.4	13.4	7.95	20.0	YES	OFF
26	0.34	115	39.1	13.5	7.93	19.7	YES	OFF
27	0.31	115	35.7	13.5	7.93	19.6	YES	OFF
28	0.32	115	36.8	13.3	8.10	21.2	YES	1000
29	0.31	115	35.7	13.2	7.89	19.7	YES	1000
30	0.34	115	39.1	13.2	8.00	20.6	YES	1000
31	0.33	115	38.0	13.2	7.96	20.3	YES	OFF

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012