


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	9/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	OFF	OFF	OFF	0.038	OFF	0.038	
2	OFF	OFF	OFF	OFF	OFF	0.039	0.039	
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4	OFF	OFF	OFF	OFF	0.033	OFF	0.033	
5	OFF	OFF	OFF	OFF	0.018	0.036	0.036	
6	OFF	OFF	0.039	0.037	0.036	0.038	0.039	
7	0.035	OFF	0.039	0.040	0.037	0.038	0.040	
8	OFF	0.040	OFF	0.037	0.040	0.038	0.040	
9	0.037	OFF	0.037	0.037	0.038	0.040	0.040	
10	OFF	OFF	0.038	0.038	0.040	0.018	0.040	
11	0.039	OFF	0.040	0.018	0.060	0.060	0.060	
12	0.040	OFF	0.040	0.040	0.040	0.040	0.040	
13	0.040	OFF	0.041	0.043	OFF	0.042	0.043	
14	OFF	OFF	OFF	0.049	0.049	OFF	0.049	
15	0.047	OFF	0.053	0.055	0.053	0.058	0.058	
16	OFF	OFF	0.061	0.061	OFF	0.063	0.063	
17	OFF	OFF	OFF	0.068	0.068	0.069	0.069	
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
27	OFF	OFF	OFF	OFF	0.032	OFF	0.032	
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
<b>5</b>					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			10/2/2023
					PHONE #: ( 503 ) 812-8804			
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Sep-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.32	115	36.8	13.1	7.96	40.9	YES	1000
2	0.29	115	33.4	13.2	7.93	20.0	YES	1000
3	0.27	115	31.1	13.4	7.95	19.8	YES	OFF
4	0.25	115	28.8	13.2	7.96	20.1	YES	1000
5	0.26	115	29.9	12.8	7.94	20.5	YES	1000
6	0.29	115	33.4	12.3	8.05	22.1	YES	1000
7	0.33	115	38.0	12.2	7.97	21.7	YES	1000
8	0.33	115	38.0	12.0	7.86	21.2	YES	1000
9	0.40	115	46.0	12.3	7.99	21.9	YES	1000
10	0.44	115	50.6	12.5	8.22	23.7	YES	1000
11	0.47	115	54.1	12.5	7.97	21.7	YES	1000
12	0.49	115	56.4	12.2	7.93	21.8	YES	1000
13	0.51	115	58.7	12.4	7.89	21.3	YES	1000
14	0.50	115	57.5	12.4	7.97	21.9	YES	1000
15	0.51	115	58.7	12.5	7.97	21.8	YES	1000
16	0.51	115	58.7	12.6	7.98	21.7	YES	1000
17	0.51	115	58.7	12.1	8.06	23.1	YES	1000
18	0.49	115	56.4	12.3	8.73	28.8	YES	OFF
19	0.49	115	56.4	12.0	8.63	28.4	YES	OFF
20	0.48	115	55.2	12.2	8.47	26.4	YES	OFF
21	0.48	115	55.2	11.9	8.47	26.9	YES	OFF
22	0.50	115	57.5	12.0	8.39	26.1	YES	OFF
23	0.48	115	55.2	12.2	8.30	24.8	YES	OFF
24	0.47	115	54.1	12.1	8.32	25.2	YES	OFF
25	0.49	115	56.4	12.2	8.27	24.6	YES	OFF
26	0.47	115	54.1	12.1	8.01	22.5	YES	OFF
27	0.45	115	51.8	12.1	8.07	23.0	YES	1000
28	0.44	115	50.6	12.0	7.92	21.9	YES	OFF
29	0.43	115	49.5	12.0	8.01	22.6	YES	OFF
30	0.41	115	47.2	11.9	8.03	22.9	YES	OFF
31		115	0.0			4.3	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012