


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	11/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15	OFF	OFF	0.048	OFF	0.038	OFF	0.048	
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
20	OFF	OFF	OFF	0.038	0.038	OFF	0.038	
21	OFF	OFF	0.038	0.038	0.040	0.039	0.040	
22	0.039	OFF	0.040	0.038	0.038	0.040	0.040	
23	0.040	0.040	0.040	0.039	0.042	0.037	0.042	
24	OFF	0.040	0.038	0.040	0.039	0.039	0.040	
25	0.039	0.036	0.038	0.040	0.040	0.041	0.041	
26	0.038	OFF	0.038	0.040	0.039	0.039	0.040	
27	0.039	0.039	0.039	0.041	0.042	0.038	0.042	
28	OFF	OFF	0.040	0.048	0.040	0.038	0.048	
29	0.038	0.043	0.040	0.040	0.040	0.040	0.043	
30	0.040	0.038	0.040	0.040	0.040	0.040	0.040	
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings $\leq$ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point $\geq$ 0.2 mg/l?	
All daily turbidity readings $\leq$ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE <sup>2</sup> triggers				Yes				
<b>5</b>					PRINTED NAME: Levi Beachy			
					SIGNATURE: 			12/5/2023
					PHONE #: ( 503 ) 812-8804			
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Nov-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.64	115	73.6	10.3	7.40	20.9	YES	OFF
2	0.57	115	65.6	10.9	7.43	20.1	YES	OFF
3	0.59	115	67.9	10.8	7.43	20.3	YES	OFF
4	0.48	115	55.2	11.3	7.43	19.4	YES	OFF
5	0.84	115	96.6	11.0	7.44	20.7	YES	OFF
6	0.59	115	67.9	11.0	7.45	20.2	YES	OFF
7	0.87	115	100.1	11.0	7.45	20.8	YES	OFF
8	0.77	115	88.6	10.6	7.45	21.1	YES	OFF
9	0.75	115	86.3	10.4	7.45	21.4	YES	OFF
10	0.77	115	88.6	10.5	7.45	21.3	YES	OFF
11	0.78	115	89.7	10.7	7.45	21.0	YES	OFF
12	0.78	115	89.7	10.6	7.45	21.2	YES	OFF
13	0.22	115	25.3	10.6	7.45	19.9	YES	OFF
14	0.62	115	71.3	10.4	7.44	21.0	YES	OFF
15	0.70	115	80.5	10.5	7.44	21.0	YES	1000
16	0.60	115	69.0	10.4	7.59	22.1	YES	OFF
17	0.62	115	71.3	10.1	7.59	22.6	YES	OFF
18	0.61	115	70.2	10.2	7.56	22.2	YES	OFF
19	0.61	115	70.2	10.2	7.56	22.2	YES	OFF
20	0.63	115	72.5	10.0	7.56	22.5	YES	1000
21	0.59	115	67.9	9.7	7.71	24.1	YES	1000
22	0.51	115	58.7	9.9	7.33	20.6	YES	1000
23	0.49	115	56.4	9.2	7.32	21.5	YES	1000
24	0.48	115	55.2	8.7	7.77	26.0	YES	1000
25	0.52	115	59.8	8.3	7.80	27.1	YES	1000
26	0.58	115	66.7	8.1	7.87	28.4	YES	1000
27	0.63	115	72.5	8.1	7.86	28.4	YES	1000
28	0.64	115	73.6	8.1	7.93	29.2	YES	1000
29	0.67	115	77.1	8.0	8.08	31.2	YES	1000
30	0.72	115	82.8	8.4	7.86	28.2	YES	1000
31		115	0.0			4.2	YES	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012