


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	12/1/2023
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.039	0.039	0.044	0.040	0.040	0.039	0.044	
2	0.039	0.043	0.043	0.040	0.058	OFF	0.043	
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7	OFF	OFF	OFF	0.052	0.038	0.038	0.052	
8	0.038	0.038	0.040	0.036	0.036	0.050	0.050	
9	0.037	0.033	0.039	0.036	0.036	0.044	0.044	
10	0.038	OFF	0.036	0.036	0.036	OFF	0.038	
11	0.041	0.040	0.040	0.036	0.038	0.038	0.041	
12	0.036	0.036	0.041	0.040	0.038	0.036	0.041	
13	0.036	OFF	0.035	0.036	0.038	0.037	0.038	
14	0.035	0.035	0.038	0.038	0.038	0.040	0.040	
15	0.040	0.039	0.039	0.040	0.040	0.040	0.040	
16	0.036	0.039	OFF	0.041	0.040	0.040	0.041	
17	0.040	OFF	0.040	0.038	0.040	0.040	0.040	
18	0.040	0.040	0.040	0.039	0.040	0.038	0.040	
19	0.038	OFF	0.040	0.038	0.038	0.022	0.040	
20	0.040	0.040	0.038	0.040	0.040	0.038	0.040	
21	0.039	0.039	0.038	0.041	0.040	0.038	0.041	
22	0.022	OFF	0.038	0.038	0.022	0.040	0.040	
23	0.040	OFF	0.038	0.038	0.040	0.038	0.040	
24	0.041	OFF	OFF	0.041	0.041	0.038	0.041	
25	0.039	0.040	OFF	0.037	0.038	0.040	0.040	
26	0.040	OFF	0.040	0.040	0.041	0.040	0.041	
27	0.042	OFF	0.038	0.039	0.041	0.041	0.042	
28	0.038	OFF	0.037	0.040	0.040	0.042	0.042	
29	OFF	0.040	0.039	0.038	0.040	0.028	0.040	
30	0.040	OFF	0.038	0.043	0.039	0.040	0.043	
31	0.040	0.040	0.039	0.041	0.038	0.038	0.041	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		1/3/2024	
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Dec-23	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.73	115	84.0	8.7	7.81	27.1	YES	1000
2	0.70	115	80.5	9.2	7.78	25.9	YES	1000
3	0.68	115	78.2	9.5	7.96	27.0	YES	OFF
4	0.66	115	75.9	9.9	7.83	25.0	YES	OFF
5	0.64	115	73.6	10.0	7.80	24.5	YES	OFF
6	0.62	115	71.3	10.1	7.85	24.8	YES	OFF
7	0.61	115	70.2	9.8	7.85	25.2	YES	1000
8	0.58	115	66.7	9.4	7.74	24.8	YES	1000
9	0.61	115	70.2	9.2	7.96	27.3	YES	1000
10	0.64	115	73.6	9.9	7.97	26.2	YES	1000
11	0.66	115	75.9	9.9	7.83	25.0	YES	1000
12	0.68	115	78.2	9.3	7.66	24.6	YES	1000
13	0.69	115	79.4	9.1	7.73	25.6	YES	1000
14	0.71	115	81.7	9.4	7.78	25.6	YES	1000
15	0.72	115	82.8	9.4	7.91	26.8	YES	1000
16	0.72	115	82.8	9.0	7.97	28.1	YES	1000
17	0.73	115	84.0	9.1	7.98	28.1	YES	1000
18	0.74	115	85.1	9.3	8.01	28.0	YES	1000
19	0.74	115	85.1	9.7	7.97	26.9	YES	1000
20	0.76	115	87.4	9.5	7.96	27.2	YES	1000
21	0.75	115	86.3	9.3	7.97	27.7	YES	1000
22	0.77	115	88.6	9.5	8.18	29.5	YES	1000
23	0.74	115	85.1	9.0	8.00	28.5	YES	1000
24	0.73	115	84.0	8.5	7.99	29.4	YES	1000
25	0.73	115	84.0	9.2	8.00	28.1	YES	1000
26	0.73	115	84.0	9.4	8.76	36.5	YES	1000
27	0.72	115	82.8	9.5	7.98	27.3	YES	1000
28	0.72	115	82.8	9.7	8.15	28.6	YES	1000
29	0.70	115	80.5	9.8	7.98	26.7	YES	1000
30	0.71	115	81.7	9.9	7.99	26.6	YES	1000
31	0.71	115	81.7	9.4	7.97	27.4	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012