


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	1/1/2024
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.039	OFF	0.043	0.040	0.040	0.042	0.043	
2	0.041	OFF	0.040	0.040	0.040	0.040	0.041	
3	0.040	OFF	0.041	0.040	0.040	0.040	0.041	
4	0.044	0.050	0.041	0.041	0.041	0.040	0.050	
5	0.040	0.042	0.040	0.043	0.042	0.042	0.043	
6	0.044	0.041	0.046	0.052	0.052	0.040	0.052	
7	0.041	0.041	0.062	0.038	0.037	0.040	0.062	
8	0.040	0.040	0.040	0.037	0.037	0.041	0.041	
9	0.037	0.037	0.041	0.042	0.039	0.037	0.042	
10	OFF	0.038	0.061	0.038	0.036	0.036	0.061	
11	OFF	0.040	OFF	0.038	OFF	OFF	0.040	
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
17	OFF	OFF	0.037	0.035	0.037	0.044	0.044	
18	0.053	0.020	0.040	0.040	0.040	0.040	0.053	
19	0.018	0.058	0.040	0.038	0.038	0.038	0.058	
20	0.036	OFF	0.036	0.042	0.038	0.038	0.042	
21	0.035	OFF	OFF	0.036	0.040	0.040	0.040	
22	0.038	OFF	0.038	0.038	0.039	0.037	0.039	
23	0.040	OFF	0.039	0.040	0.042	0.064	0.064	
24	0.040	OFF	0.038	0.050	0.040	0.037	0.050	
25	0.040	0.036	0.040	0.040	0.039	0.038	0.040	
26	0.039	OFF	0.041	0.038	0.039	0.039	0.041	
27	0.039	OFF	0.036	OFF	0.040	0.040	0.040	
28	0.040	0.040	OFF	0.041	0.061	0.040	0.061	
29	0.040	0.040	0.040	OFF	OFF	OFF	0.040	
30	OFF	0.039	0.038	0.037	0.038	0.037	0.039	
31	0.038	0.039	0.039	0.037	0.037	0.040	0.040	
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		2/1/2024	
PHONE #: (503) 812-8804								
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Jan-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.70	115	80.5	8.9	8.06	29.2	YES	1000
2	0.70	115	80.5	9.0	8.01	28.5	YES	1000
3	0.72	115	82.8	9.3	7.99	27.8	YES	1000
4	0.72	115	82.8	9.3	8.11	29.0	YES	1000
5	0.74	115	85.1	9.1	7.98	28.1	YES	1000
6	0.71	115	81.7	9.2	8.01	28.1	YES	1000
7	0.70	115	80.5	8.9	8.19	30.6	YES	1000
8	0.70	115	80.5	8.9	8.16	30.3	YES	1000
9	0.70	115	80.5	9.3	9.05	40.8	YES	1000
10	0.70	115	80.5	8.8	7.83	27.1	YES	1000
11	0.70	115	80.5	8.7	8.36	33.0	YES	1000
12	0.68	115	78.2	8.9	7.95	28.0	YES	OFF
13	0.66	115	75.9	8.7	7.97	28.5	YES	OFF
14	0.64	115	73.6	8.4	7.96	28.9	YES	OFF
15	0.64	115	73.6	8.3	7.95	29.0	YES	OFF
16	0.62	115	71.3	8.1	7.94	29.2	YES	OFF
17	0.63	115	72.5	8.4	7.84	27.7	YES	OFF
18	0.66	115	75.9	8.7	7.91	27.9	YES	1000
19	0.69	115	79.4	8.9	7.92	27.7	YES	1000
20	0.70	115	80.5	8.8	7.94	28.2	YES	1000
21	0.71	115	81.7	9.1	7.88	27.0	YES	1000
22	0.72	115	82.8	9.5	7.91	26.6	YES	1000
23	0.72	115	82.8	9.6	7.80	25.4	YES	1000
24	0.73	115	84.0	9.5	7.86	26.2	YES	1000
25	0.70	115	80.5	9.5	8.25	30.0	YES	1000
26	0.74	115	85.1	9.5	8.18	29.4	YES	1000
27	0.74	115	85.1	9.9	7.80	25.0	YES	1000
28	0.73	115	84.0	10.3	7.53	22.1	YES	1000
29	0.73	115	84.0	10.1	7.67	23.5	YES	1000
30	0.72	115	82.8	10.3	7.82	24.4	YES	1000
31	0.72	115	82.8	10.4	7.93	25.2	YES	1000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012