


OHA - Drinking Water Program -Turbidity Monitoring Report Form							County:	Tillamook
Conventional or Direct Filtration							Month/Year:	2/1/2024
System Name:	City of Tillamook			ID#: 41	00893		WTP : TP -	Combined
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.036	OFF	0.038	0.038	0.040	0.040	0.040	
2	0.040	OFF	0.039	0.037	0.024	0.038	0.040	
3	0.039	0.040	0.037	0.037	0.058	0.035	0.058	
4	0.036	OFF	0.038	0.040	0.038	0.040	0.040	
5	0.039	0.040	0.040	0.036	0.040	0.040	0.040	
6	0.040	OFF	0.040	0.038	0.040	0.041	0.041	
7	0.036	OFF	0.057	0.038	0.038	0.038	0.057	
8	0.036	0.036	OFF	0.040	0.040	0.038	0.040	
9	OFF	OFF	0.040	0.030	0.040	0.038	0.040	
10	0.037	OFF	0.040	0.032	0.040	0.040	0.040	
11	0.040	OFF	0.040	0.039	0.039	0.038	0.040	
12	0.040	0.040	0.038	0.021	0.038	0.038	0.040	
13	0.043	0.020	0.036	0.020	0.040	0.040	0.040	
14	0.040	0.040	0.040	0.038	0.040	0.038	0.040	
15	0.037	OFF	0.036	0.041	OFF	0.037	0.041	
16	0.036	0.040	0.048	0.039	0.038	0.038	0.048	
17	0.040	OFF	0.036	0.043	0.040	0.040	0.040	
18	0.040	OFF	0.040	0.036	0.044	0.039	0.044	
19	0.040	0.040	OFF	0.037	0.040	0.041	0.041	
20	0.041	0.037	0.037	0.052	OFF	0.039	0.052	
21	0.040	0.040	0.039	OFF	0.040	0.040	0.040	
22	OFF	0.041	0.038	0.038	0.039	0.037	0.041	
23	0.018	OFF	0.020	0.038	0.037	0.040	0.040	
24	0.040	0.040	0.039	0.037	0.037	0.040	0.040	
25	0.036	OFF	OFF	0.039	0.038	0.037	0.039	
26	0.038	OFF	0.042	0.040	0.040	0.039	0.042	
27	0.021	0.040	0.024	0.040	0.040	0.040	0.040	
28	0.039	0.038	0.041	0.039	0.039	0.039	0.041	
29	0.045	0.052	0.040	0.028	0.062	0.038	0.062	
30								
31								
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings \leq 0.3 NTU?				Yes	CT's met everyday? (see back)		All Cl2 residual at entry point \geq 0.2 mg/l?	
All daily turbidity readings \leq 1 NTU?				Yes	Yes		Yes	
All turbidity readings < IFE ² triggers				Yes				
PRINTED NAME: Levi Beachy					SIGNATURE: 		3/1/2024	
					PHONE #: (503) 812-8804			
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))								

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP - :	A
System Name:	City of Tillamook		ID#: 41	00893	Month/Year:	Jan-24	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.73	115	84.0	10.2	7.97	26.0	YES	1000
2	0.74	115	85.1	9.9	8.02	27.0	YES	1000
3	0.74	115	85.1	9.4	8.03	28.1	YES	1000
4	0.75	115	86.3	9.0	8.10	29.6	YES	1000
5	0.75	115	86.3	9.2	8.12	29.4	YES	1000
6	0.76	115	87.4	9.2	8.03	28.5	YES	1000
7	0.75	115	86.3	9.1	8.05	28.9	YES	1000
8	0.75	115	86.3	8.9	8.09	29.7	YES	1000
9	0.75	115	86.3	9.0	8.08	29.4	YES	1000
10	0.77	115	88.6	9.0	8.07	29.3	YES	1000
11	0.74	115	85.1	9.2	8.11	29.3	YES	1000
12	0.74	115	85.1	9.3	8.06	28.5	YES	1000
13	0.75	115	86.3	8.9	8.11	29.9	YES	1000
14	0.72	115	82.8	8.6	8.07	30.0	YES	1000
15	0.72	115	82.8	8.8	8.05	29.4	YES	1000
16	0.72	115	82.8	9.0	8.07	29.2	YES	1000
17	0.72	115	82.8	8.8	8.10	29.9	YES	1000
18	0.73	115	84.0	8.9	8.08	29.5	YES	1000
19	0.75	115	86.3	9.2	8.06	28.8	YES	1000
20	0.76	115	87.4	9.4	8.08	28.6	YES	1000
21	0.74	115	85.1	9.6	8.23	29.7	YES	1000
22	0.77	115	88.6	9.3	8.00	28.0	YES	1000
23	0.74	115	85.1	9.1	8.13	29.7	YES	1000
24	0.73	115	84.0	9.0	8.07	29.2	YES	1000
25	0.72	115	82.8	9.3	8.08	28.7	YES	1000
26	0.72	115	82.8	9.1	8.00	28.3	YES	1000
27	0.71	115	81.7	8.5	8.03	29.7	YES	1000
28	0.71	115	81.7	9.0	8.05	28.9	YES	1000
29	0.70	115	80.5	9.1	7.73	25.6	YES	1000
30		115	0.0			4.2		
31		115	0.0			4.2		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012