

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

**System Name: TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: APRIL 2021**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1				.03			.04
2				.03			.03
3				.03			.03
4				.03			.04
5				.02			.03
6				.02			.03
7				.02			.03
8				.02			.03
9				.02			.03
10				.03			.03
11				.03			.03
12				.03			.03
13				.03			.03
14				.03			.03
15				.03			.03
16				.03			.03
17				.03			.03
18				.03			.03
19				.03			.03
20				.03			.03
21				.03			.03
22				.03			.03
23				.03			.03
24				.03			.03
25				.03			.03
26				.03			.03
27				.03			.03
28				.03			.03
29				.03			.03
30				.03			.03
31							

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
<b>Notes:</b>		PRINTED NAME: <i>Jeff Burch</i>	DATE: <i>5-10-21</i>
		SIGNATURE: <i>Jeff Burch</i>	CERT #: <i>6091</i>
		PHONE #: <i>503 1816-0958</i>	

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

## OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP: WTP-A Month/Year: APRIL 2021

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/21:05	1.08	72	77.76	10.8	7.90	27	Yes	14
2/21:35	1.17		84.24	11.1	7.90	27	Yes	14
3/19:35	1.11		79.92	11.8	7.90	27	Yes	14
4/18:45	.94		67.68	11.3	7.90	27	Yes	14
5/23:53	.84		60.48	9.1	8.0	36	yes	14
6/16:45	1.06		76.32	9.4	8.0	37	yes	14
7/20:45	1.07		77.04	9.2	8.0	37	yes	14
8/16:30	1.04		74.88	9.1	8.0	37	yes	14
9/11:00	.87		62.64	8.6	7.9	36	yes	14
10/16:45	1.01		72.72	11.4	7.90	27	Yes	14
11/19:35	.84		60.48	10.6	7.90	26	Yes	14
12/14:55	.95		68.40	10.5	7.90	27	Yes	14
13/18:25	1.07		77.04	10.8	7.90	27	Yes	14
14/14:55	.83		59.76	11.2	7.90	26	Yes	14
15/21:35	.88		63.36	11.5	7.90	26	Yes	14
16/18:35	.85		61.20	11.8	7.90	26	Yes	14
17/20:05	.84		60.48	11.8	7.90	26	Yes	14
18/19:05	.83		59.76	11.8	7.90	26	Yes	14
19/23:00	.62		44.64	10.7	7.90	26	yes	14
20/14:00	.69		48.38	11.3	7.70	26	yes	14
21/12:30	1.13		81.36	10.9	7.80	28	yes	14
22/14:55	1.10		79.20	10.5	7.90	27	Yes	14
23/20:05	1.06		76.32	10.9	7.90	27	Yes	14
24/20:05	.88		63.36	10.8	7.90	26	Yes	14
25/18:05	.90		64.80	11.4	7.90	27	Yes	14
26/14:55	.76		54.72	11.7	7.90	26	Yes	14
27/19:05	.96		69.12	12.3	7.90	27	Yes	14
28/15:05	.87		62.64	12.7	7.90	26	Yes	14
29/17:40	.82		59.04	12.3	7.90	26	Yes	14
30/22:35	1.11		79.92	12.1	7.90	27	Yes	14
31/								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.