

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: **TIMBER WATER ASSOCIATION** ID #: **OR4100898** WTP-: **WTP-A** Month/Year: **JUNE 2021**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.03			.03
2				.03			.03
3				.03			.03
4				.03			.03
5				.03			.03
6				.03			.06
7				.06			.06
8				.04			.04
9				.03			.03
10				.03			.03
11				.03			.03
12				.03			.03
13				.03			.03
14				.03			.03
15				.03			.03
16				.03			.03
17				.03			.03
18				.03			.03
19				.03			.03
20				.03			.03
21				.03			.03
22				.03			.03
23				.03			.03
24				.03			.04
25				.03			.03
26				.03			.03
27				.03			.04
28				.03			.13
29				.05			.05
30				.03			.03
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Notes:	PRINTED NAME: Jeff Burch	
	SIGNATURE: <i>[Signature]</i>	DATE: 7-9-21
	PHONE #: (503) 816-0968	CERT #: 6091

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP: WTP-A Month/Year: JUNE 2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/19/05	.86	72	61.92	15.0	7.90	18	Yes	16
2/21/45	.97		69.84	16.4	7.90	18	Yes	16
3/14/45	.80		57.60	15.8	7.90	18	Yes	16
4/18/55	.86		61.92	15.5	7.90	18	Yes	16
5/18/05	.99		71.28	14.6	7.90	27	Yes	16
6/6/35	.94		67.68	14.1	7.80	27	Yes	16
7/20/20	.78		58.16	14.4	7.50	22	Yes	20
8/22/35	.60		43.20	12.5	7.60	26	Yes	20
9/12/00	.69		49.68	12.9	7.50	22	Yes	20
10/22/25	.86		61.92	12.8	7.50	22	Yes	20
11/20/32	.68		48.96	12.7	7.60	26	Yes	20
12/20/45	.60		43.20	12.7	7.70	26	Yes	20
13/15/50	.62		43.40	13.0	7.50	22	Yes	20
14/14/54	1.21		87.12	14.1	7.70	28	Yes	20
15/16/55	1.00		72	14.2	7.80	27	Yes	20
16/22/05	.90		64.80	15.4	7.80	18	Yes	20
17/16/35	1.03		74.16	15.8	7.90	18	Yes	20
18/21/35	1.00		72	14.7	7.80	27	Yes	20
19/19/45	.94		67.68	15.3	7.80	18	Yes	20
20/21/45	.80		57.60	16.1	7.80	18	Yes	20
21/21/55	.68		48.96	15.9	7.80	17	Yes	20
22/11/35	.87		62.64	16.5	7.80	18	Yes	20
23/21/35	.72		51.84	16.8	7.80	18	Yes	20
24/11/35	1.10		79.20	17.3	7.80	18	Yes	20
25/21/05	.99		71.28	17.8	7.80	18	Yes	20
26/12/25	.90		64.80	18.2	7.70	18	Yes	20
27/22/05	.71		51.12	18.6	7.80	17	Yes	20
28/21/35	.66		47.52	18.4	7.70	17	Yes	20
29/11/45	.68		48.96	18.3	7.70	17	Yes	20
30/15/55	.88	V	63.36	18.9	7.70	18	Yes	20
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day