

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **TIMBER WATER ASSOCIATION** ID #: **OR4100898** WTP-: **WTP-A** Month/Year: **July 2021**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.03			.04
2				.03			.03
3				.04			.04
4				.03			.03
5				.04			.04
6				.04			.04
7				.04			.04
8				.04			.04
9				.04			.04
10				.04			.04
11				.04			.04
12				.05			.05
13				.05			.05
14				.06			.06
15				.07			.08
16				.05			.07
17				.03			.03
18				.03			.03
19				.03			.03
20				.04			.04
21				.03			.03
22				.03			.03
23				.03			.04
24				.03			.04
25				.03			.03
26				.03			.03
27				.03			.04
28				.03			.04
29				.03			.03
30				.03			.03
31				.03			.04

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings \leq 5 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Notes:	PRINTED NAME: Jeff Burch	DATE: 8-9-21
	SIGNATURE: <i>[Signature]</i>	CERT #: 6091
	PHONE #: (503) 816-0958	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: July 2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/16:45	.78	72	56.16	19.1	7.80	18	Yes	20
2/19:05	.71		51.12	17.3	7.80	17	Yes	20
3/15:05	.79		56.88	17.2	7.80	18	Yes	20
4/21:40	.68		48.96	17.5	7.80	17	Yes	20
5/14:05	.88		63.36	19.0	7.80	18	Yes	20
6/16:30	.70		50.4	17.1	7.90	18	Yes	20
7/13:15	.78		56.16	17.0	7.80	18	Yes	20
8/11:15	.96		69.12	18.0	7.80	18	Yes	20
9/15:30	.64		46.08	17.1	7.80	17	Yes	20
10/16:15	.70		50.4	18.0	7.80	18	Yes	20
11/17:20	.75		54	18.3	7.80	18	Yes	20
12/21:45	.85		61.2	17.8	7.80	18	Yes	20
13/20:05	.80		57.6	18.2	7.90	18	Yes	20
14/21:55	.85		61.2	17.3	7.80	18	Yes	20
15/13:25	1.08		77.76	17.8	7.70	18	Yes	20
16/21:05	.72		51.84	17.3	7.90	18	Yes	20
17/20:05	.79		56.88	17.5	7.80	18	Yes	20
18/19:55	.71		51.12	17.8	7.80	18	Yes	20
19/14:00	.88		63.36	17.9	7.80	18	Yes	20
20/19:45	.93		66.96	18.0	7.80	18	Yes	20
21/17:35	.80		57.6	17.5	7.80	18	Yes	20
22/19:00	.62		43.4	17.0	7.80	17	Yes	20
23/10:00	.68		48.96	17.3	7.80	17	Yes	20
24/10:00	.73		52.56	17.8	7.80	18	Yes	20
25/11:50	.67		48.24	17.2	7.80	17	Yes	20
26/17:05	1.01		72.72	18.3	7.80	18	Yes	20
27/21:45	.99		71.28	18.5	7.90	18	Yes	12
28/16:05	.89		64.08	18.5	7.90	18	Yes	12
29/13:05	.86		61.92	18.8	7.90	18	Yes	12
30/14:05	.77		55.44	19.0	7.80	18	Yes	12
31/20:05	.68	↓	48.96	19.1	7.80	17	Yes	12

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.