

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **TIMBER WATER ASSOCIATION** ID #: **OR4100898** WTP: **WTP-A** Month/Year: **October / 2021**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.10			.10
2				.11			.11
3				.14			.17
4				.13			.14
5				.15			.19
6				.04			.06
7				.04			.04
8				.04			.04
9				.04			.07
10				.04			.05
11				.05			.05
12				.05			.05
13				.05			.05
14				.06			.06
15				.06			.06
16				.07			.07
17				.12			.12
18				.09			.09
19				.10			.10
20				.03			.03
21				.04			.05
22				.07			.07
23				.08			.09
24				.09			.09
25				.13			.13
26				.12			.18
27				.15			.17
28				.18			.19
29				.22			.28
30				.30			.32
31				.33			.33

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All daily turbidity readings \leq 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	Notes:		
PRINTED NAME: Jeff Burch		DATE: 11-8-21	
SIGNATURE: <i>Jeff Burch</i>		CERT # 6091	
PHONE #: (503) 816-0958			

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only

OHA - Drinking Water Program - Surface Water Quality Data Form

TIMBLER WATER ASSOCIATION ID #: OR4100898 WTP: WTP-A Month/Year: October / 2002

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1/19/02	.81	1.2	58.32	15.1	7.80	18	Yes	10
2/19/02	1.02		73.41	15.9	7.80	18	Yes	10
3/15/02	.97		69.84	16.1	7.80	18	Yes	10
4/21/02	.93		66.96	15.0	7.80	18	Yes	10
5/20/02	1.08		77.16	15.6	7.80	18	Yes	10
6/21/02	.90		64.8	15.8	7.80	18	Yes	10
7/18/02	.73		52.56	16.3	7.80	18	Yes	10
8/15/02	.81		58.32	15.1	7.80	18	Yes	10
9/11/02	.99		71.28	15.2	7.80	18	Yes	10
10/16/02	.96		69.12	14.5	7.80	27	Yes	10
11/11/02	.89		64.08	14.3	7.80	27	Yes	10
12/18/02	1.10		79.2	14.6	7.80	27	Yes	10
13/21/02	.90		64.8	14.5	7.80	27	Yes	10
14/19/02	.72		51.84	14.1	7.80	27	Yes	10
15/13/02	.71		51.12	15.6	7.80	18	Yes	10
16/13/02	.76		54.72	15.1	7.80	18	Yes	10
17/11/02	.79		56.88	14.7	7.80	26	Yes	10
18/21/02	.65		46.80	12.6	7.80	26	Yes	10
19/18/02	.73		52.56	13.8	7.80	26	Yes	10
20/15/02	.81		58.32	14.3	7.80	26	Yes	10
21/12/02	.86		61.92	12.5	7.80	26	Yes	10
22/12/02	.69		49.68	12.6	7.80	26	Yes	10
23/11/02	.71		51.12	12.6	7.80	26	Yes	10
24/14/02	.64		46.08	12.8	7.80	26	Yes	10
25/11/02	.67		48.24	12.5	7.80	26	Yes	10
26/16/02	.73		52.56	13.0	7.80	26	Yes	10
27/17/02	.78		56.16	12.7	7.80	26	Yes	10
28/18/02	.75		51	13.1	7.80	26	Yes	10
29/13/02	.67		48.24	13.0	7.80	26	Yes	10
30/9/02	.75		54	12.7	7.80	26	Yes	10
31/15/02	.69		49.68	12.0	7.80	26	Yes	10

If Cl₂ at entry point < 0.2 mg/L OR CT not met, notify DWP by end of next business day