

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: October / 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.04			.04
2				.04			.04
3				.04			.04
4				.05			.05
5				.05			.05
6				.05			.05
7				.05			.06
8				.05			.05
9				.06			.07
10				.06			.06
11				.06			.06
12				.06			.06
13				.07			.07
14				.07			.08
15				.07			.07
16				.07			.08
17				.08			.08
18				.08			.08
19				.08			.08
20				.09			.09
21				.09			.11
22				.12			.12
23				.09			.09
24				.09			.10
25				.10			.10
26	PLANT SHUTDOWN POWER OUTAGE						
27	NO TEST RAN TODAY						
28				.10			.10
29	plant shutdown power outage						
30	plant shutdown power outage						
31	NO TEST RAN TODAY						

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² <input checked="" type="radio"/> Yes / No All daily turbidity readings \leq 5 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / No
Notes:	PRINTED NAME: Jeff Burch	DATE: 1-10-22
	SIGNATURE: <i>Jeff Burch</i>	CERT #: 6091
	PHONE #: (503) 816-0958	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: December/2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/20:00	.85	72	61.2	12.0	7.80	26	Yes	10
2/17:30	.71		51.12	11.3	7.96	26	Yes	10
3/17:45	.61		43.72	11.6	7.80	26	Yes	10
4/20:00	.69		49.68	11.3	7.80	26	Yes	10
5/13:30	.75		54	12.0	7.76	26	Yes	10
6/21:35	.84		60.48	11.8	7.90	26	Yes	10
7/14:45	.79		56.88	11.8	7.90	26	Yes	10
8/14:35	.63		45.36	11.4	7.90	26	Yes	10
9/14:35	.76		54.72	10.8	7.90	26	Yes	10
10/17:35	.73		52.56	11.2	7.90	26	Yes	10
11/14:35	.87		62.64	11.7	7.80	26	Yes	10
12/20:05	.93		66.96	12.9	7.80	27	Yes	10
13/20:30	.75		54	11.5	7.80	26	Yes	10
14/16:30	.85		61.2	11.1	7.80	26	Yes	10
15/19:30	1.10		79.2	10.9	7.90	26	Yes	10
16/14:30	.84		60.48	11.6	7.80	26	Yes	10
17/11:30	.79		71.28	10.9	7.80	26	Yes	10
18/17:00	.75		54	10.3	7.80	26	Yes	10
19/16:00	.65		46.8	11.3	7.80	26	Yes	10
20/20:05	.88		63.36	11.0	7.80	26	Yes	10
21/21:05	.81		58.32	10.8	7.80	26	Yes	10
22/16:05	.63		45.36	10.5	7.80	26	Yes	10
23/17:05	.98		70.56	10.0	7.80	27	Yes	10
24/19:55	.92		66.24	9.5	7.80	35	Yes	10
25/16:15	.89		64.08	9.2	7.80	35	Yes	10
26/	PLANT		SHUTDOWN		POWER		OUTAGE	
27/	NO		TEST		RAN		TODAY	
28/14:30	.89		64.08	9.1	7.80	35	Yes	10
29/	Plant		Shutdown		Power		outage	
30/	Plant		Shutdown		Power		outage	
31/	NO		TEST		RAN		TODAY	

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.