

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: January/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.03			.03
2				.03			.04
3				.03			.03
4				.04			.04
5				.04			.04
6				.04			.04
7				.04			.04
8	PLANT SHUT DOWN VFD FAILED						
9				.06			.06
10				.04			.04
11				.04			.05
12				.05			.05
13				.06			.06
14				.08			.08
15				.07			.08
16				.08			.09
17				.08			.08
18				.08			.08
19				.08			.09
20				.10			.11
21				.10			.10
22				.10			.10
23				.10			.10
24				.10			.10
25				.10			.10
26				.10			.10
27				.10			.10
28				.10			.10
29				.10			.10
30				.10			.10
31				.10			.10

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Notes:	PRINTED NAME: Jeff Burch	
	SIGNATURE: <i>JMB</i>	DATE: 1-14-22
	PHONE #: (503) 816-0958	CERT #: 6091

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP: WTP-A Month/Year: January / 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/1/22	.80	72	57.6	9.7	7.80	35	Yes	10
2/1/22	.93		57.76	9.8	7.80	35	Yes	10
3/1/22	.81		58.32	8.6	7.80	35	Yes	10
4/1/22	.70		50.4	8.8	7.70	35	Yes	10
5/1/22	.77		55.44	8.0	7.70	35	Yes	10
6/1/22	1.19		85.68	8.0	7.80	37	Yes	10
7/1/22	1.10		79.2	8.2	7.80	36	Yes	10
8/1/22	PLANT SHUT DOWN VFD FAILED							
9/1/22	1.16		83.52	8.5	7.80	36	Yes	10
10/1/22	.91		65.52	9.1	7.80	35	Yes	10
11/1/22	.89		64.08	8.8	7.80	35	Yes	10
12/1/22	.63		45.36	10.1	7.80	35	Yes	10
13/1/22	.66		47.52	10.3	7.80	25	Yes	10
14/1/22	.71		51.12	10.1	7.80	35	Yes	10
15/1/22	.69		49.68	10.6	7.80	35	Yes	10
16/1/22	.73		52.56	9.9	7.80	35	Yes	10
17/1/22	.76		54.72	10.1	7.80	26	Yes	10
18/1/22	.65		46.8	10.2	7.90	26	Yes	10
19/1/22	.87		62.64	11.3	7.90	26	Yes	10
20/1/22	1.06		76.37	10.7	7.90	27	Yes	10
21/1/22	.97		69.84	9.9	7.90	36	Yes	10
22/1/22	.85		61.2	9.6	7.90	35	Yes	10
23/1/22	.91		65.52	9.3	7.90	35	Yes	10
24/1/22	.97		69.84	9.5	7.90	35	Yes	10
25/1/22	.80		61.92	9.7	7.90	35	Yes	10
26/1/22	.78		56.16	9.9	7.80	35	Yes	10
27/1/22	.92		66.24	9.5	7.80	35	Yes	10
28/1/22	.78		56.16	9.8	7.80	35	Yes	10
29/1/22	.80		57.6	9.8	7.80	35	Yes	10
30/1/22	.67		48.24	9.3	7.90	35	Yes	10
31/1/22	.77		55.44	9.5	7.90	35	Yes	10

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.