

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **TIMBER WATER ASSOCIATION** ID #: **OR4100898** WTP-: **WTP-A** Month/Year: **FEBRUARY 2021**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1				.10			.11
2				.11			.11
3				.11			.11
4				.11			.11
5				.11			.11
6				.11			.11
7				.01			.01
8				.01			.01
9				.01			.01
10				.01			.01
11				.01			.01
12				.02			.02
13				.02			.03
14				.02			.02
15				.02			.03
16				.04			.06
17				.05			.06
18				.08			.08
19				.08			.08
20				.02			.02
21		CLP		cleaning			
22				.02			.02
23				.02			.02
24				.02			.02
25				.02			.02
26				.02			.02
27				.04			.04
28				.02			.05
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> Yes / No All daily turbidity readings ≤ 5 NTU? Yes / No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) Yes / No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes / No
Notes:	PRINTED NAME: <i>Jeff Burch</i>	
	SIGNATURE: <i>Jeff Burch</i>	DATE: <i>3-4-22</i>
	PHONE #: <i>(303) 816-0958</i>	CERT #: <i>609'</i>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

## OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: FEBRUARY 2022

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/18:35	.73	72	52.56	9.7	7.80	34	Yes	10
2/21:45	.95		68.4	9.9	7.80	36	Yes	10
3/18:45	1.03		74.16	9.3	7.90	36	Yes	10
4/20:35	.99		71.28	9.6	7.90	36	Yes	10
5/15:05	.93		66.96	9.7	7.90	35	Yes	10
6/14:35	.84		60.48	10.3	7.90	26	Yes	10
7/12:30	1.01		72.72	10.0	7.90	26	Yes	10
8/16:00	.75		54	10.1	7.90	26	Yes	10
9/20:06	1.03		74.16	10.0	7.90	26	Yes	10
10/16:30	1.08		77.76	10.5	7.90	26	Yes	10
11/21:06	.83		59.76	10.7	7.90	26	Yes	10
12/20:45	.77		56.88	10.9	7.90	26	Yes	10
13/17:30	.94		67.68	10.7	7.90	26	Yes	10
14/20:45	.96		69.12	10.8	7.90	27	Yes	10
15/19:25	.88		63.36	10.5	7.90	26	Yes	10
16/20:50	.76		54.72	10.5	7.90	26	Yes	10
17/21:25	1.05		75.6	10.3	7.90	27	Yes	10
18/11:05	1.04		74.88	10.1	7.90	27	Yes	10
19/16:35	1.10		79.2	10.0	7.90	27	Yes	10
20/21:40	1.14		82.08	10.0	7.90	27	Yes	10
21/18:30	1.12		80.64	10.5	7.90	26	Yes	10
22/	CLO			cleaning				
23/17:00	.90		64.8	8.7	7.80	36	Yes	10
24/20:00	.74		53.28	8.9	7.80	36	Yes	10
25/7:30	.78		56.16	9.3	7.80	36	Yes	10
26/22:00	.69		49.68	8.2	7.80	36	Yes	10
27/15:00	.73		52.56	8.9	7.80	36	Yes	10
28/21:35	.70	▼	50.4	10.0	7.90	26	Yes	10
29/								
30/								
31/								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.