

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: MARCH 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.03			.05
2				.03			.04
3				.03			.05
4				.04			.04
5				.04			.06
6				.04			.04
7				.04			.05
8				.04			.04
9				.04			.04
10				.05			.05
11				.05			.05
12				.04			.05
13				.04			.04
14				.04			.05
15				.04			.04
16				.04			.05
17				.04			.04
18				.04			.04
19				.04			.04
20				.04			.05
21				.04			.05
22				.05			.05
23				.05			.05
24				.05			.05
25				.05			.05
26				.05			.05
27				.05			.06
28				.05			.05
29				.06			.06
30				.06			.06
31				.06			.06

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: Jeff Burch	DATE: 4-15-22
	SIGNATURE: <i>Jeff Burch</i>	CERT #: 6091
	PHONE #: 503 1816-0958	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: MARCH 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/19:20	.81	72	58.32	10.8	7.90	26	Yes	10
2/21:35	.76		54.72	11.6	7.90	26	Yes	10
3/17:25	.99		71.28	11.1	7.90	27	Yes	10
4/16:05	.87		62.64	10.5	7.80	27	Yes	10
5/15:05	.71		51.12	10.2	7.80	26	Yes	10
6/18:05	.63		45.36	10.0	7.80	26	Yes	10
7/20:30	.60		43.2	10.3	7.80	26	Yes	10
8/16:00	.74		53.28	10.8	7.80	26	Yes	10
9/16:00	.62		44.64	10.9	7.80	26	Yes	10
10/17:00	.65		46.8	10.8	7.80	26	Yes	10
11/19:00	.72		51.84	10.3	7.80	26	Yes	10
12/12:30	.80		57.6	9.7	7.80	35	Yes	10
13/19:30	.69		49.68	9.8	7.80	34	Yes	10
14/15:35	1.04		74.88	10.2	7.80	27	Yes	10
15/19:35	.81		58.32	10.3	7.90	26	Yes	10
16/15:35	1.06		76.32	10.9	7.90	27	Yes	10
17/21:05	.98		70.56	10.4	7.90	27	Yes	10
18/13:05	.82		59.04	10.2	7.90	26	Yes	10
19/13:05	.78		56.16	10.2	7.90	26	Yes	10
20/17:05	.65		46.8	10.0	7.90	26	Yes	10
21/17:00	1.10		79.2	10.8	7.90	26	Yes	10
22/18:00	.95		68.4	11.1	7.90	27	Yes	10
23/17:00	.71		51.12	11.4	7.80	27	Yes	10
24/19:00	.79		56.88	12.8	7.80	27	Yes	10
25/20:00	.83		59.76	12.3	7.90	27	Yes	10
26/19:00	.94		67.68	12.6	7.90	27	Yes	10
27/20:00	.87		62.64	11.9	7.80	27	Yes	10
28/22:05	.96		69.12	11.7	7.90	27	Yes	10
29/20:35	.81		58.32	11.9	7.90	26	Yes	10
30/21:35	.74		53.24	11.9	7.90	26	Yes	10
31/20:25	.92	↓	66.24	12.6	7.90	26	Yes	10

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.