

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year:

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.06			.06
2				.06			.06
3				.07			.06
4	Storm plant shutdown						
5	Maintenance shutdown						
6	no maintenance shutdown						
7	maintenance shutdown						
8							
9				.13			.15
10				.17			.18
11				.02			.02
12				.02			.05
13				.02			.02
14				.02			.02
15				.02			.07
16				.02			.02
17				.02			.02
18				.02			.02
19				.02			.02
20				.02			.02
21				.02			.02
22				.02			.02
23				.02			.02
24				.02			.04
25				.02			.02
26				.02			.04
27				.03			.03
28				.03			.03
29				.03			.03
30	NO TEST - PLANT MAINTENANCE						
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings \leq 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: Jeff Burk	DATE: 5-6-22
	SIGNATURE: <i>Jeff Burk</i>	CERT #: 6091
	PHONE #: (503) 816-095	

Including continuous turbidity data, if applicable, for optimization recording purposes Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: APRIL 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/21:20	.91	72	65.52	11.1	7.90	26	Yes	10
2/16:30	.88		63.36	10.9	7.90	26	Yes	10
3/18:45	.85		61.2	11.0	7.90	26	Yes	10
4/	storm		plant			shutdown		
5/	maint					shutdown		
6/	maint					shutdown		
7/	maint					shutdown		
8/18:00	.87		62.64	11.9	7.90	26	Yes	10
9/13:00	.74		53.28	10.9	7.90	26	Yes	10
10/17:30	.83		59.76	11.5	7.80	26	Yes	10
11/23:05	.71		51.12	10.4	7.90	26	Yes	10
12/20:05	.63		45.36	10.1	7.80	26	Yes	10
13/21:35	.79		56.88	10.3	7.80	26	Yes	10
14/20:55	.72		51.84	10.5	7.80	26	Yes	10
15/20:35	1.04		74.88	10.9	7.80	27	Yes	10
16/23:05	.96		69.12	9.8	7.80	34	Yes	10
17/20:05	.71		51.12	9.5	7.80	36	Yes	10
18/19:30	.65		46.8	10.3	7.80	26	Yes	10
19/17:30	.85		61.2	10.5	7.80	26	Yes	10
20/21:45	1.02		73.44	10.4	7.80	27	Yes	10
21/18:00	.91		65.52	10.6	7.80	27	Yes	10
22/17:00	.89		64.08	10.9	7.80	27	Yes	10
23/11:30	1.10		79.2	10.5	7.80	27	Yes	10
24/16:30	1.11		79.92	11.5	7.80	27	Yes	16
25/21:55	.87		62.64	12.3	7.90	26	Yes	10
26/17:45	1.00		72	12.1	7.80	27	Yes	10
27/21:55	.95		68.4	12.7	7.80	27	Yes	10
28/17:05	.90		64.8	12.5	7.80	27	Yes	10
29/16:35	.88		63.36	12.5	7.80	26	Yes	10
30/	NO							TEST RAN - PLANT MAINTENANCE
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day