

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **TIMBER WATER ASSOCIATION** ID #: **OR4100898** WTP-: **WTP-A** Month/Year: **MAY 2022**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.03			.08
2				.03			.04
3				.02			.09
4				.02			.03
5				.02			.02
6				.02			.02
7				.02			.02
8				.02			.02
9				.02			.02
10				.03			.03
11				.02			.03
12				.02			.03
13				.02			.02
14				.02			.03
15				.03			.03
16				.04			.04
17				.03			.03
18				.03			.03
19			Computer	mess	UP		
20				.04			.04
21				.04			.04
22				.07			.07
23				.05			.06
24				.05			.06
25				.07			.07
26				.07			.08
27				.08			.08
28				.09			.10
29				.11			.12
30				.02			.02
31				.01			.01

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings \leq 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings \leq 5 NTU? <input checked="" type="checkbox"/> Yes / No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Notes:	PRINTED NAME: <i>Jeff Bush</i>	DATE: <i>6-7-22</i>
	SIGNATURE: <i>Jeff Bush</i>	CERT #: <i>6091</i>
	PHONE #: <i>(503) 816-0958</i>	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: MAY 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual - CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/17:05	.84	72	60.48	12.3	7.80	26	Yes	10
2/22:25	.62		44.64	12.3	7.80	26	Yes	10
3/19:45	1.07		77.04	12.6	7.90	27	Yes	10
4/22:45	.98		70.56	13.2	7.90	27	Yes	10
5/22:05	.87		62.64	13.1	7.90	26	Yes	10
6/23:05	.89		64.08	12.9	7.80	26	Yes	10
7/21:25	.91		65.52	12.6	7.90	26	Yes	10
8/14:35	.86		61.92	12.6	7.80	26	Yes	10
9/16:05	.81		58.32	12.3	7.80	26	Yes	10
10/19:05	1.11		79.92	10.9	7.90	27	Yes	10
11/22:35	1.08		77.76	10.8	7.90	27	Yes	10
12/21:45	1.04		74.88	11.0	7.90	27	Yes	10
13/16:05	1.00		72	11.4	7.90	27	Yes	10
14/20:05	.95		68.4	11.4	7.90	27	Yes	10
15/19:05	.98		70.56	11.2	7.90	27	Yes	10
16/19:00	1.00		72	11.0	7.90	27	Yes	10
17/16:30	.71		51.2	12.8	7.80	26	Yes	10
18/10:30	1.01		72.72	11.4	7.80	27	Yes	8
19/15:30	.77		55.44	11.6	7.80	27	Yes	8
20/19:30	.80		57.6	12.8	7.90	27	Yes	8
21/17:30	.85		61.2	13.3	7.90	27	Yes	8
22/11:30	1.10		71.2	12.8	7.90	27	Yes	8
23/21:05	1.14		82.08	11.7	7.90	27	Yes	8
24/19:45	.97		69.84	12.1	7.90	27	Yes	8
25/21:55	.86		61.92	12.5	8.00	26	Yes	8
26/15:45	.95		68.4	12.8	7.90	27	Yes	8
27/22:45	.90		64.8	12.7	7.80	26	Yes	8
28/13:05	.83		59.76	13.2	7.80	26	Yes	8
29/18:15	.72		51.84	13.5	7.80	26	Yes	8
30/13:30	.68		48.96	12.8	7.80	26	Yes	8
31/17:00	.78		56.16	12.9	7.80	26	Yes	8

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.