

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: June 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.01			.01
2				.01			.01
3				.01			.01
4				.01			.01
5				.02			.02
6				.02			.02
7				.02			.02
8				.02			.02
9				.02			.03
10				.02			.02
11				.02			.02
12				.02			.02
13				.02			.02
14				.02			.02
15				.02			.05
16				.03			.06
17				.04			.06
18				.05			.05
19				.06			.06
20				.06			.06
21				.06			.07
22				.07			.08
23				.07			.08
24				.08			.08
25				.08			.08
26				.06			.06
27				.01			.02
28				.01			.01
29				.03			.03
30				.01			.03
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ² <input checked="" type="radio"/> Yes / No All daily turbidity readings \leq 5 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / No
Notes:	PRINTED NAME: <u>Jeff Burch</u>	
	SIGNATURE: <u>Jeff Burch</u>	DATE: <u>7-6-22</u>
	PHONE #: <u>(503) 816-0958</u>	CERT #: <u>6091</u>

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100896 WTP-: WTP-A Month/Year: June/2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/12:00	88	72	6336	13.0	7.90	26	Yes	8
2/18:00	.79		56.88	14.1	7.80	26	Yes	8
3/18:30	1.05		75.6	13.8	7.90	27	Yes	8
4/19:30	1.11		79.92	13.0	7.90	27	Yes	8
5/18:00	.81		58.32	14.1	7.80	26	Yes	8
6/16:35	.87		62.64	13.9	7.80	26	Yes	8
7/18:05	.80		57.60	14.2	7.80	26	Yes	8
8/22:45	.71		51.12	13.7	7.80	26	Yes	8
9/17:05	.99		71.28	14.1	7.80	27	Yes	8
10/20:05	1.02		73.44	13.4	7.80	27	Yes	8
11/20:35	.98		70.56	13.5	7.80	27	Yes	8
12/14:05	.68		48.96	13.7	7.80	26	Yes	8
13/20:00	.65		46.8	13.0	7.80	26	Yes	8
14/18:00	.67		48.2	13.8	7.80	26	Yes	8
15/18:00	.86		61.92	13.1	7.80	26	Yes	8
16/19:00	.80		57.6	12.7	7.80	26	Yes	8
17/18:30	.71		51.12	13.2	7.80	26	Yes	8
18/18:00	.66		47.52	13.2	7.80	26	Yes	10
19/20:30	.74		53.28	14.0	7.80	26	Yes	10
20/13:45	.96		69.12	14.2	7.90	27	Yes	16
21/15:05	.91		65.52	14.5	7.90	26	Yes	10
22/15:35	.87		62.64	14.8	7.90	26	Yes	10
23/21:05	.69		49.68	13.2	7.90	26	Yes	10
24/17:05	.88		63.36	14.3	7.90	26	Yes	10
25/15:35	.75		54	14.9	7.90	26	Yes	10
26/12:35	.71		51.12	15.5	7.80	17	Yes	12
27/16:30	1.11		79.92	15.0	7.80	17	Yes	12
28/17:30	.63		45.36	15.1	7.80	17	Yes	15
29/18:00	.64		46.08	15.5	7.80	17	Yes	15
30/20:00	.75		54	15.0	7.90	17	Yes	15
31/								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day